

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Oct-22

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
10	0.02	0.02	0.03	0.02	0.02	0.02	0.03		
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
12	0.03	0.02	0.02	0.02	0.02	0.02	0.03		
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
19	0.02	0.03	0.02	0.02	0.02	0.02	0.03		
20	0.02	0.02	0.02	0.03	0.02	0.02	0.03		
21	0.02	0.02	0.02	0.02	0.02	0.03	0.03		
22	0.03	0.04	0.02	0.02	0.02	0.02	0.04		
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02		

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Oct-22							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.25	110	137.5	20.4	7.57	25.0	yes	69
2	1.13	110	139.0	19.6	7.63	27.0	yes	74
3	1.06	110	116.6	19.3	7.63	27.0	yes	67
4	1.10	110	121.0	19.7	7.69	27.0	yes	65
5	1.22	110	134.2	18.9	7.69	29.0	yes	62
6	1.11	110	122.1	19.0	7.64	27.0	yes	68
7	1.15	110	126.5	18.7	7.69	29.0	yes	62
8	1.12	110	123.2	20.1	7.67	27.0	yes	75
9	1.00	110	110.0	20.0	7.44	28.0	yes	76
10	1.19	110	130.9	19.6	7.62	26.0	yes	71
11	1.40	110	154.0	19.7	7.63	27.0	yes	73
12	1.40	110	188.0	19.3	7.49	26.0	yes	107
13	1.20	110	154.0	19.2	7.59	27.0	yes	93
14	1.20	110	132.0	18.4	7.67	30.0	yes	101
15	0.91	110	100.1	19.6	7.65	27.0	yes	79
16	0.96	110	105.6	19.0	7.54	27.0	yes	84
17	1.00	110	112.2	18.9	7.44	27.0	yes	90
18	0.86	110	94.6	18.0	7.69	30.0	yes	98
19	1.13	110	124.3	17.8	7.73	31.0	yes	85
20	1.20	110	120.0	17.8	7.47	30.0	yes	73
21	1.60	110	143.0	16.9	7.47	32.0	yes	86
22	1.60	110	189.0	16.6	7.49	33.0	yes	84
23	1.30	110	137.0	16.3	7.51	33.0	yes	83
24	1.46	110	160.6	16.5	7.54	25.0	yes	85
25	1.40	110	154.0	15.9	7.52	36.0	yes	77
26	1.50	110	165.0	15.1	7.63	38.0	yes	71
27	1.50	110	165.0	15.5	7.65	37.0	yes	81
28	1.39	110	152.0	15.4	7.58	38.0	yes	74
29	1.61	110	177.1	15.3	7.62	36.0	yes	83
30	1.55	110	170.5	15.1	7.57	37.0	yes	81
31	1.39	110	152.9	14.8	7.60	38.0	yes	75

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX