

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration


Month/Year: Nov-22

System Name:		Georgia Pacific CPLP Wauna					ID #: OR4190416	WTP: TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
5	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
19	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
20	0.07	0.02	0.02	0.02	0.02	0.02	0.18	
21	0.02	OFF	OFF	OFF	OFF	0.02	0.04	
22	0.02	0.02	0.02	0.02	0.03	0.02	0.04	
23	0.02	0.02	OFF	OFF	0.02	0.02	0.05	
24	0.02	OFF	0.02	0.02	0.02	0.02	0.06	
25	OFF	OFF	OFF	OFF	OFF	OFF	0.07	
26	0.03	0.02	0.02	0.02	0.02	OFF	0.06	
27	OFF	OFF	OFF	OFF	OFF	OFF	0.05	
28	OFF	OFF	OFF	OFF	OFF	OFF	0.13	
29	OFF	OFF	OFF	OFF	0.02	OFF	0.09	
30	0.02	0.03	0.02	0.02	0.02	0.03	0.12	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:

Printed Name: Terry Force

SIGNATURE: 

Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna							ID #: OR4190416		Month/ Year: Nov-22		WTP - : A	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	Disinfection <i>Giardia</i> Log Inactiv:	CT Met? ³	Peak Hourly Demand Flow			
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]				
1	1.41	110	155.1	15.0	7.58	38.0	yes	69				
2	1.20	110	132.0	14.3	7.61	40.0	yes	94				
3	1.15	110	126.5	14.2	7.63	38.0	yes	76				
4	1.20	110	132.0	13.8	7.65	40.0	yes	83				
5	1.22	110	134.2	13.4	7.25	40.0	yes	80				
6	1.09	110	119.9	13.2	7.49	40.0	yes	80				
7	1.04	110	114.4	13.2	7.58	40.0	yes	90				
8	1.03	110	113.3	12.9	7.58	40.0	yes	98				
9	1.09	110	119.9	12.2	7.91	48.0	yes	89				
10	0.95	110	104.5	12.2	7.77	45.0	yes	97				
11	0.98	110	107.8	11.4	7.60	45.0	yes	97				
12	1.03	110	113.3	11.3	7.70	47.0	yes	91				
13	1.19	110	130.9	11.3	7.70	47.0	yes	87				
14	1.00	110	110.0	11.1	7.68	47.0	yes	89				
15	1.15	110	126.5	10.9	7.72	49.0	yes	92				
16	1.25	110	137.5	11.5	7.71	52.0	yes	91				
17	1.26	110	138.6	10.8	7.44	54.0	yes	97				
18	1.40	110	154.0	10.7	7.33	56.0	yes	100				
19	1.09	110	119.9	9.4	7.84	58.0	yes	90				
20	1.35	110	148.5	9.1	7.84	61.0	yes	87				
21	1.53	110	168.3	8.9	7.86	61.0	yes	96				
22	1.38	110	151.8	9.0	7.82	61.0	yes	95				
23	1.30	110	143.0	8.6	7.58	57.0	yes	99				
24	1.15	110	126.5	9.6	7.57	52.0	yes	118				
25	1.27	110	139.7	10.1	7.61	55.0	yes	120				
26	1.47	110	161.7	9.0	7.45	58.0	yes	102				
27	1.43	110	157.3	8.5	7.54	56.0	yes	105				
28	1.40	110	141.0	8.7	7.72	59.0	yes	105				
29	1.42	110	156.2	8.2	7.54	59.0	yes	102				
30	1.38	110	151.8	8.2	7.65	59.0	yes	104				

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.