


Conventional or Direct Filtration							Month/Year:	Dec-22
System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416	WTP : TP - A		
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	0.03	0.02	0.02	0.02	OFF	0.25	
2	OFF	0.02	0.02	0.03	0.03	OFF	0.13	
3	OFF	OFF	OFF	OFF	0.02	0.02	0.07	
4	0.02	0.03	0.02	0.02	0.03	0.03	0.07	
5	0.03	0.03	0.03	0.03	0.03	0.02	0.07	
6	0.03	0.02	0.02	0.02	OFF	0.02	0.06	
7	OFF	OFF	OFF	0.03	OFF	OFF	0.12	
8	OFF	OFF	OFF	OFF	0.03	0.02	0.15	
9	0.02	0.02	OFF	OFF	0.02	OFF	0.08	
10	OFF	OFF	0.03	0.03	0.03	OFF	0.22	
11	OFF	OFF	OFF	OFF	OFF	0.03	0.06	
12	0.03	0.03	OFF	OFF	OFF	OFF	0.07	
13	0.03	OFF	OFF	OFF	0.03	0.02	0.33	
14	0.02	0.02	0.02	0.02	OFF	OFF	0.08	
15	OFF	OFF	OFF	0.03	OFF	OFF	0.24	
16	OFF	0.02	0.02	0.02	OFF	OFF	0.05	
17	OFF	0.02	0.02	0.03	OFF	OFF	0.09	
18	OFF	0.03	OFF	0.03	OFF	OFF	0.14	
19	OFF	OFF	0.02	0.02	0.02	0.02	0.13	
20	0.02	0.03	OFF	0.03	0.02	OFF	0.89	
21	OFF	OFF	0.02	OFF	0.03	0.02	0.05	
22	0.02	0.02	0.02	0.03	OFF	OFF	0.60	
23	OFF	0.05	0.02	OFF	0.02	0.03	0.33	
24	OFF	0.03	0.03	0.03	0.03	0.03	0.60	
25	OFF	OFF	0.03	0.03	0.03	0.03	1.64	
26	OFF	OFF	0.03	0.03	0.03	OFF	1.62	
27	OFF	OFF	OFF	OFF	0.05	0.03	0.29	
28	0.03	0.03	OFF	OFF	0.06	OFF	0.57	
29	0.06	OFF	OFF	OFF	0.10	0.10	2.32	
30	OFF	0.12	0.12	0.04	OFF	0.04	0.86	
31	OFF	OFF	0.03	OFF	OFF	OFF	1.17	
				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?		YES		CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?		
All 4-hour turbidity readings ≤ 1 NTU?		YES		YES		YES		
All turbidity readings < IFE ² triggers		YES						
Notes:				Printed Name: Terry Force				
				SIGNATURE: 				
				Phone# (503) 455-3334 88783				

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Dec-22							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.09	110	119.9	8.2	7.65	58.0	yes	142
2	1.15	110	126.5	9.0	7.70	58.0	yes	102
3	1.22	110	134.2	8.2	7.47	65.0	yes	104
4	1.25	110	137.5	8.7	7.60	60.0	yes	105
5	1.13	110	124.3	7.6	7.62	60.0	yes	107
6	1.10	110	121.0	7.6	7.61	60.0	yes	117
7	1.31	110	144.1	7.2	7.61	63.0	yes	110
8	1.38	110	151.8	7.6	7.67	65.0	yes	76
9	0.94	110	103.4	7.0	7.79	66.0	yes	79
10	1.00	110	110.0	8.0	7.61	60.0	yes	113
11	0.82	110	90.2	7.8	7.63	51.0	yes	107
12	1.13	110	124.3	9.9	7.55	66.0	yes	83
13	1.17	110	128.7	7.0	7.69	64.0	yes	82
14	1.29	110	141.9	7.2	7.62	62.0	yes	82
15	1.10	110	121.0	8.2	7.35	65.0	yes	93
16	1.10	110	121.0	6.7	7.78	63.0	yes	73
17	1.10	110	121.0	6.8	7.85	67.0	yes	74
18	1.10	110	121.0	6.7	7.58	68.0	yes	81
19	1.23	110	135.3	8.2	7.56	67.0	yes	84
20	1.33	110	146.3	6.7	7.51	68.0	yes	77
21	1.03	110	113.3	6.7	7.62	64.0	yes	78
22	1.40	110	154.0	5.9	7.62	67.0	yes	80
23	1.37	110	150.7	5.1	7.86	79.0	yes	173
24	1.24	110	136.4	5.4	7.79	66.0	yes	130
25	1.09	110	119.9	5.3	7.79	73.0	yes	126
26	1.19	110	130.9	5.1	7.59	68.0	yes	94
27	1.10	110	121.0	6.1	7.50	72.0	yes	106
28	1.40	110	154.0	7.7	7.47	74.0	yes	84
29	1.08	110	118.8	6.7	7.59	66.0	yes	81
30	1.70	110	187.0	6.5	7.50	65.0	yes	79
31	1.57	110	172.7	8.4	7.36	52.0	yes	74

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX