

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jan-22

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 WTP: TP - A

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.04	OFF	0.04	0.04	0.04	OFF	3.50
2	0.07	0.06	0.07	0.07	OFF	0.07	0.51
3	0.07	0.13	0.08	0.07	0.07	0.07	0.73
4	0.08	OFF	OFF	0.06	0.05	0.05	0.63
5	0.05	0.06	0.06	0.06	OFF	0.06	0.56
6	0.06	0.06	0.10	0.07	OFF	OFF	3.49
7	OFF	0.07	0.07	0.07	0.07	0.08	0.16
8	OFF	OFF	OFF	OFF	OFF	0.08	0.14
9	OFF	OFF	OFF	OFF	0.08	0.08	0.17
10	OFF	OFF	OFF	0.03	OFF	OFF	0.13
11	OFF	OFF	0.03	0.03	OFF	OFF	0.08
12	OFF	OFF	OFF	OFF	OFF	0.03	0.14
13	0.03	0.03	OFF	OFF	OFF	0.03	0.21
14	OFF	OFF	OFF	0.03	0.03	0.03	0.22
15	OFF	OFF	OFF	OFF	0.03	0.03	0.21
16	0.03	0.03	OFF	OFF	OFF	OFF	0.09
17	OFF	0.03	0.03	0.03	0.03	0.03	0.10
18	0.03	0.03	OFF	OFF	OFF	OFF	0.07
19	0.03	0.03	0.03	0.03	0.03	OFF	0.08
20	OFF	OFF	0.03	0.03	0.04	0.03	0.06
21	OFF	0.03	OFF	OFF	OFF	OFF	0.12
22	0.03	0.03	0.03	OFF	OFF	OFF	0.06
23	OFF	0.03	0.03	0.03	OFF	0.03	0.23
24	0.03	0.03	OFF	OFF	OFF	0.04	0.05
25	OFF	OFF	OFF	0.03	0.03	0.03	0.06
26	OFF	0.03	OFF	0.03	OFF	OFF	0.06
27	0.03	0.03	0.03	OFF	OFF	OFF	0.06
28	OFF	OFF	OFF	OFF	0.04	0.03	0.06
29	0.03	0.03	0.03	OFF	OFF	OFF	0.06
30	OFF	0.03	0.03	OFF	OFF	0.03	0.05
31	0.03	OFF	OFF	OFF	0.03	OFF	0.05

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:

Printed Name: Terry Force

SIGNATURE: 

Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Jan-22							WTP #: A	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	Disinfection Giardia Log Inactiv:	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	CT Met? ³ Yes / No	[GPM]
1	1.52	110	167.2	7.4	7.58	46.0	yes	73
2	1.02	110	112.2	7.4	7.58	59.0	yes	80
3	1.01	110	111.1	7.4	7.62	62.0	yes	93
4	1.42	110	156.2	8.1	7.46	65.0	yes	84
5	1.12	110	123.2	8.4	7.46	63.0	yes	82
6	1.28	110	140.8	7.1	7.46	59.0	yes	79
7	1.27	110	139.7	6.7	7.72	87.0	yes	77
8	1.16	110	127.6	6.6	7.82	52.0	yes	74
9	1.21	110	133.1	6.8	7.39	57.0	yes	76
10	1.02	110	112.2	6.8	7.49	59.0	yes	80
11	1.02	110	112.2	7.5	7.47	56.0	yes	77
12	1.01	110	111.1	9.0	7.64	65.0	yes	82
13	1.30	110	143.0	8.8	7.65	66.0	yes	80
14	1.26	110	138.6	8.8	7.75	58.0	yes	79
15	1.36	110	149.6	7.3	7.70	63.0	yes	73
16	1.34	110	111.0	7.3	7.73	55.0	yes	77
17	1.06	110	116.6	7.3	7.92	68.0	yes	79
18	1.29	110	141.9	7.3	7.94	67.0	yes	71
19	1.21	110	133.1	7.6	7.85	66.0	yes	76
20	1.20	110	132.0	7.3	7.84	67.0	yes	79
21	1.25	110	137.5	6.9	7.82	67.0	yes	71
22	1.18	110	129.8	7.4	7.81	54.0	yes	71
23	1.37	110	150.7	6.8	7.84	57.0	yes	76
24	1.39	110	152.9	6.9	7.84	57.0	yes	78
25	1.57	110	172.7	6.9	7.84	57.0	yes	77
26	1.18	110	129.8	6.9	7.84	69.0	yes	82
27	1.20	110	132.0	7.3	7.85	68.0	yes	74
28	1.34	110	141.0	8.4	7.61	69.0	yes	80
29	1.22	110	134.2	7.8	7.66	63.0	yes	73
30	1.30	110	143.0	7.0	7.77	66.0	yes	75
31	1.65	110	181.5	5.9	7.81	73.0	yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.