


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Feb-22

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416					WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	0.03	0.03	0.03	0.03	0.03	0.05	
2	OFF	0.03	OFF	OFF	OFF	OFF	0.05	
3	OFF	0.03	0.03	0.03	0.03	0.03	0.05	
4	OFF	OFF	0.03	0.03	OFF	OFF	0.05	
5	OFF	OFF	0.03	0.03	OFF	0.03	0.05	
6	0.03	0.03	0.03	OFF	OFF	0.03	0.05	
7	0.03	0.03	OFF	OFF	0.03	0.04	0.05	
8	0.03	OFF	OFF	OFF	0.03	OFF	0.06	
9	OFF	0.03	0.03	OFF	OFF	OFF	0.08	
10	OFF	0.03	OFF	OFF	OFF	0.03	0.06	
11	0.03	0.03	OFF	OFF	0.03	0.04	0.08	
12	OFF	0.04	OFF	0.04	0.04	0.04	0.08	
13	OFF	OFF	0.04	OFF	0.03	0.02	0.06	
14	OFF	OFF	0.02	0.02	0.02	OFF	0.09	
15	0.02	OFF	OFF	OFF	0.02	0.02	0.05	
16	0.02	OFF	OFF	0.02	0.02	OFF	0.06	
17	OFF	OFF	0.02	0.02	0.02	0.02	0.04	
18	OFF	0.03	0.02	0.02	0.03	0.02	0.07	
19	OFF	0.02	0.02	0.02	0.02	0.02	0.06	
20	0.02	0.02	OFF	OFF	0.03	0.02	0.04	
21	0.02	0.02	0.02	0.02	OFF	OFF	0.10	
22	OFF	0.03	0.02	OFF	0.02	0.02	0.14	
23	0.02	OFF	OFF	0.02	OFF	OFF	0.08	
24	0.03	0.02	OFF	0.02	0.02	OFF	0.06	
25	0.02	0.02	0.02	OFF	OFF	OFF	0.05	
26	0.03	0.03	OFF	OFF	0.03	0.02	0.07	
27	OFF	OFF	0.03	0.03	OFF	OFF	0.06	
28	OFF	0.02	0.02	0.02	0.03	0.02	0.06	
				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?		YES		CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?		
All 4-hour turbidity readings ≤ 1 NTU?		YES		NO		YES		
All turbidity readings < IFE ² triggers		YES						
Notes: CT was not met on 2/4. Issue was resolved, notice was issued, and coliform sampling was conducted. The system was returned to normal operations on 2/7.				Printed Name: Terry Force SIGNATURE:  Phone# (503) 455-3334				
						88783		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Feb-22							WTP - : A	
							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.49	110	163.9	6.0	7.82	61.0	yes	79
2	1.26	110	138.6	5.8	7.81	60.0	yes	73
3	1.08	110	118.8	5.8	7.81	73.0	yes	77
4	0.51	110	56.1	6.4	7.79	66.0	no	72
5	1.30	110	143.0	8.5	7.78	76.0	yes	87
6	1.27	110	139.7	8.8	7.79	76.0	yes	83
7	1.41	110	155.1	7.0	7.82	71.0	yes	83
8	1.64	110	180.4	6.2	7.88	61.0	yes	76
9	1.56	110	171.6	7.1	7.88	58.0	yes	72
10	1.62	110	178.2	6.8	7.83	57.0	yes	75
11	1.23	110	135.3	6.8	7.84	70.0	yes	73
12	1.16	110	127.6	7.3	7.76	66.0	yes	70
13	1.52	110	167.2	7.0	7.56	70.0	yes	78
14	1.27	110	139.7	7.3	7.53	71.0	yes	82
15	1.31	110	144.1	7.0	7.75	67.0	yes	82
16	1.48	110	162.8	6.0	7.73	71.0	yes	81
17	1.59	110	174.9	6.1	7.73	58.0	yes	85
18	1.67	110	183.7	6.2	7.59	58.0	yes	84
19	1.41	110	155.1	6.2	7.70	70.0	yes	78
20	1.00	110	110.0	7.0	7.72	66.0	yes	82
21	1.63	110	179.3	7.9	7.65	72.0	yes	88
22	1.13	110	124.3	7.2	7.69	73.0	yes	110
23	1.25	110	137.5	1.8	7.75	97.0	yes	104
24	1.74	110	191.4	4.9	7.75	78.0	yes	111
25	1.51	110	166.1	5.7	7.71	64.0	yes	96
26	1.65	110	181.5	5.0	7.84	62.0	yes	87
27	1.27	110	139.7	5.0	7.86	80.0	yes	89
28	1.42	110	156.2	5.9	7.88	76.0	yes	92

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX