


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Clatsop**

Conventional or Direct Filtration

Month/Year: **Mar-22**

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416	WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	OFF	OFF	OFF	0.02	0.02	0.06	
2	0.02	OFF	0.02	0.02	OFF	OFF	0.06	
3	OFF	OFF	0.02	0.02	OFF	OFF	0.07	
4	0.03	0.03	0.03	0.03	OFF	OFF	0.04	
5	0.03	0.03	0.03	OFF	0.03	0.03	0.05	
6	OFF	OFF	OFF	OFF	0.03	OFF	0.10	
7	OFF	OFF	0.03	OFF	0.03	OFF	0.05	
8	0.03	0.03	OFF	OFF	0.03	0.03	0.05	
9	0.03	OFF	OFF	0.03	0.03	0.03	0.05	
10	OFF	OFF	0.03	0.03	0.03	OFF	0.05	
11	OFF	OFF	OFF	0.03	0.03	0.03	0.11	
12	OFF	0.03	0.03	0.03	OFF	OFF	0.05	
13	0.03	0.03	OFF	OFF	OFF	0.03	0.05	
14	0.03	0.03	OFF	OFF	0.03	OFF	0.05	
15	OFF	0.03	0.03	OFF	OFF	OFF	0.05	
16	0.03	0.03	0.03	0.03	0.03	OFF	0.05	
17	OFF	0.03	0.03	OFF	0.02	OFF	1.79	
18	0.02	0.02	OFF	OFF	0.02	0.02	0.04	
19	0.02	0.02	OFF	0.02	0.02	OFF	0.04	
20	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
21	0.02	0.02	OFF	OFF	OFF	0.02	0.04	
22	0.02	0.02	0.02	OFF	OFF	OFF	0.04	
23	0.02	OFF	0.02	0.02	0.02	OFF	0.04	
24	OFF	0.02	0.02	0.02	0.02	0.02	0.04	
25	OFF	OFF	0.03	0.02	0.05	0.02	0.86	
26	0.02	0.02	OFF	0.02	0.02	OFF	0.04	
27	0.02	0.02	OFF	0.02	0.02	0.02	0.04	
28	OFF	OFF	OFF	0.02	0.03	0.02	0.05	
29	OFF	OFF	OFF	OFF	0.02	0.02	0.05	
30	0.02	OFF	OFF	OFF	OFF	0.02	0.04	
31	0.02	OFF	0.02	0.02	OFF	OFF	0.05	
					Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU? YES					CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU? YES					YES		YES	
All turbidity readings < IFE ² triggers YES								
Notes:					Printed Name: Terry Force			
					SIGNATURE: 			
					Phone# (503) 455-3331		88783	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	
System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/Year:	Mar-22	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.02	110	112.2	7.7	7.78	79.0	yes	129
2	1.30	110	143.0	5.3	7.91	77.0	yes	90
3	1.31	110	144.1	6.4	7.89	60.0	yes	79
4	1.42	110	156.3	5.4	7.86	64.0	yes	79
5	1.29	110	141.9	5.8	7.55	61.0	yes	76
6	1.38	110	151.8	5.8	7.62	59.0	yes	83
7	1.35	110	148.5	5.8	7.68	69.0	yes	82
8	1.31	110	144.1	7.1	7.73	65.0	yes	77
9	1.29	110	141.9	6.8	7.76	69.0	yes	86
10	1.30	110	143.0	6.9	7.68	70.0	yes	81
11	1.30	110	143.0	6.9	7.70	54.0	yes	78
12	1.38	110	151.8	6.6	7.75	56.0	yes	84
13	1.39	110	152.9	6.8	7.63	55.0	yes	84
14	1.37	110	150.7	7.0	7.71	56.0	yes	88
15	1.30	110	143.0	6.6	7.77	68.0	yes	92
16	1.10	110	121.0	7.7	7.74	62.0	yes	93
17	1.10	110	121.0	7.8	7.58	63.0	yes	96
18	1.18	110	129.8	8.0	7.68	60.0	yes	89
19	1.31	110	144.1	8.0	7.80	61.0	yes	90
20	1.21	110	133.1	8.0	7.80	61.0	yes	97
21	1.26	110	138.6	8.5	7.66	50.0	yes	91
22	1.29	110	141.9	9.3	7.67	48.0	yes	89
23	1.27	110	139.7	8.0	7.72	59.0	yes	90
24	1.21	110	133.1	8.9	7.72	56.0	yes	93
25	1.26	110	138.6	9.3	7.76	62.0	yes	89
26	1.25	110	137.5	9.5	7.70	61.0	yes	86
27	1.16	110	127.6	9.5	7.70	55.0	yes	91
28	1.10	110	141.0	8.5	7.72	59.0	yes	84
29	1.08	110	118.8	8.5	7.67	50.5	yes	78
30	1.05	110	115.5	8.6	7.64	49.0	yes	85
31	1.00	110	110.0	8.5	7.75	58.0	yes	81

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.