

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Apr-22

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416		WTP : TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.02	0.02	0.02	OFF	0.05
2	OFF	OFF	OFF	0.02	0.02	0.02	0.05
3	0.02	OFF	0.02	0.02	0.02	0.02	0.05
4	0.02	0.02	OFF	OFF	0.02	0.02	0.05
5	0.02	0.02	OFF	OFF	0.02	0.02	0.05
6	0.02	0.02	0.02	0.02	OFF	OFF	0.05
7	OFF	0.02	0.02	0.02	OFF	OFF	0.05
8	OFF	0.02	0.03	OFF	OFF	OFF	0.05
9	0.02	0.02	0.02	0.02	OFF	OFF	0.05
10	0.02	0.02	0.02	OFF	OFF	OFF	0.05
11	OFF	OFF	0.02	0.02	0.02	OFF	0.05
12	OFF	0.02	0.02	0.02	0.02	OFF	0.05
13	OFF	0.03	0.02	0.02	0.02	OFF	0.06
14	OFF	0.03	0.02	OFF	OFF	OFF	0.06
15	0.02	0.02	0.02	0.03	OFF	OFF	0.21
16	0.02	0.02	OFF	OFF	0.02	OFF	0.09
17	OFF	OFF	0.02	0.02	OFF	OFF	0.15
18	OFF	OFF	0.02	0.02	OFF	OFF	0.08
19	0.02	0.02	0.02	0.02	0.02	OFF	0.08
20	0.03	0.02	0.02	0.02	OFF	OFF	0.06
21	OFF	0.02	0.02	0.02	OFF	OFF	0.06
22	OFF	0.02	0.02	0.02	0.02	0.02	0.06
23	0.02	0.02	OFF	OFF	0.02	0.02	0.06
24	0.02	0.02	0.02	OFF	OFF	OFF	0.09
25	0.02	0.02	0.02	0.02	OFF	OFF	0.11
26	0.02	0.02	OFF	OFF	OFF	OFF	0.06
27	OFF	0.02	0.02	OFF	OFF	OFF	0.19
28	OFF	0.02	0.02	OFF	0.02	0.03	0.21
29	OFF	OFF	OFF	OFF	0.02	0.02	0.07
30	OFF	OFF	OFF	0.02	0.02	0.02	0.09

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Forge
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna						ID #: OR4190416	Month/ Year: Apr-22	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	1.10	110	121.0	9.0	7.71	55.0	yes	105	
2	1.07	110	117.7	9.0	7.69	56.0	yes	54	
3	1.10	110	121.0	8.9	7.65	57.0	yes	97	
4	1.09	110	119.9	8.4	7.77	59.0	yes	100	
5	1.06	110	116.6	8.5	7.74	58.0	yes	91	
6	1.17	110	128.7	8.8	7.72	56.0	yes	105	
7	1.03	110	113.3	9.0	7.68	53.0	yes	79	
8	1.05	110	115.5	9.1	7.66	53.0	yes	88	
9	1.11	110	122.1	9.2	7.67	54.0	yes	86	
10	1.18	110	129.8	9.2	7.66	54.0	yes	89	
11	1.12	110	123.2	9.0	7.67	56.0	yes	89	
12	1.12	110	123.2	9.2	7.65	53.0	yes	92	
13	1.09	110	119.9	9.4	7.66	53.0	yes	91	
14	1.07	110	117.7	9.4	7.64	52.0	yes	90	
15	1.11	110	122.1	9.9	7.62	50.0	yes	92	
16	1.09	110	119.9	10.5	7.69	50.0	yes	87	
17	1.02	110	112.2	10.3	7.66	49.0	yes	92	
18	1.00	110	110.0	10.3	7.60	52.0	yes	78	
19	1.10	110	121.0	10.7	7.68	53.0	yes	81	
20	1.13	110	124.3	9.9	7.74	45.0	yes	75	
21	1.11	110	122.1	9.6	7.74	46.0	yes	83	
22	1.05	110	115.5	10.6	7.67	45.0	yes	83	
23	1.00	110	110.0	10.6	7.68	44.0	yes	78	
24	1.14	110	125.4	10.9	7.74	43.0	yes	79	
25	1.06	110	116.6	11.4	7.74	41.0	yes	86	
26	1.12	110	123.2	12.7	7.73	41.0	yes	97	
27	1.05	110	115.5	14.4	7.62	48.0	yes	97	
28	1.04	110	141.0	12.5	7.65	37.0	yes	87	
29	1.09	110	119.9	12.9	7.69	36.0	yes	83	
30	1.16	110	127.6	13.2	7.64	36.0	yes	91	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX