

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: May-23


System Name:	Georgia Pacific CPLP Wauna			ID #: OR4190416	WTP : TP - A		
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.02	0.02	OFF	0.02	OFF	0.03	0.24
2	0.03	0.03	0.03	0.03	OFF	0.03	0.05
3	0.04	0.03	OFF	0.02	0.02	0.02	0.08
4	0.04	0.03	OFF	0.03	0.03	0.03	0.16
5	OFF	OFF	OFF	0.03	OFF	OFF	0.20
6	0.03	0.03	OFF	OFF	0.03	OFF	0.12
7	OFF	0.03	0.03	0.03	0.03	OFF	0.18
8	OFF	0.03	0.03	0.02	0.03	OFF	0.31
9	0.02	OFF	OFF	0.03	0.02	OFF	0.36
10	OFF	0.02	0.03	0.02	OFF	0.02	0.34
11	0.02	0.05	0.02	0.02	0.02	0.02	0.34
12	0.02	0.03	0.06	OFF	OFF	0.03	0.94
13	0.03	OFF	0.04	0.06	OFF	0.03	0.29
14	0.03	0.03	OFF	0.03	0.05	OFF	0.30
15	0.08	0.03	OFF	OFF	0.03	0.03	0.34
16	OFF	OFF	OFF	0.04	0.05	OFF	0.47
17	OFF	OFF	0.05	0.04	0.04	0.04	1.04
18	0.04	0.08	0.05	0.05	0.05	OFF	0.38
19	0.08	0.12	0.08	OFF	0.03	0.02	0.39
20	0.03	OFF	OFF	0.05	0.02	OFF	0.10
21	OFF	0.02	0.02	0.08	OFF	OFF	0.21
22	0.02	0.02	0.20	0.02	0.02	OFF	0.99
23	OFF	0.03	0.05	0.04	OFF	OFF	0.16
24	OFF	0.04	0.04	0.04	OFF	0.04	0.21
25	0.04	0.10	0.03	OFF	0.02	0.02	0.61
26	0.02	OFF	OFF	0.11	0.03	OFF	0.49
27	0.03	0.03	0.03	0.03	OFF	OFF	0.08
28	0.03	0.03	OFF	OFF	0.04	0.03	0.07
29	0.03	OFF	OFF	0.04	0.05	0.04	0.09
30	OFF	OFF	0.04	0.05	0.05	OFF	0.70
31	OFF	0.02	0.02	0.03	0.02	OFF	0.06

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? **YES**
 All 4-hour turbidity readings ≤ 1 NTU? **YES**
 All turbidity readings < IFE² triggers **YES**

CT's met everyday? (see back) **YES**
 All Cl₂ residual at entry point ≥ 0.2 mg/l? **YES**

Notes:

Printed Name: Terry Force
 SIGNATURE: 
 Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effic. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: May-22							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.34	110	147.4	13.2	7.60	35.0	yes	90
2	1.01	110	111.1	13.2	7.74	43.0	yes	104
3	1.14	110	125.4	13.5	7.76	42.0	yes	98
4	1.00	110	110.0	13.5	7.58	37.0	yes	84
5	1.10	110	121.0	13.6	7.60	43.0	yes	84
6	1.19	110	130.9	13.7	7.47	41.0	yes	74
7	1.01	110	111.1	13.2	7.55	44.0	yes	75
8	1.15	110	126.5	13.9	7.60	35.0	yes	95
9	1.24	110	136.4	14.0	7.51	32.0	yes	93
10	1.13	110	124.3	14.0	7.66	39.0	yes	105
11	1.00	110	110.0	15.0	7.70	38.0	yes	103
12	1.08	110	118.8	15.5	7.69	39.0	yes	111
13	1.09	110	119.9	17.0	7.43	42.0	yes	115
14	1.00	110	110.0	16.0	7.50	27.0	yes	115
15	1.03	110	113.3	15.9	7.49	27.0	yes	103
16	1.09	110	119.9	16.1	7.42	27.0	yes	107
17	1.03	110	113.3	16.6	7.58	28.0	yes	115
18	1.10	110	121.0	16.0	7.60	33.0	yes	100
19	1.29	110	141.9	16.0	7.66	34.0	yes	101
20	1.14	110	125.4	16.9	7.61	35.0	yes	104
21	1.17	110	128.7	16.4	7.54	34.0	yes	96
22	1.09	110	119.9	16.4	7.63	33.0	yes	99
23	1.33	110	146.3	15.4	7.89	39.0	yes	97
24	1.39	110	152.9	16.1	7.61	33.0	yes	108
25	1.43	110	157.3	16.4	7.64	29.0	yes	116
26	1.36	110	149.6	16.4	7.70	34.0	yes	110
27	1.35	110	148.5	17.2	7.73	33.0	yes	93
28	1.38	110	171.5	17.1	7.55	35.0	yes	97
29	1.36	110	149.6	17.2	7.60	36.0	yes	99
30	0.96	110	105.6	16.2	7.73	29.0	yes	97
31	1.13	110	124.3	16.1	7.72	29.0	yes	98

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX