

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jun-22

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	0.02	0.02	0.04	OFF	OFF	0.62	
2	0.06	0.05	0.03	0.03	OFF	0.03	0.98	
3	0.04	0.03	0.04	OFF	0.04	0.06	0.18	
4	OFF	OFF	0.04	0.04	OFF	OFF	0.16	
5	0.04	0.04	0.04	0.04	0.02	0.03	0.26	
6	OFF	OFF	OFF	0.02	0.02	OFF	0.19	
7	0.02	0.02	0.02	OFF	OFF	0.02	0.33	
8	0.02	0.03	OFF	OFF	0.03	0.02	0.12	
9	0.03	0.03	0.04	0.03	OFF	OFF	0.18	
10	OFF	0.04	0.05	OFF	OFF	OFF	0.15	
11	0.04	OFF	0.07	OFF	0.06	0.04	0.20	
12	0.05	OFF	0.04	0.05	0.06	0.05	0.94	
13	OFF	0.04	0.05	OFF	0.04	0.05	0.23	
14	0.08	OFF	0.05	0.06	OFF	0.05	0.90	
15	0.05	0.10	0.07	OFF	OFF	0.04	1.42	
16	OFF	OFF	0.06	OFF	0.02	0.04	0.78	
17	OFF	0.02	0.03	0.02	OFF	0.02	0.09	
18	0.02	0.02	0.02	OFF	0.02	0.03	0.13	
19	OFF	OFF	0.03	0.03	0.02	OFF	0.99	
20	OFF	OFF	0.02	OFF	0.02	OFF	0.10	
21	0.02	0.03	0.02	OFF	0.03	0.02	0.06	
22	0.02	OFF	OFF	0.05	0.03	0.03	0.19	
23	0.04	0.04	0.04	OFF	OFF	0.07	0.33	
24	0.05	OFF	OFF	0.02	0.02	OFF	0.63	
25	0.02	0.02	0.02	0.02	OFF	0.02	0.30	
26	0.02	OFF	OFF	OFF	0.02	OFF	0.09	
27	OFF	0.03	0.02	0.02	OFF	OFF	0.40	
28	OFF	OFF	0.02	0.02	0.03	OFF	1.42	
29	OFF	0.02	0.02	OFF	0.02	0.02	0.16	
30	0.02	0.02	0.02	0.02	0.02	0.02	0.80	

Monthly Summary (Answer Yes or No)


95% of 4-hour turbidity readings ≤ 0.3 NTU? **YES**
 All 4-hour turbidity readings ≤ 1 NTU? **YES**
 All turbidity readings < IFE² triggers **YES**

CT's met everyday? (see back)
YES

All Cl2 residual at entry point ≥ 0.2 mg/l?
YES

Notes:

Printed Name: Terry Force

SIGNATURE: 

Phone# (503) 455-3331

88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Jun-22							WTP - : A	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	Disinfection <i>Giardia</i> Log Inactiv:	1
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	CT Met? ³	Peak Hourly Demand Flow
							Yes / No	[GPM]
1	1.52	110	167.2	16.6	7.35	30.0	yes	109
2	1.39	110	152.9	16.8	7.78	32.0	yes	115
3	1.39	110	152.9	16.3	7.78	36.0	yes	103
4	1.47	110	161.7	16.5	7.74	36.0	yes	107
5	1.40	110	154.0	17.3	7.78	33.0	yes	115
6	1.32	110	145.2	17.3	7.78	34.0	yes	123
7	1.29	110	141.9	18.3	7.66	25.0	yes	112
8	1.31	110	144.1	17.6	7.67	26.0	yes	132
9	1.38	110	151.8	17.6	7.65	26.0	yes	114
10	1.31	110	144.1	17.9	7.59	26.0	yes	105
11	1.45	110	159.5	17.5	7.59	31.0	yes	114
12	1.17	110	128.7	18.0	7.60	30.0	yes	128
13	1.26	110	138.6	18.7	7.66	30.0	yes	120
14	1.40	110	154.0	18.8	7.78	31.0	yes	108
15	1.39	110	152.9	18.8	7.78	30.0	yes	121
16	1.54	110	169.4	18.4	7.78	31.0	yes	130
17	1.50	110	165.0	18.4	7.51	26.0	yes	114
18	1.37	110	150.7	18.0	7.58	31.0	yes	90
19	1.33	110	146.3	18.0	7.75	31.0	yes	93
20	1.25	110	137.5	16.5	7.78	35.0	yes	98
21	1.23	110	135.3	19.0	7.69	32.0	yes	106
22	1.33	110	146.3	19.7	7.61	31.0	yes	129
23	1.22	110	134.2	18.5	7.70	25.0	yes	104
24	1.36	110	149.6	18.5	7.75	25.0	yes	112
25	1.29	110	141.9	18.7	7.62	24.0	yes	103
26	1.31	110	144.1	19.4	7.46	24.0	yes	120
27	1.33	110	146.3	19.6	7.22	24.0	yes	104
28	1.27	110	139.7	20.1	7.35	23.0	yes	110
29	1.26	110	138.6	21.7	7.67	27.0	yes	119
30	1.31	110	144.1	20.7	7.73	26.0	yes	111

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX