


OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Aug-23

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	0.02	0.02	0.02	0.02	OFF	0.04
2	0.02	0.03	OFF	0.02	0.02	0.02	0.09
3	OFF	0.02	0.02	0.03	OFF	0.02	0.04
4	0.03	0.02	0.02	0.02	0.02	0.02	0.04
5	OFF	0.02	0.02	OFF	OFF	OFF	0.14
6	0.02	0.04	OFF	OFF	0.02	0.02	0.32
7	OFF	0.02	0.02	0.02	OFF	0.02	0.04
8	0.02	0.02	0.02	0.02	OFF	0.03	0.04
9	OFF	OFF	0.02	0.02	0.02	0.02	0.04
10	0.02	0.02	0.02	0.02	0.02	0.02	0.04
11	0.02	OFF	OFF	0.02	0.02	0.02	0.04
12	0.02	0.02	OFF	0.02	0.02	OFF	0.04
13	OFF	0.02	OFF	0.02	OFF	0.02	0.05
14	OFF	0.02	0.02	0.02	0.03	0.02	0.07
15	OFF	0.02	0.02	0.03	0.02	0.02	0.05
16	0.02	0.02	0.02	OFF	0.02	0.03	0.08
17	0.03	0.03	OFF	0.03	OFF	0.02	0.25
18	0.03	0.03	0.02	OFF	0.02	0.02	0.05
19	0.02	0.03	OFF	0.02	OFF	0.03	0.05
20	0.03	0.03	OFF	OFF	0.02	0.03	0.05
21	0.03	OFF	0.03	0.02	0.02	0.03	0.05
22	OFF	0.03	0.03	0.04	0.03	OFF	0.05
23	OFF	OFF	0.03	OFF	0.03	0.03	0.06
24	0.03	OFF	OFF	0.03	0.03	0.03	0.09
25	0.03	0.03	0.03	0.03	0.03	OFF	0.06
26	0.03	0.03	OFF	0.03	0.04	0.03	0.06
27	OFF	0.04	0.04	OFF	0.04	0.04	0.07
28	0.04	0.04	0.04	0.04	0.04	0.04	0.06
29	OFF	0.04	0.04	0.02	0.02	OFF	0.09
30	OFF	0.02	0.02	0.02	0.02	OFF	0.03
31	OFF	OFF	0.02	0.02	0.02	OFF	0.06

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE <sup>2</sup> triggers	YES		
Notes:		Printed Name: Terry Force	
		SIGNATURE: 	
		Phone# (503) 455-3331	88783

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Aug-22							WTP -: A	
							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.15	110	126.5	22.0	7.82	24.0	yes	130
2	1.08	110	118.8	23.0	7.74	19.0	yes	135
3	1.45	110	159.5	22.2	7.70	19.0	yes	141
4	1.41	110	155.1	23.1	7.72	19.0	yes	132
5	1.26	110	138.6	22.5	7.66	19.0	yes	126
6	1.42	110	156.2	22.5	7.68	23.0	yes	127
7	1.21	110	133.1	22.2	7.70	23.0	yes	131
8	1.35	110	148.5	22.9	7.67	18.0	yes	133
9	1.21	110	133.1	22.1	7.69	22.0	yes	132
10	1.24	110	136.4	22.7	7.72	20.0	yes	126
11	1.23	110	135.3	22.8	7.75	19.0	yes	132
12	1.34	110	147.4	23.0	7.75	19.0	yes	128
13	1.36	110	149.6	23.2	7.76	19.0	yes	133
14	1.32	110	145.2	23.0	7.76	22.0	yes	145
15	1.35	110	148.5	23.0	7.73	22.0	yes	146
16	1.16	110	127.6	24.2	7.60	22.0	yes	127
17	1.02	110	112.2	23.7	7.63	21.0	yes	136
18	1.24	110	136.4	23.2	7.59	22.0	yes	128
19	1.06	110	116.6	24.1	7.65	21.0	yes	132
20	1.07	110	117.7	23.3	7.80	20.0	yes	124
21	1.25	110	137.5	22.5	7.80	19.0	yes	127
22	1.03	110	113.3	21.1	7.80	26.0	yes	141
23	1.11	110	122.1	21.4	7.81	25.0	yes	137
24	1.25	110	137.5	23.9	7.75	23.0	yes	134
25	1.17	110	128.7	23.4	7.70	24.0	yes	140
26	1.31	110	144.1	22.2	7.76	20.0	yes	141
27	1.21	110	133.1	21.7	7.76	21.0	yes	134
28	1.53	110	141.0	21.7	7.78	21.0	yes	129
29	1.44	110	158.4	21.5	7.75	21.0	yes	128
30	1.15	110	126.5	20.7	7.72	26.0	yes	143
31	1.00	110	110.0	21.4	7.67	24.0	yes	106

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX