

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Clatsop

Conventional or Direct Filtration

Month/Year: Sep-22

System Name:	Georgia Pacific CPLP Wauna			ID #: OR4190416	WTP : TP - A		
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	0.02	0.02	0.02	0.03
2	0.02	OFF	0.02	0.02	0.02	0.02	0.04
3	OFF	OFF	0.02	OFF	0.02	OFF	0.03
4	OFF	0.02	0.02	0.02	OFF	OFF	0.04
5	OFF	OFF	0.02	0.02	OFF	OFF	0.04
6	OFF	OFF	0.02	0.02	0.02	OFF	0.04
7	0.03	0.03	0.03	.03	0.03	OFF	0.05
8	0.03	0.03	OFF	0.03	0.03	OFF	0.05
9	0.03	OFF	0.02	0.02	0.02	0.02	0.04
10	0.02	0.02	OFF	0.02	0.02	0.02	0.04
11	0.02	OFF	0.02	OFF	0.02	0.02	0.04
12	OFF	OFF	0.02	0.02	0.02	OFF	0.04
13	0.02	0.02	0.02	OFF	OFF	OFF	0.11
14	OFF	0.03	OFF	OFF	OFF	0.02	0.20
15	0.02	OFF	OFF	0.02	0.02	0.02	0.04
16	0.02	0.02	0.02	0.02	OFF	OFF	0.04
17	OFF	OFF	0.02	0.02	0.02	0.02	0.06
18	OFF	OFF	OFF	OFF	0.02	0.02	0.04
19	0.02	0.02	OFF	OFF	OFF	0.02	0.05
20	0.02	0.02	0.02	0.02	0.02	OFF	0.04
21	OFF	OFF	0.02	0.02	0.02	0.02	0.04
22	0.02	0.02	0.02	0.02	0.02	OFF	0.03
23	0.02	OFF	OFF	0.02	0.02	0.02	0.09
24	OFF	OFF	OFF	OFF	0.02	0.02	0.03
25	0.01	OFF	OFF	OFF	0.01	0.02	0.03
26	0.01	0.01	OFF	OFF	OFF	0.02	0.05
27	0.01	0.01	0.02	OFF	OFF	OFF	1.37
28	OFF	0.02	0.01	0.02	OFF	OFF	0.23
29	OFF	0.01	0.02	OFF	OFF	OFF	0.16
30	OFF	0.02	0.02	OFF	OFF	OFF	0.04

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Terry Force
	SIGNATURE: 
	Phone# (503) 455-3331 88783

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/ Year: Sep-22							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	110	110.0	21.9	7.67	24.0	yes	110
2	1.24	110	136.4	21.3	7.62	24.0	yes	108
3	1.14	110	125.4	21.2	7.62	20.0	yes	97
4	1.16	110	127.6	20.8	7.66	21.0	yes	92
5	1.10	110	121.0	21.2	7.39	22.0	yes	92
6	1.11	110	122.1	21.1	7.30	22.0	yes	100
7	1.34	110	147.4	21.0	7.63	22.0	yes	103
8	1.39	110	152.9	21.1	7.81	23.0	yes	104
9	1.59	110	174.9	22.4	7.66	27.0	yes	108
10	1.42	110	156.2	21.4	7.69	31.0	yes	103
11	1.15	110	126.5	19.7	7.74	23.0	yes	113
12	1.20	110	132.0	19.5	7.72	23.0	yes	115
13	1.31	110	144.1	21.0	7.71	23.0	yes	120
14	1.18	110	129.8	21.6	7.74	22.0	yes	108
15	1.19	110	130.9	21.6	7.69	22.0	yes	115
16	1.36	110	149.6	20.9	7.72	22.0	yes	107
17	1.30	110	143.0	20.6	7.76	24.0	yes	93
18	1.12	110	123.2	20.5	7.74	24.0	yes	102
19	0.91	110	100.1	20.4	7.72	23.0	yes	95
20	1.12	110	123.2	19.7	7.76	24.0	yes	95
21	1.19	110	130.9	20.5	7.70	24.0	yes	94
22	1.13	110	124.3	19.5	7.75	24.0	yes	95
23	1.27	110	139.7	19.2	7.72	24.0	yes	94
24	1.15	110	126.5	18.8	7.73	25.0	yes	85
25	1.25	110	137.5	18.9	7.70	24.0	yes	86
26	1.10	110	121.0	18.4	7.70	25.0	yes	91
27	1.19	110	130.9	18.3	7.69	25.0	yes	90
28	1.52	110	141.0	18.5	7.61	26.0	yes	74
29	1.11	110	122.1	18.5	7.60	26.0	yes	66
30	1.11	110	122.1	17.7	7.64	26.0	yes	67

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX