

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Dec-23

System Name:	Georgia Pacific CPLP Wauna						ID #: OR4190416	WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.02	0.02	OFF	OFF	0.04	
2	OFF	0.03	OFF	OFF	OFF	Off	0.04	
3	0.02	0.03	OFF	OFF	OFF	0.03	0.04	
4	0.03	0.03	0.03	0.03	0.03	0.04	1.74	
5	0.03	OFF	0.03	0.03	0.03	0.03	0.05	
6	0.04	0.02	0.03	0.02	OFF	0.10	5.84	
7	0.10	OFF	0.19	OFF	0.05	OFF	0.41	
8	OFF	0.02	0.02	0.02	OFF	0.03	0.06	
9	0.02	0.03	OFF	0.03	0.03	0.03	0.16	
10	OFF	0.04	0.05	0.06	0.06	OFF	0.16	
11	0.02	0.02	0.02	0.03	0.03	0.03	0.27	
12	0.02	OFF	OFF	0.03	0.03	0.02	0.05	
13	OFF	OFF	OFF	OFF	OFF	0.03	0.06	
14	0.03	0.03	0.03	0.03	OFF	0.04	0.08	
15	0.03	0.03	OFF	0.03	0.03	OFF	0.08	
16	0.03	0.03	0.06	0.07	0.03	OFF	0.11	
17	OFF	0.03	OFF	OFF	OFF	0.05	0.07	
18	0.05	OFF	0.06	0.08	OFF	OFF	0.14	
19	0.08	0.09	OFF	OFF	0.09	0.09	0.15	
20	0.08	0.10	OFF	0.10	0.10	0.10	0.15	
21	0.12	0.13	0.09	0.07	0.06	0.04	0.16	
22	0.03	0.04	0.03	0.03	OFF	0.04	0.06	
23	0.03	0.03	0.03	OFF	0.04	0.03	0.05	
24	0.02	OFF	OFF	0.03	OFF	OFF	0.09	
25	0.04	0.03	0.03	OFF	OFF	0.04	0.06	
26	0.03	OFF	OFF	0.04	0.04	0.04	0.06	
27	OFF	0.04	0.04	0.03	0.04	0.04	0.07	
28	OFF	OFF	OFF	0.03	0.04	OFF	0.07	
29	0.05	0.04	0.05	0.05	0.05	OFF	0.08	
30	0.05	OFF	OFF	0.06	0.05	0.05	0.08	
31	0.05	OFF	0.05	0.05	0.05	OFF	0.11	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> YES	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> YES	All Cl2 residual at entry point ≥ 0.2 mg/l?
		<input type="checkbox"/> NO
Notes: Inadequate C/T time was reported to OHA on Decdember 6 2023.		
Printed Name: Darrel Lockard		
SIGNATURE: Darrel Lockard		1/5/2023
Phone# 541-505-9968	CERT# 2853	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna						ID #: OR4190416	Month/ Year: Dec-23	Disinfection <i>Giardia</i> Log Inactiv: 1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.36	110	149.6	9.0	7.77	48.0	yes	93
2	1.31	110	144.1	9.0	7.61	47.0	yes	89
3	1.42	110	156.2	9.4	7.62	48.0	yes	93
4	1.40	110	154.0	9.4	7.69	46.0	yes	86
5	1.50	110	165.0	11.0	7.64	54.0	yes	84
6	0.02	110	2.2	11.0	7.69	46.0	no	86
7	2.00	110	220.0	11.0	7.68	47.0	yes	86
8	1.35	110	148.5	11.0	7.69	41.0	yes	91
9	0.89	110	97.9	9.9	7.44	40.0	yes	86
10	1.10	110	121.0	10.9	7.35	42.0	yes	88
11	1.26	110	138.6	9.9	7.40	33.0	yes	98
12	1.01	110	111.1	10.1	7.76	42.0	yes	98
13	1.18	110	129.8	9.9	7.51	44.0	yes	96
14	1.18	110	129.8	9.6	7.47	56.0	yes	96
15	1.07	110	117.7	9.5	7.52	54.0	yes	109
16	1.07	110	117.7	9.5	7.61	44.0	yes	105
17	1.33	110	146.3	8.9	7.69	47.0	yes	95
18	1.46	110	160.7	9.1	7.35	47.0	yes	93
19	1.59	110	174.9	9.3	7.37	48.0	yes	93
20	1.33	110	146.3	9.1	7.54	53.0	yes	94
21	1.31	110	144.1	9.1	7.48	53.0	yes	100
22	1.31	110	144.1	9.9	7.49	57.0	yes	94
23	1.24	110	136.4	8.4	7.50	59.0	yes	88
24	1.25	110	137.5	8.3	7.72	50.0	yes	91
25	1.42	110	156.2	8.3	7.75	50.0	yes	89
26	1.35	110	148.5	8.9	7.65	49.0	yes	91
27	1.35	110	148.5	8.8	7.71	48.0	yes	97
28	1.36	110	141.0	9.0	7.65	49.0	yes	95
29	1.12	110	123.2	8.8	7.61	49.0	yes	88
30	1.15	110	126.5	8.2	7.66	61.0	yes	87
31	1.40	110	154.0	8.0	7.65	60.0	yes	98

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX