

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Feb-24

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.05	0.08	0.07	OFF	0.07	0.03	0.13	
2	0.06	0.07	OFF	OFF	0.06	OFF	0.14	
3	OFF	0.09	0.09	OFF	0.10	0.13	0.17	
4	0.12	OFF	OFF	OFF	0.11	0.08	0.16	
5	0.07	0.08	0.06	OFF	0.06	OFF	0.17	
6	OFF	OFF	0.04	0.04	0.04	OFF	0.10	
7	OFF	0.05	0.05	0.05	0.05	OFF	0.06	
8	OFF	OFF	0.05	0.02	0.02	OFF	0.06	
9	OFF	0.02	OFF	0.02	0.03	0.02	0.04	
10	OFF	OFF	OFF	0.03	OFF	0.02	0.08	
11	0.03	0.03	0.03	0.02	OFF	0.03	0.05	
12	0.03	0.03	OFF	0.03	0.03	0.03	0.08	
13	OFF	0.04	OFF	OFF	0.04	0.04	0.08	
14	OFF	0.04	0.05	0.03	0.06	0.05	0.08	
15	0.05	OFF	0.06	0.08	0.06	OFF	0.13	
16	0.10	0.09	0.09	0.05	OFF	0.11	0.15	
17	0.08	0.06	OFF	0.05	0.05	0.05	0.17	
18	OFF	OFF	0.05	0.05	0.05	OFF	0.12	
19	0.05	0.05	OFF	OFF	0.03	OFF	0.10	
20	OFF	0.02	0.02	OFF	OFF	OFF	0.12	
21	0.03	0.02	OFF	OFF	OFF	0.03	0.06	
22	OFF	0.03	0.02	OFF	0.03	0.03	0.06	
23	OFF	0.03	0.03	0.02	0.03	0.03	0.22	
24	0.03	0.03	0.03	0.03	0.03	0.03	0.07	
25	0.03	0.03	0.03	0.03	0.03	0.03	0.08	
26	0.03	0.06	OFF	0.04	0.03	0.03	0.12	
27	0.03	0.03	0.03	0.03	OFF	OFF	0.08	
28	0.03	0.03	OFF	OFF	0.03	0.03	0.08	
29	OFF	OFF	OFF	0.03	0.03	0.03	0.06	

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes	CT's met everyday? (see back) <input checked="" type="radio"/> Yes
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes	
Notes:	Printed Name: Darrel Lockard 3/4/2024
	SIGNATURE: <i>Darrel Lockard</i>
	Phone# 541-505-9968 CERT# 2853

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Feb-24							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.07	110	117.7	8.5	7.41	56.0	yes	102
2	1.10	110	121.0	8.0	7.52	47.0	yes	104
3	1.34	110	147.4	7.9	7.60	49.0	yes	103
4	1.54	110	169.4	7.6	7.64	51.0	yes	99
5	1.36	110	149.6	7.4	7.61	51.0	yes	102
6	1.07	110	117.7	7.4	7.62	51.0	yes	102
7	1.30	110	143.0	7.8	7.69	62.0	yes	104
8	1.67	110	195.8	8.0	7.65	53.0	yes	98
9	1.41	110	155.1	7.8	7.64	53.0	yes	98
10	1.25	110	137.5	7.0	7.71	54.0	yes	95
11	1.63	110	179.3	7.5	7.85	55.0	yes	99
12	1.46	110	127.6	7.4	7.80	53.0	yes	99
13	1.52	110	167.2	7.5	7.69	54.0	yes	99
14	1.45	110	159.5	7.2	7.84	69.0	yes	102
15	1.35	110	148.5	6.8	7.75	68.0	yes	104
16	1.52	110	167.2	7.0	7.78	55.0	yes	99
17	1.57	110	172.7	6.8	7.78	69.0	yes	89
18	1.65	110	181.5	6.8	7.75	68.0	yes	98
19	1.36	110	149.6	7.8	7.74	52.0	yes	99
20	1.67	110	183.7	7.3	7.50	51.0	yes	99
21	1.43	110	157.3	7.5	7.47	54.0	yes	108
22	1.41	110	155.1	7.5	7.60	62.0	yes	110
23	1.59	110	174.9	7.7	7.57	61.0	yes	99
24	1.19	110	130.9	8.1	7.51	61.0	yes	97
25	1.20	110	132.0	8.1	7.47	57.0	yes	104
26	1.14	110	125.4	7.9	7.71	51.0	yes	120
27	1.20	110	132.0	7.5	7.71	52.0	yes	98
28	1.25	110	137.5	8.1	7.57	51.0	yes	98
29	1.23	110	135.3	7.7	7.55	52.0	yes	121

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX