

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Mar-24

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.03	OFF	0.03	OFF	OFF	0.03	0.05		
2	0.03	0.03	OFF	0.04	0.04	0.04	0.05		
3	OFF	OFF	0.04	0.04	0.04	OFF	0.06		
4	0.04	0.04	OFF	OFF	0.03	OFF	0.11		
5	OFF	0.03	0.02	0.02	0.02	OFF	0.14		
6	OFF	OFF	0.02	0.02	OFF	0.02	0.30		
7	0.03	OFF	OFF	OFF	0.03	0.04	0.08		
8	OFF	0.03	OFF	OFF	OFF	0.03	0.14		
9	0.03	OFF	0.03	0.03	OFF	OFF	0.05		
10	0.03	0.03	0.03	0.03	0.03	0.03	0.10		
11	0.03	0.03	0.03	0.02	0.02	0.02	0.13		
12	0.02	0.02	OFF	0.02	OFF	OFF	0.21		
13	0.02	0.02	0.02	0.02	0.02	0.02	0.16		
14	0.02	0.02	0.02	OFF	0.02	0.02	0.22		
15	0.02	OFF	0.02	OFF	0.02	0.02	0.82		
16	OFF	OFF	OFF	0.02	0.02	OFF	0.29		
17	OFF	OFF	0.02	OFF	0.02	0.02	0.32		
18	0.01	OFF	OFF	0.02	0.01	OFF	0.16		
19	OFF	0.02	0.02	OFF	OFF	0.02	0.13		
20	0.02	0.02	OFF	0.02	OFF	OFF	0.14		
21	OFF	0.02	OFF	OFF	OFF	0.01	0.19		
22	0.01	OFF	0.02	0.02	0.01	0.01	0.08		
23	0.02	0.02	0.02	0.01	OFF	OFF	0.06		
24	0.02	0.02	0.02	OFF	0.02	0.02	0.07		
25	0.02	0.02	OFF	OFF	OFF	0.02	0.12		
26	0.02	OFF	OFF	OFF	0.02	0.02	0.08		
27	0.02	OFF	OFF	OFF	0.02	0.02	0.07		
28	0.02	OFF	0.02	0.02	0.02	0.02	0.12		
29	OFF	0.02	0.02	0.02	0.02	0.02	0.05		
30	OFF	0.02	0.02	0.02	OFF	OFF	0.06		
31	0.04	0.02	0.02	0.02	OFF	OFF	0.05		

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	YES	YES	YES
All turbidity readings < IFE ² triggers	YES		

Notes:	Printed Name: Darrel Lockard 4/3/2024	
	SIGNATURE: Darrel Lockard <small>Digital Signature by Darrel Lockard For Additional Details on this Signature, see www.lockandkey.com/ESD Date: 2024.04.03 09:59:07 AM</small>	
	Phone# 541-505-9968	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Mar-24		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.29	110	141.9	7.0	7.55	62.0	yes	127					
2	1.22	110	134.2	7.0	7.75	66.0	yes	90					
3	1.19	110	130.9	7.3	7.54	55.0	yes	96					
4	1.32	110	145.2	8.0	7.53	54.0	yes	97					
5	1.36	110	149.6	7.5	7.69	63.0	yes	99					
6	1.09	110	119.9	7.5	7.67	63.0	yes	104					
7	1.48	110	162.8	7.5	7.54	49.0	yes	101					
8	1.35	110	148.5	7.9	7.49	51.0	yes	97					
9	1.03	110	113.3	7.7	7.80	64.0	yes	97					
10	1.26	110	138.6	7.8	7.73	63.0	yes	95					
11	1.58	110	174.9	7.7	7.71	67.0	yes	101					
12	1.23	110	135.5	8.0	7.54	64.0	yes	99					
13	1.37	110	150.7	8.0	7.83	63.0	yes	96					
14	1.32	110	145.2	8.8	7.90	62.0	yes	98					
15	1.20	110	132.0	9.7	7.47	47.0	yes	89					
16	1.25	110	137.5	10.3	7.28	43.0	yes	94					
17	1.15	110	126.5	9.0	7.51	52.0	yes	93					
18	1.29	110	141.9	9.4	7.49	51.0	yes	95					
19	1.30	110	143.0	10.0	7.56	48.0	yes	94					
20	1.34	110	147.5	10.7	7.45	52.0	yes	99					
21	1.39	110	152.9	10.0	7.68	53.0	yes	93					
22	1.38	110	151.8	10.0	7.61	51.0	yes	92					
23	1.36	110	149.6	10.7	7.60	41.0	yes	83					
24	1.35	110	148.5	10.0	7.70	44.0	yes	86					
25	1.18	110	129.8	10.1	7.72	53.0	yes	86					
26	1.23	110	135.3	9.8	7.65	53.0	yes	86					
27	1.27	110	135.3	9.8	7.57	43.0	yes	90					
28	1.17	110	128.7	10.0	7.50	57.0	yes	129					
29	1.13	110	124.3	8.5	7.72	49.0	yes	86					
30	1.10	110	121.0	10.1	7.75	45.0	yes	91					
31	1.06	110	116.6	11.2	7.42	43.0	yes	82					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX