

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Apr-24

System Name:	Georgia Pacific CPLP Wauna						ID #: OR4190416	WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.02	0.02	OFF	OFF	0.06	
2	OFF	0.02	0.02	OFF	0.02	0.02	0.06	
3	0.02	OFF	OFF	0.02	0.02	0.02	0.05	
4	OFF	0.02	0.02	0.02	0.02	OFF	0.05	
5	OFF	0.02	OFF	0.02	0.02	OFF	0.05	
6	0.02	0.02	OFF	0.02	0.02	OFF	0.05	
7	0.02	0.02	0.02	0.02	0.02	OFF	0.04	
8	0.02	0.04	0.02	OFF	OFF	0.02	0.23	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.10	
10	OFF	0.02	OFF	0.02	0.02	OFF	0.11	
11	0.02	0.02	OFF	0.02	0.02	OFF	0.10	
12	0.02	0.03	OFF	0.02	0.02	0.02	0.11	
13	0.02	OFF	0.02	0.02	OFF	0.02	0.05	
14	OFF	OFF	0.02	0.02	0.02	0.02	0.23	
15	0.02	0.02	0.02	0.02	0.02	OFF	0.11	
16	0.02	0.02	0.02	0.02	OFF	0.02	0.04	
17	0.02	OFF	OFF	0.02	0.02	0.02	0.05	
18	0.02	0.02	0.02	OFF	OFF	0.02	0.19	
19	0.02	0.02	OFF	OFF	0.02	0.02	0.09	
20	0.02	OFF	0.02	0.02	OFF	OFF	0.05	
21	0.02	0.02	0.02	OFF	0.02	0.02	0.05	
22	0.02	OFF	0.02	0.02	0.02	0.02	0.05	
23	OFF	OFF	0.02	0.02	0.02	0.02	0.06	
24	Off	OFF	OFF	OFF	0.02	OFF	0.06	
25	OFF	OFF	OFF	0.03	OFF	OFF	0.06	
26	OFF	0.02	0.02	OFF	OFF	OFF	0.06	
27	0.03	0.02	OFF	0.02	0.02	OFF	0.07	
28	OFF	OFF	0.02	OFF	0.02	0.02	0.06	
29	0.02	OFF	0.02	0.02	OFF	OFF	0.06	
30	0.02	0.02	OFF	0.02	0.02	0.02	0.05	

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> YES	<input checked="" type="checkbox"/> YES	<input checked="" type="checkbox"/> YES
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> YES		
Notes:		Printed Name: Darrel Lockard	
		SIGNATURE: Darrel Lockard	
		Phone# 541-505-9968	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Apr-24							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.18	110	129.8	11.4	7.53	41.0	yes	103
2	1.00	110	110.0	11.4	7.74	50.0	yes	101
3	1.03	110	113.3	10.8	7.89	54.0	yes	100
4	1.16	110	127.6	11.4	7.67	40.0	yes	123
5	1.60	110	176.0	10.8	7.75	43.0	yes	113
6	1.34	110	147.0	11.6	7.84	53.0	yes	108
7	1.34	110	147.4	11.6	7.74	49.0	yes	114
8	1.45	110	159.5	10.9	7.66	40.0	yes	105
9	1.23	110	135.3	11.4	7.64	42.0	yes	107
10	1.07	110	117.7	10.8	7.68	50.0	yes	107
11	1.13	110	124.3	10.0	7.55	50.0	yes	108
12	1.43	110	157.3	11.8	7.63	38.0	yes	108
13	1.38	110	151.8	11.6	7.62	39.0	yes	107
14	1.29	110	141.9	11.8	7.71	47.0	yes	106
15	1.40	110	154.0	12.8	7.73	45.0	yes	108
16	1.41	110	155.1	12.1	7.48	39.0	yes	94
17	1.43	110	156.2	12.6	7.58	40.0	yes	127
18	1.35	110	148.5	11.7	7.79	41.0	yes	94
19	1.37	110	150.7	10.2	7.76	44.0	yes	92
20	1.46	110	160.6	12.5	7.71	47.0	yes	90
21	1.41	110	155.1	13.2	7.41	51.0	yes	97
22	1.44	110	158.4	12.0	7.82	48.0	yes	96
23	1.32	110	188.1	13.3	7.82	43.0	yes	93
24	1.24	110	136.4	12.9	7.56	36.0	yes	100
25	1.09	110	119.9	12.9	7.50	35.0	yes	98
26	1.29	110	141.9	12.5	7.40	45.0	yes	97
27	1.25	110	137.5	12.5	7.69	44.0	yes	104
28	1.06	110	116.6	12.8	7.60	40.0	yes	95
29	1.34	110	147.4	13.0	7.44	43.0	yes	102
30	1.34	110	147.4	12.3	7.67	45.0	yes	98

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX