

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jun-24

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416	WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	OFF	OFF	OFF	0.02	0.02	0.02	
2	0.02	OFF	0.02	0.02	0.02	0.02	0.02	
3	OFF	OFF	OFF	0.02	0.02	0.02	0.02	
4	0.02	OFF	OFF	OFF	0.02	0.02	0.02	
5	0.02	OFF	0.04	0.02	OFF	OFF	0.04	
6	0.01	0.02	OFF	OFF	0.02	0.02	0.02	
7	0.02	OFF	OFF	0.01	0.01	0.02	0.02	
8	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
9	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
10	0.02	OFF	OFF	0.01	0.02	0.02	0.02	
11	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
12	0.02	OFF	OFF	0.02	0.02	OFF	0.02	
13	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
14	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
15	OFF	0.01	0.02	0.02	OFF	0.02	0.02	
16	0.01	OFF	OFF	OFF	0.02	0.02	0.02	
17	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
18	0.02	0.02	OFF	OFF	OFF	0.03	0.03	
19	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
20	0.02	0.02	OFF	0.02	0.02	0.02	0.02	
21	OFF	0.02	OFF	0.02	0.02	0.02	0.02	
22	0.02	0.02	OFF	OFF	OFF	0.02	0.02	
23	0.02	OFF	0.02	0.02	OFF	OFF	0.02	
24	0.02	OFF	0.02	0.02	0.02	0.02	0.02	
25	OFF	0.02	0.02	0.02	OFF	0.02	0.02	
26	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
27	OFF	OFF	OFF	0.02	0.02	OFF	0.02	
28	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
29	0.02	OFF	0.02	0.02	0.02	0.02	0.02	
30	0.01	0.02	0.02	0.02	0.02	OFF	0.02	

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> Yes
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes		

Notes:	Printed Name: Darrel Lockard	7/1/2024
	SIGNATURE: Darrel Lockard	
	Phone# 541-505-9968	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Jun-24							Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.28	110	140.8	16.0	7.75	30.0	yes	103
2	1.30	110	143.0	16.0	7.78	30.0	yes	105
3	1.43	110	157.3	15.7	7.39	30.0	yes	96
4	1.27	110	139.7	15.5	7.71	30.0	yes	100
5	1.27	110	139.7	15.4	7.71	37.0	yes	109
6	1.34	110	147.4	15.5	7.72	36.0	yes	111
7	1.30	110	143.0	15.9	7.65	35.0	yes	113
8	1.19	110	130.9	16.7	7.56	32.0	yes	112
9	1.26	110	138.6	17.5	7.60	26.0	yes	109
10	1.28	110	140.8	16.6	7.61	27.0	yes	119
11	1.29	110	141.9	17.2	7.61	27.0	yes	110
12	1.39	110	152.9	17.4	7.43	26.0	yes	109
13	1.30	110	143.0	16.9	7.66	32.0	yes	118
14	1.35	110	148.5	16.4	7.66	34.0	yes	111
15	1.06	110	116.6	17.1	7.49	34.0	yes	106
16	1.38	110	151.8	17.3	7.50	35.0	yes	102
17	1.37	110	150.7	16.6	7.74	29.0	yes	110
18	1.13	110	124.3	16.6	7.78	28.0	yes	116
19	1.42	110	156.2	17.8	7.51	28.0	yes	120
20	1.48	110	162.8	18.5	7.47	26.0	yes	125
21	1.43	110	157.3	17.8	7.68	31.0	yes	117
22	1.33	110	146.3	17.7	7.75	32.0	yes	106
23	1.23	110	135.3	18.0	7.69	30.0	yes	114
24	1.32	110	145.2	19.0	7.47	31.0	yes	124
25	1.34	110	147.4	18.7	7.70	25.0	yes	122
26	1.33	110	146.3	18.9	7.71	30.0	yes	136
27	1.40	110	154.0	18.8	7.56	29.0	yes	119
28	1.33	110	146.3	19.0	7.63	29.0	yes	105
29	1.02	110	112.2	18.4	7.66	29.0	yes	117
30	1.29	110	141.9	18.8	7.57	29.0	yes	132

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX