

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jul-24

System Name:		Georgia Pacific CPLP Wauna				ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.02	0.02	0.01	0.02	0.02	OFF	0.02		
2	OFF	0.02	0.02	OFF	OFF	0.02	0.02		
3	0.02	OFF	0.02	0.02	0.02	0.02	0.02		
4	OFF	0.02	0.02	OFF	0.02	0.02	0.02		
5	OFF	0.02	0.01	0.02	0.02	0.02	0.02		
6	0.02	0.02	0.02	0.02	OFF	OFF	0.02		
7	0.02	OFF	OFF	0.02	0.02	0.02	0.02		
8	0.02	0.02	0.03	0.02	0.02	0.02	0.03		
9	0.02	0.02	0.01	OFF	0.02	0.02	0.02		
10	0.02	OFF	OFF	0.02	0.02	0.02	0.02		
11	OFF	0.02	0.02	0.02	0.02	0.02	0.02		
12	0.02	0.02	0.02	OFF	OFF	0.02	0.02		
13	OFF	0.02	0.01	0.01	0.02	OFF	0.02		
14	OFF	OFF	0.02	0.02	0.02	OFF	0.02		
15	OFF	OFF	0.01	0.01	0.02	0.02	0.02		
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
17	OFF	OFF	0.02	0.02	0.02	0.02	0.02		
18	OFF	0.02	0.02	OFF	OFF	0.01	0.02		
19	OFF	OFF	0.01	0.01	0.01	0.02	0.02		
20	0.02	0.02	OFF	0.02	0.02	OFF	0.02		
21	0.02	0.02	OFF	0.02	0.02	0.01	0.02		
22	0.01	0.02	0.02	0.01	0.01	OFF	0.02		
23	0.01	0.01	0.02	OFF	0.02	OFF	0.02		
24	0.01	0.01	0.01	0.01	0.01	OFF	0.01		
25	0.02	0.02	0.01	0.01	OFF	0.02	0.02		
26	0.02	0.01	OFF	0.01	0.02	0.01	0.02		
27	OFF	0.02	0.02	0.02	0.02	0.02	0.02		
28	0.02	0.02	OFF	OFF	0.02	0.01	0.02		
29	0.02	OFF	0.02	0.02	0.02	OFF	0.02		
30	0.02	0.02	0.02	0.02	0.02	OFF	0.02		
31	0.02	0.02	0.02	OFF	0.02	0.02	0.02		

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> YES	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> YES	<input checked="" type="checkbox"/> YES
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> YES	All Cl2 residual at entry point ≥ 0.2 mg/l?
		<input checked="" type="checkbox"/> YES
Notes:		
Printed Name: Darrel Lockard 8/8/24		
SIGNATURE: <i>Darrel Lockard</i>		
Phone# 541-505-9968		CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna						ID #: OR4190416	Month/ Year: Jul-24	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	1.31	110	144.1	19.8	7.41	28.0	yes	120	
2	1.21	110	133.1	19.4	7.44	29.0	yes	112	
3	1.34	110	147.4	6.0	7.68	68.0	yes	123	
4	1.30	110	143.0	19.3	7.69	28.0	yes	133	
5	1.32	110	145.2	21.0	7.49	22.0	yes	126	
6	1.40	110	154.0	21.5	7.44	21.0	yes	122	
7	1.41	110	155.1	21.9	7.50	20.0	yes	121	
8	1.31	110	144.1	22.4	7.47	20.0	yes	128	
9	1.17	110	126.7	23.0	7.45	24.0	yes	124	
10	1.28	110	140.6	22.4	7.47	24.0	yes	115	
11	1.31	110	144.1	22.0	7.63	23.0	yes	113	
12	1.30	110	143.0	21.1	7.67	25.0	yes	122	
13	1.13	110	124.3	22.2	7.42	21.0	yes	112	
14	1.09	110	119.9	21.8	7.45	19.0	yes	109	
15	1.20	110	132.0	22.0	7.31	21.0	yes	117	
16	1.30	110	143.0	22.6	7.49	21.0	yes	135	
17	1.19	110	130.9	22.4	7.50	25.0	yes	127	
18	1.05	110	115.5	22.6	7.46	23.0	yes	125	
19	1.38	110	151.8	22.6	7.59	22.0	yes	124	
20	1.10	110	121.0	21.8	7.63	23.0	yes	134	
21	1.28	110	140.8	22.2	7.61	23.0	yes	120	
22	1.16	110	127.6	22.2	7.68	23.0	yes	120	
23	1.23	110	135.3	21.3	7.68	24.0	yes	126	
24	1.25	110	137.5	21.3	7.72	25.0	yes	123	
25	1.08	110	118.8	21.9	7.48	23.0	yes	119	
26	1.24	110	136.4	21.8	7.54	25.0	yes	118	
27	1.39	110	152.9	21.5	7.69	25.0	yes	119	
28	1.46	110	160.6	21.3	7.69	25.0	yes	115	
29	1.41	110	155.1	21.2	7.69	25.0	yes	126	
30	1.20	110	132.0	21.3	7.60	24.0	yes	120	
31	1.42	110	156.2	21.3	7.61	24.0	yes	129	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX