

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Aug-24

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
2	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
3	OFF	0.02	0.02	0.02	OFF	0.02	0.02	
4	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	OFF	0.02	0.02	OFF	0.02	0.02	0.02	
7	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	OFF	0.02	0.02	OFF	0.02	0.02	
9	0.02	OFF	OFF	0.02	0.02	0.02	0.02	
10	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	OFF	OFF	0.02	0.02	OFF	0.02	
12	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
13	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
14	OFF	OFF	0.02	0.02	OFF	0.02	0.02	
15	0.02	OFF	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
17	OFF	0.02	0.02	0.02	OFF	0.02	0.02	
18	0.02	OFF	OFF	0.02	0.02	0.02	0.02	
19	0.02	0.02	OFF	OFF	0.02	OFF	0.02	
20	OFF	0.02	0.02	0.02	OFF	0.02	0.02	
21	0.02	0.02	OFF	0.02	0.02	0.02	0.02	
22	0.02	0.02	OFF	OFF	OFF	OFF	0.02	
23	0.02	0.02	0.02	0.02	OFF	OFF	0.02	
24	OFF	OFF	0.02	0.02	0.02	OFF	0.02	
25	OFF	OFF	OFF	0.03	0.02	0.02	0.03	
26	OFF	OFF	OFF	0.02	0.03	0.02	0.03	
27	OFF	OFF	0.03	0.02	0.02	OFF	0.03	
28	OFF	OFF	OFF	OFF	0.03	0.02	0.03	
29	0.02	0.02	OFF	OFF	0.03	0.02	0.03	
30	0.02	OFF	0.03	0.02	0.02	0.03	0.03	
31	OFF	0.02	0.02	0.02	0.03	0.03	0.03	

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU?	<input checked="" type="checkbox"/> Yes	CT's met everyday? (see foot)	<input type="checkbox"/> NO
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="checkbox"/> Yes	All Cl2 residual at entry point \geq 0.2 mg/l?	<input checked="" type="checkbox"/> YES
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes		

Notes:	Printed Name: Darrel Lockard
	SIGNATURE: <i>Darrel Lockard</i>
	Phone# 541-505-9968
	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -- A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:	Aug-24	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	1.38	110	151.8	21.7	7.59	23.0	yes	145	
2	1.34	110	147.4	22.0	7.59	23.0	yes	127	
3	1.42	110	156.2	21.8	7.65	24.0	yes	130	
4	1.38	110	151.8	21.9	7.64	23.0	yes	129	
5	1.20	110	132.0	22.1	7.63	23.0	yes	129	
6	1.18	110	129.8	22.1	7.64	24.0	yes	129	
7	1.18	110	129.8	21.7	7.64	24.0	yes	130	
8	1.28	110	140.8	22.1	7.67	23.0	yes	134	
9	1.27	110	139.7	22.1	7.77	24.0	yes	121	
10	1.33	110	146.3	21.9	7.64	23.0	yes	123	
11	1.32	110	145.2	21.8	7.72	24.0	yes	130	
12	1.26	110	138.6	21.5	7.65	24.0	yes	128	
13	1.34	110	147.4	21.9	7.56	24.0	yes	130	
14	1.32	110	145.2	22.2	7.47	23.0	yes	129	
15	1.44	110	158.4	22.1	7.36	24.0	yes	130	
16	1.45	110	159.5	21.6	7.63	24.0	yes	125	
17	1.55	110	170.5	21.0	7.63	25.0	yes	128	
18	1.35	110	148.5	22.2	7.42	22.0	yes	122	
19	1.36	110	143.6	21.7	7.49	24.0	yes	127	
20	1.55	110	170.5	21.6	7.50	24.0	yes	126	
21	1.52	110	167.2	21.7	7.44	25.0	yes	131	
22	1.55	110	170.5	21.5	7.53	24.0	yes	123	
23	1.30	110	143.0	20.9	7.53	25.0	yes	112	
24	1.40	110	154.0	20.4	7.60	26.0	yes	162	
25	1.09	110	119.9	20.6	7.62	25.0	yes	114	
26	1.21	110	133.1	21.5	7.49	26.0	yes	119	
27	1.18	110	129.8	21.4	7.43	25.0	yes	118	
28	1.18	110	129.8	20.6	7.61	24.0	yes	117	
29	1.28	110	140.8	19.9	7.71	27.0	yes	127	
30	1.17	110	128.7	21.5	7.26	25.0	yes	147	
31	1.19	110	130.9	21.3	7.66	25.0	yes	130	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX