

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Sep-24

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 WTP : TP - A

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.03	0.03	0.03	OFF	0.03
2	OFF	OFF	OFF	0.03	0.03	OFF	0.03
3	OFF	OFF	0.03	0.03	0.02	0.02	0.03
4	0.02	0.03	0.03	0.02	0.02	0.02	0.03
5	0.03	0.03	0.02	0.03	OFF	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	OFF	OFF	OFF	OFF	0.03	0.03	0.03
8	OFF	OFF	0.02	0.02	0.03	0.02	0.03
9	0.02	OFF	OFF	0.02	0.02	0.02	0.02
10	0.03	OFF	0.02	0.02	0.02	0.02	0.03
11	0.02	OFF	0.03	OFF	0.02	0.02	0.03
12	OFF	0.02	OFF	OFF	0.02	0.02	0.02
13	0.02	0.02	0.02	OFF	0.02	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.02	0.02	OFF	OFF	0.02	0.02	0.02
16	OFF	OFF	OFF	0.02	0.02	OFF	0.02
17	OFF	OFF	OFF	0.02	OFF	OFF	0.02
18	OFF	0.02	0.02	OFF	0.02	0.02	0.02
19	0.02	0.02	0.02	OFF	0.02	0.02	0.02
20	0.02	OFF	0.02	0.02	0.02	0.02	0.02
21	OFF	0.02	0.02	0.02	0.02	0.02	0.02
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	OFF	0.02
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02
26	OFF	0.02	0.02	0.02	OFF	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	OFF	OFF	0.02
29	OFF	OFF	OFF	OFF	OFF	0.02	0.02
30	0.02	0.02	0.02	OFF	0.02	OFF	0.02

95% of 4-hour turbidity readings ≤ 0.3 NTU? <input type="checkbox"/> YES All 4-hour turbidity readings ≤ 1 NTU? <input type="checkbox"/> YES All turbidity readings < IFE ² triggers <input type="checkbox"/> Yes		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input type="checkbox"/> Yes All Cl2 residual at entry point ≥ 0.2 mg/l? <input type="checkbox"/> Yes	
--	--	---	--

Notes:	Printed Name: Darrel Lockard
	SIGNATURE: Darrel Lockard <small>Digitally signed by Darrel Lockard DN: cn=Darrel Lockard, o=Clatsop County, ou=Sanitation Dept, email=lockard@clatsop.net, c=US</small>
	Phone# 541-505-9968 CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Sep-24	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.17	110	128.7	20.6	7.68	26.0	yes	122
2	1.25	110	137.5	20.5	7.69	26.0	yes	126
3	1.03	110	113.3	21.0	7.46	25.0	yes	115
4	1.21	110	123.3	21.8	7.44	26.0	yes	124
5	1.34	110	147.4	21.0	7.63	24.0	yes	137
6	1.31	110	144.1	21.9	7.64	23.0	yes	124
7	1.33	110	146.3	21.2	7.56	24.0	yes	122
8	1.15	110	126.5	21.5	7.56	24.0	yes	130
9	1.30	110	143.0	21.1	7.62	25.0	yes	136
10	1.33	110	146.3	21.0	7.59	25.0	yes	129
11	1.29	110	141.9	20.8	7.62	27.0	yes	132
12	1.33	110	146.3	20.9	7.61	26.0	yes	124
13	1.31	110	144.1	20.5	7.69	26.0	yes	129
14	1.31	110	144.1	21.4	7.73	25.0	yes	118
15	1.40	110	154.0	20.3	7.60	25.0	yes	118
16	1.32	110	145.2	20.3	7.65	25.0	yes	116
17	1.47	110	161.7	20.0	7.67	27.0	yes	111
18	1.49	110	163.9	20.0	7.67	27.0	yes	116
19	1.41	110	155.1	19.8	7.69	26.0	yes	123
20	1.44	110	158.4	18.2	7.69	30.0	yes	129
21	1.41	110	155.1	20.2	7.69	27.0	yes	141
22	1.41	110	155.1	20.1	7.66	27.0	yes	140
23	1.43	110	157.3	19.9	7.56	26.0	yes	141
24	1.51	110	166.1	19.9	7.44	26.0	yes	134
25	1.49	110	163.9	19.9	7.65	27.0	yes	130
26	1.45	110	159.5	20.1	7.66	27.0	yes	134
27	1.37	110	150.7	20.1	7.68	27.0	yes	138
28	1.36	110	149.6	20.1	7.65	26.0	yes	141
29	1.45	110	159.5	19.8	7.64	27.0	yes	139
30	1.45	110	159.5	19.6	7.75	28.0	yes	140

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX