

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Oct-24

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 WTP : TP - A

Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	OFF	0.02	0.02	0.02	0.02	0.02	0.02
3	0.02	0.02	0.02	0.02	0.02	OFF	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	OFF	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	OFF	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	OFF	0.02	OFF	0.02	0.02
8	0.02	0.02	OFF	OFF	0.02	0.03	0.03
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.02	0.02	OFF	OFF	OFF	OFF	0.02
11	0.02	0.02	0.02	OFF	0.02	OFF	0.02
12	0.02	0.02	0.02	0.02	0.02	OFF	0.02
13	OFF	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	OFF	0.02	0.02	OFF	0.02
15	0.02	OFF	OFF	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	OFF	OFF	OFF	0.02
17	0.02	0.02	0.02	0.02	0.02	OFF	0.02
18	OFF	0.02	0.02	0.02	0.02	OFF	0.02
19	OFF	0.02	OFF	OFF	OFF	OFF	0.02
20	OFF	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	OFF	OFF	0.02
22	0.02	0.02	0.02	0.02	0.02	OFF	0.02
23	OFF	0.02	0.02	0.02	OFF	0.02	0.02
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	OFF	OFF	0.02
26	0.02	0.02	0.02	OFF	OFF	OFF	0.02
27	0.02	0.02	OFF	OFF	0.02	OFF	0.02
28	OFF	0.02	0.02	OFF	OFF	OFF	0.02
29	OFF	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02
31	0.02	0.02	OFF	OFF	0.02	0.02	0.02

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input type="checkbox"/> Yes	CT's met everyday? (see back) <input type="checkbox"/> Yes
All 4-hour turbidity readings ≤ 1 NTU? <input type="checkbox"/> Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? <input type="checkbox"/> Yes
All turbidity readings < IFE <sup>2</sup> triggers <input type="checkbox"/> Yes	

Notes:	Printed Name: Darrel Lockard
	SIGNATURE: Darrel Lockard <small>DN: cn=Darrel Lockard, o=Delta Operations, ou, email=darrel@psd.com, c=US Date: 2024.11.06 12:00:32 -08'00'</small>
	Phone# 541-505-9968 CERT# 2853

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Oct-24						Disinfection Giardia Log Inactiv:	1	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.45	110	159.5	19.3	7.67	29.0	yes	138
2	1.40	110	154.0	18.7	7.47	28.0	yes	147
3	1.51	110	166.1	18.7	7.56	29.0	yes	135
4	1.49	110	163.9	19.0	7.59	28.0	yes	137
5	1.48	110	162.8	18.9	7.64	29.0	yes	139
6	1.46	110	160.6	18.4	7.65	30.0	yes	138
7	1.51	110	166.1	18.6	7.75	30.1	yes	137
8	1.44	110	158.4	18.5	7.71	31.0	yes	138
9	1.40	110	154.0	17.4	7.62	30.0	yes	142
10	1.41	110	155.1	17.6	7.59	31.0	yes	143
11	1.44	110	158.4	17.6	7.59	31.0	yes	135
12	1.47	110	161.7	18.1	7.65	30.0	yes	139
13	1.51	110	166.1	18.2	7.68	30.0	yes	146
14	1.43	110	157.3	18.2	7.56	29.0	yes	143
15	1.44	110	158.4	18.3	7.48	30.0	yes	138
16	1.11	110	122.1	18.1	7.65	31.0	yes	139
17	1.35	110	148.5	16.7	7.61	31.0	yes	139
18	1.54	110	169.4	16.2	7.62	34.0	yes	129
19	1.39	110	152.9	16.2	7.62	34.0	yes	135
20	1.45	110	159.5	17.3	7.62	32.0	yes	132
21	1.35	110	148.5	16.0	7.60	34.0	yes	138
22	1.52	110	167.2	15.8	7.58	34.0	yes	139
23	1.35	110	144.8	15.7	7.56	35.0	yes	145
24	1.34	110	147.4	15.5	7.60	35.0	yes	151
25	1.43	110	157.0	16.0	7.56	37.0	yes	137
26	1.48	110	162.8	15.7	7.60	36.0	yes	142
27	1.37	110	150.7	15.0	7.60	36.0	yes	137
28	1.48	110	162.8	14.7	7.67	38.0	yes	133
29	1.52	110	167.2	14.5	7.61	38.0	yes	134
30	1.54	110	169.4	14.1	7.68	40.0	yes	134
31	1.36	110	149.6	13.6	7.61	40.0	yes	141

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.