

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Nov-24

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
2	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
3	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
4	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.01	OFF	0.02	0.02	0.02	OFF	0.02	
7	OFF	OFF	OFF	OFF	OFF	0.02	0.02	
8	0.02	0.02	OFF	OFF	0.02	OFF	0.02	
9	0.02	0.02	0.02	OFF	OFF	OFF	0.02	
10	0.02	0.02	OFF	OFF	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
12	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
13	0.02	0.02	OFF	OFF	0.02	0.02	0.02	
14	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
15	0.02	OFF	0.03	0.02	0.02	0.02	0.03	
16	OFF	0.02	0.02	OFF	OFF	0.02	0.02	
17	0.02	0.02	0.02	OFF	0.02	OFF	0.02	
18	0.02	0.02	0.02	0.02	0.03	0.02	0.03	
19	OFF	OFF	0.02	0.02	0.02	0.02	0.02	
20	0.02	OFF	OFF	0.02	0.02	0.02	0.02	
21	0.02	0.03	0.03	0.03	0.04	0.03	0.04	
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
23	0.02	0.02	OFF	OFF	0.02	0.03	0.03	
24	0.02	0.03	OFF	OFF	OFF	Off	0.03	
25	OFF	0.02	0.04	OFF	0.03	0.04	0.04	
26	OFF	0.03	0.03	0.03	0.06	0.04	0.06	
27	0.03	0.03	0.03	OFF	OFF	OFF	0.03	
28	Off	0.04	0.04	0.04	0.04	OFF	0.04	
29	OFF	0.04	0.04	OFF	0.04	0.04	0.04	
30	0.04	0.04	0.04	OFF	OFF	0.02	0.04	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ YES	CT's met everyday? (see back)
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ YES	☒ YES
All turbidity readings < IFE ² triggers	☒ YES	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
		☒ YES

Notes:	Printed Name: Darrel Lockard 12/06/2024	
	SIGNATURE:	
	Phone# 541-505-9968	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/ Year: Nov-24							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.49	110	163.9	13.6	7.64	40.0	yes	151
2	1.43	110	157.3	13.9	7.60	40.0	yes	139
3	1.40	110	154.0	13.6	7.58	40.0	yes	141
4	1.32	110	145.2	13.5	7.58	40.0	yes	143
5	1.37	110	150.7	13.1	7.55	40.0	yes	142
6	1.46	110	160.6	13.0	7.58	41.0	yes	137
7	1.47	110	161.7	12.8	7.57	41.0	yes	127
8	1.36	110	149.6	12.8	7.50	41.0	yes	120
9	1.45	110	159.5	12.6	7.57	42.0	yes	119
10	1.47	110	161.7	12.8	7.40	43.0	yes	131
11	1.40	110	154.0	12.5	7.49	44.0	yes	138
12	1.41	110	155.1	12.5	7.49	41.0	yes	139
13	1.30	110	143.0	12.0	7.59	44.0	yes	148
14	1.28	110	140.8	12.0	7.54	43.0	yes	134
15	1.30	110	143.0	11.1	7.60	47.0	yes	127
16	1.28	110	140.8	10.9	7.53	46.0	yes	127
17	1.41	110	155.1	10.8	7.59	50.0	yes	136
18	1.41	110	155.1	10.3	7.59	49.0	yes	144
19	1.39	110	152.9	10.3	7.52	48.0	yes	120
20	1.25	110	137.5	10.1	7.61	42.0	yes	123
21	1.16	110	127.6	10.0	7.58	50.0	yes	115
22	1.25	110	137.5	10.1	7.61	42.0	yes	123
23	1.16	110	127.6	10.0	7.58	50.0	yes	115
24	1.42	110	156.2	10.0	7.54	50.0	yes	110
25	1.42	110	156.2	10.0	7.51	50.0	yes	125
26	1.41	110	155.1	10.3	7.25	51.0	yes	125
27	1.38	110	151.8	10.5	7.54	50.0	yes	136
28	1.17	110	128.7	9.8	7.54	50.0	yes	128
29	1.53	110	168.3	9.3	7.65	54.0	yes	132
30	1.32	110	145.2	9.4	7.68	55.0	yes	133

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX