

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Clatsop

Conventional or Direct Filtration

Month/Year:

Dec-24

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	0.02	0.02	0.03	0.02	OFF	0.03	
2	0.02	OFF	OFF	0.02	OFF	OFF	0.02	
3	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
4	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
5	0.02	0.02	OFF	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
7	0.02	0.02	0.01	OFF	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	OFF	0.02	0.02	
9	0.02	0.02	OFF	OFF	OFF	OFF	0.02	
10	0.02	0.02	OFF	OFF	OFF	0.02	0.02	
11	0.02	OFF	OFF	0.01	0.02	0.02	0.02	
12	Off	0.02	0.02	0.02	0.02	OFF	0.02	
13	OFF	OFF	0.02	OFF	0.02	0.02	0.02	
14	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
15	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
16	0.01	OFF	0.02	0.02	0.02	OFF	0.02	
17	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
18	0.02	OFF	OFF	0.02	0.02	0.02	0.02	
19	0.02	0.02	0.02	OFF	0.02	OFF	0.02	
20	0.01	0.02	OFF	0.02	0.02	OFF	0.02	
21	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
22	0.02	OFF	0.02	0.02	0.02	0.02	0.02	
23	0.02	OFF	0.03	0.02	0.02	0.02	0.03	
24	0.02	0.02	0.03	OFF	0.02	OFF	0.03	
25	0.02	0.02	OFF	0.02	0.02	0.03	0.03	
26	0.02	OFF	0.02	OFF	0.02	0.02	0.02	
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
28	0.02	0.02	OFF	0.02	0.02	0.02	0.02	
29	0.02	0.02	0.03	0.03	OFF	0.03	0.03	
30	0.03	OFF	0.03	0.03	0.03	0.03	0.03	
31	OFF	0.05	0.05	0.05	OFF	0.05	0.05	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes	CT's met everyday? (see back)
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes	☒ Yes
All turbidity readings < IFE ² triggers	☒ Yes	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
		☒ Yes

Notes:	Printed Name: Darrel Lockard	
	SIGNATURE: Darrel Lockard	
	Phone# 541-505-9968	Cert #2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Dec-24		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.45	110	159.5	9.2	7.65	55.0	yes	134					
2	1.45	110	159.5	9.0	7.69	57.0	yes	130					
3	1.39	110	152.9	8.5	7.74	59.0	yes	154					
4	1.39	110	152.9	8.8	7.68	62.0	yes	154					
5	1.43	110	157.3	8.7	7.72	62.0	yes	131					
6	1.35	110	148.5	7.8	7.77	63.0	yes	114					
7	1.47	110	161.7	7.8	7.80	63.0	yes	114					
8	1.45	110	159.5	8.0	7.79	65.0	yes	134					
9	1.46	110	160.6	7.8	7.73	62.0	yes	116					
10	1.27	110	139.7	7.8	7.76	63.0	yes	121					
11	1.26	110	138.6	7.5	7.76	63.0	yes	118					
12	1.27	110	139.7	8.6	7.71	62.0	yes	112					
13	1.34	110	147.4	8.6	7.66	61.0	yes	121					
14	1.20	110	120.0	8.3	7.71	62.0	yes	118					
15	1.27	110	139.7	8.2	7.52	62.0	yes	117					
16	1.26	110	138.6	7.5	7.64	60.0	yes	117					
17	1.39	110	152.9	7.8	7.71	61.0	yes	128					
18	1.63	110	179.3	8.1	7.68	61.0	yes	127					
19	1.28	110	140.8	8.2	7.68	60.0	yes	118					
20	1.46	110	140.8	9.0	7.38	58.0	yes	112					
21	1.31	110	144.1	9.3	7.37	55.0	yes	117					
22	1.14	110	125.4	8.5	7.61	55.0	yes	118					
23	1.24	110	136.4	8.4	7.64	58.0	yes	111					
24	1.30	110	143.0	8.4	7.61	57.0	yes	112					
25	1.35	110	148.5	8.5	7.59	56.0	yes	110					
26	1.20	110	132.0	8.4	7.64	57.0	yes	116					
27	1.18	110	129.8	8.6	7.61	56.0	yes	116					
28	1.30	110	140.0	9.1	7.56	55.0	yes	114					
29	1.25	110	137.5	8.8	7.49	55.0	yes	116					
30	1.27	110	139.7	8.3	7.50	54.0	yes	115					
31	1.22	110	134.2	8.2	7.59	56.0	yes	119					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX