

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Jan-25

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416		WTP : TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.07	OFF	0.07	0.08	0.07	0.08
2	0.07	0.08	OFF	0.02	0.02	0.02	0.08
3	0.02	OFF	0.02	OFF	0.03	0.04	0.04
4	0.04	0.04	0.04	OFF	0.06	OFF	0.06
5	0.05	OFF	0.03	OFF	0.03	OFF	0.05
6	0.03	0.03	0.03	OFF	0.04	OFF	0.04
7	OFF	0.03	0.05	0.04	0.03	0.03	0.05
8	OFF	OFF	0.05	0.04	0.04	OFF	0.05
9	OFF	0.06	0.05	0.04	OFF	0.02	0.06
10	OFF	0.02	0.02	0.02	0.02	OFF	0.02
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02
12	OFF	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	OFF	0.02
14	0.02	OFF	0.02	0.02	OFF	0.02	0.02
15	OFF	0.02	0.02	0.02	0.02	OFF	0.02
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	OFF	0.02	OFF	0.02
19	0.02	0.02	0.02	0.02	0.03	0.02	0.03
20	0.02	0.03	0.02	0.02	0.03	OFF	0.03
21	0.02	0.02	0.02	0.03	0.02	0.04	0.04
22	0.02	OFF	0.06	0.03	0.03	OFF	0.06
23	0.03	OFF	0.02	0.05	0.03	0.03	0.05
24	0.02	0.03	0.03	0.03	0.03	OFF	0.03
25	OFF	0.03	0.02	OFF	OFF	0.03	0.03
26	0.03	0.03	OFF	OFF	0.03	OFF	0.03
27	OFF	0.04	0.04	OFF	OFF	0.04	0.04
28	0.04	0.06	OFF	OFF	OFF	OFF	0.06
29	OFF	0.04	0.03	0.05	0.11	0.02	0.11
30	OFF	OFF	OFF	OFF	OFF	0.04	0.04
31	0.03	0.06	0.03	0.03	OFF	OFF	0.06

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	YES
All 4-hour turbidity readings $\leq$ 1 NTU?	YES
All turbidity readings < IFE ² triggers	YES
CT's met everyday? (see back)	YES
All Cl2 residual at entry point $\geq$ 0.2 mg/l?	YES

Notes:	Printed Name: Darrel Lockard
	SIGNATURE: Darrel Lockard
	Phone# 541-505-9968 CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Jan-25		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.23	110	135.3	8.3	7.71	59.0	yes	114					
2	1.29	110	141.9	8.4	7.64	57.0	yes	114					
3	1.16	110	127.6	8.2	7.57	56.0	yes	116					
4	1.28	110	140.8	8.3	7.58	56.0	yes	114					
5	1.34	110	147.4	8.7	7.56	58.0	yes	115					
6	1.39	110	152.9	8.6	7.55	58.0	yes	119					
7	1.02	110	112.2	8.0	7.85	64.0	yes	116					
8	1.26	110	138.6	7.9	7.56	58.0	yes	77					
9	1.32	110	145.2	9.1	7.47	55.0	yes	119					
10	1.39	110	152.9	9.2	7.76	57.0	yes	124					
11	1.38	110	151.8	7.8	7.70	62.0	yes	125					
12	1.32	110	145.2	7.8	7.73	62.0	yes	123					
13	1.42	110	156.2	7.3	7.65	63.0	yes	127					
14	1.43	110	157.3	7.3	7.71	64.0	yes	110					
15	1.46	110	160.6	7.3	7.89	68.0	yes	110					
16	1.49	110	163.9	7.3	7.77	66.0	yes	110					
17	1.37	110	150.7	7.7	7.58	68.0	yes	116					
18	1.48	110	153.9	7.3	7.57	64.0	yes	110					
19	1.30	110	143.0	6.3	7.74	71.0	yes	116					
20	1.52	110	167.2	6.0	7.73	71.0	yes	124					
21	1.51	110	166.1	5.9	7.76	72.0	yes	124					
22	1.50	110	165.0	5.6	7.78	75.0	yes	116					
23	1.09	110	119.9	5.8	7.72	71.0	yes	116					
24	1.47	110	161.7	5.8	7.79	73.0	yes	95					
25	1.30	110	143.0	6.3	7.54	73.0	yes	89					
26	1.15	110	126.5	6.8	7.50	65.0	yes	84					
27	1.03	110	113.3	6.1	7.61	65.0	yes	92					
28	1.00	110	110.0	5.4	7.68	75.0	yes	95					
29	1.13	110	124.3	5.0	7.76	74.0	yes	94					
30	1.15	110	126.5	5.3	7.79	73.0	yes	96					
31	1.01	110	111.1	5.3	7.77	77.0	yes	88					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX