

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Feb-25

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	0.03	0.02	OFF	0.03	
2	0.02	0.02	0.03	0.02	0.02	OFF	0.03	
3	0.05	OFF	0.02	OFF	0.02	0.02	0.05	
4	0.03	0.02	OFF	0.03	0.02	OFF	0.03	
5	OFF	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.05	0.02	0.05	
7	OFF	0.02	OFF	OFF	0.03	0.02	0.03	
8	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
9	0.02	0.03	0.02	0.02	OFF	0.03	0.03	
10	0.08	0.02	OFF	0.02	0.03	OFF	0.08	
11	0.02	OFF	OFF	0.02	0.03	OFF	0.03	
12	0.02	0.02	OFF	0.06	0.03	OFF	0.06	
13	OFF	OFF	0.05	0.03	0.04	0.03	0.05	
14	0.04	0.03	OFF	0.03	OFF	0.03	0.04	
15	OFF	0.04	OFF	0.03	0.03	OFF	0.04	
16	0.03	0.03	OFF	0.14	0.03	0.04	0.14	
17	0.10	0.04	OFF	0.09	0.07	OFF	0.10	
18	OFF	0.13	0.06	0.04	0.03	0.03	0.13	
19	0.06	0.09	0.03	0.03	0.06	0.03	0.09	
20	OFF	0.03	0.02	0.03	OFF	0.03	0.03	
21	OFF	0.03	OFF	OFF	0.03	0.02	0.03	
22	OFF	OFF	0.02	OFF	0.02	0.04	0.04	
23	0.02	OFF	0.04	OFF	0.02	0.05	0.05	
24	0.02	0.03	0.07	0.02	0.02	0.05	0.07	
25	OFF	0.03	0.02	0.02	OFF	OFF	0.03	
26	0.03	OFF	0.04	OFF	OFF	0.04	0.04	
27	0.04	0.04	0.06	0.05	0.04	0.04	0.06	
28	OFF	0.04	0.06	OFF	0.27	0.02	0.27	
29								
30								
31								

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? YES	CT's met everyday? (see back) YES
All 4-hour turbidity readings $\leq$ 1 NTU? YES	All Cl2 residual at entry point $\geq$ 0.2 mg/l? YES
All turbidity readings < IFE ² triggers YES	

Notes:	Printed Name: Darrel Lockard
	SIGNATURE: Darrel Lockard
	Phone# 541-505-9968

CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in column 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Feb-25		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.52	110	167.2	5.5	7.74	75.0	yes	86					
2	1.37	110	150.7	5.6	7.72	78.0	yes	88					
3	1.47	110	161.7	6.1	7.72	78.0	yes	91					
4	1.46	110	160.6	5.4	7.78	76.0	yes	94					
5	1.44	110	158.4	5.3	7.80	76.0	yes	92					
6	1.46	110	160.6	5.8	7.78	79.0	yes	96					
7	1.38	110	151.8	6.1	7.97	76.0	yes	95					
8	1.33	110	146.3	5.4	7.97	79.0	yes	87					
9	1.25	110	137.5	5.3	7.74	73.0	yes	89					
10	1.32	110	145.2	6.7	7.72	75.0	yes	92					
11	1.36	110	143.6	6.1	7.72	82.0	yes	94					
12	1.17	110	128.7	5.1	7.84	77.0	yes	99					
13	1.34	110	147.4	4.4	7.84	83.0	yes	98					
14	1.31	110	144.1	4.4	7.84	87.0	yes	88					
15	1.17	110	128.7	4.4	7.78	77.0	yes	82					
16	1.19	110	130.9	4.3	7.78	78.0	yes	86					
17	1.16	110	127.6	4.4	7.73	79.0	yes	89					
18	1.42	110	156.2	4.4	7.76	80.0	yes	95					
19	1.44	110	158.4	5.0	7.72	77.0	yes	84					
20	1.47	110	161.7	5.3	7.55	71.0	yes	100					
21	1.26	110	138.6	5.4	7.56	68.0	yes	100					
22	1.32	110	145.2	5.4	7.60	70.0	yes	88					
23	1.27	110	139.7	6.0	7.57	66.0	yes	92					
24	1.45	110	159.5	6.7	7.57	63.0	yes	90					
25	1.48	110	16238.0	5.9	7.65	69.0	yes	105					
26	1.32	110	145.2	8.4	7.49	63.0	yes	90					
27	1.36	110	149.6	8.4	7.30	58.0	yes	86					
28	1.34	110	147.4	7.8	7.45	56.0	yes	88					
29													
30													
31													

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX