

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Mar-25

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416		WTP : TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.02	0.03	0.02	0.02	0.02	0.02	0.03
2	0.02	0.02	0.02	0.02	0.31	OFF	0.31
3	OFF	0.04	0.02	0.07	0.04	OFF	0.07
4	OFF	OFF	0.04	0.03	0.03	0.03	0.04
5	0.02	0.05	0.02	0.04	OFF	0.02	0.05
6	0.05	OFF	0.02	0.02	0.03	0.02	0.05
7	0.06	0.02	0.02	0.02	0.02	0.02	0.06
8	0.05	0.02	0.04	OFF	0.02	0.02	0.05
9	OFF	0.05	OFF	0.03	OFF	OFF	0.05
10	0.03	0.02	0.03	OFF	0.03	0.04	0.04
11	0.02	0.03	0.02	OFF	0.02	0.02	0.03
12	0.02	0.02	0.02	OFF	0.06	OFF	0.06
13	0.02	0.02	0.02	0.02	0.07	OFF	0.07
14	0.02	OFF	OFF	0.02	0.03	OFF	0.03
15	0.02	OFF	0.03	0.02	0.04	0.02	0.04
16	OFF	0.06	OFF	OFF	OFF	0.03	0.06
17	0.02	0.04	0.02	0.03	0.02	0.04	0.04
18	OFF	0.03	0.02	0.03	0.02	0.03	0.03
19	0.02	0.06	0.02	0.05	0.03	0.04	0.06
20	0.02	0.03	0.02	0.03	0.02	OFF	0.03
21	OFF	0.03	OFF	0.02	0.03	0.04	0.04
22	OFF	0.04	OFF	0.04	0.02	0.02	0.04
23	0.02	OFF	0.02	0.03	0.02	0.07	0.07
24	0.02	0.02	0.02	0.03	OFF	0.05	0.05
25	0.02	0.02	OFF	0.02	OFF	0.02	0.02
26	0.02	0.02	0.03	0.02	0.03	0.03	0.03
27	OFF	OFF	OFF	OFF	0.02	OFF	0.02
28	0.02	0.04	0.03	0.02	0.02	0.02	0.04
29	OFF	OFF	0.02	0.03	OFF	0.02	0.03
30	0.02	0.02	0.02	OFF	0.02	OFF	0.02
31	0.02	0.04	0.02	0.02	0.02	OFF	0.04

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? YES	CT's met everyday? (see back)
All 4-hour turbidity readings $\leq$ 1 NTU? YES	YES
All turbidity readings < IFE ² triggers YES	All Cl2 residual at entry point $\geq$ 0.2 mg/l? YES

Notes:	Printed Name: Darrel Lockard
	SIGNATURE: Darrel Lockard
	Phone# 541-505-9968 CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	
System Name:	Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/ Year:	Mar-25	Disinfection <i>Giardia</i> Log Inactiv:	1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.41	110	155.1	7.8	7.65	61.0	yes	86
2	1.22	110	134.2	7.7	7.84	65.0	yes	83
3	1.35	110	148.5	7.5	7.70	63.0	yes	89
4	1.57	110	172.7	7.3	7.75	67.0	yes	102
5	1.50	110	165.0	7.3	7.75	67.0	yes	100
6	1.07	110	117.7	8.3	7.74	66.0	yes	83
7	1.14	110	125.4	7.9	7.75	63.0	yes	90
8	1.46	110	160.6	7.7	7.88	67.0	yes	92
9	1.62	110	178.2	7.7	7.80	65.0	yes	90
10	1.49	110	163.9	7.7	7.70	62.0	yes	95
11	1.48	110	162.8	7.3	7.67	64.0	yes	87
12	1.19	110	130.9	7.7	7.65	60.0	yes	88
13	1.26	110	138.6	7.8	7.61	58.0	yes	85
14	1.26	110	138.6	8.3	7.40	61.0	yes	86
15	1.32	110	145.2	8.6	7.61	62.0	yes	81
16	1.40	110	154.0	7.5	7.65	61.0	yes	82
17	1.37	110	150.7	7.5	7.60	60.0	yes	93
18	1.51	110	166.1	7.6	7.54	59.0	yes	97
19	1.41	110	155.1	7.8	7.55	59.0	yes	99
20	1.18	110	129.8	7.8	7.48	56.0	yes	95
21	1.28	110	140.8	7.9	7.67	60.0	yes	91
22	1.27	110	139.7	9.1	7.52	55.0	yes	102
23	1.06	110	143.0	9.5	7.54	52.0	yes	92
24	1.04	110	114.4	8.5	7.54	55.0	yes	99
25	1.50	110	165.0	9.0	7.56	54.0	yes	94
26	1.41	110	155.1	9.6	7.53	51.0	yes	88
27	1.47	110	158.4	9.8	7.61	52.0	yes	91
28	1.40	110	154.0	9.9	7.60	52.0	yes	86
29	1.38	110	151.8	10.0	7.60	51.0	yes	83
30	1.41	110	155.1	10.0	7.65	52.0	yes	83
31	1.36	110	149.6	9.8	7.66	53.0	yes	93

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.