

## OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: May-25

System Name: Georgia Pacific CPLP Wauna		ID #: OR4190416		WTP : TP - A			
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.02	OFF	0.02	0.02	OFF	0.02
2	0.02	OFF	0.03	0.02	0.02	0.05	0.05
3	0.02	0.02	OFF	0.02	OFF	0.02	0.02
4	0.02	0.04	0.02	0.02	0.02	0.02	0.04
5	0.04	0.02	0.02	0.06	0.02	0.03	0.06
6	OFF	0.03	OFF	0.02	0.04	0.02	0.04
7	0.02	0.02	OFF	OFF	OFF	0.02	0.02
8	0.03	0.02	0.02	OFF	OFF	0.04	0.04
9	0.02	OFF	OFF	0.02	OFF	0.02	0.02
10	0.02	0.02	0.02	OFF	OFF	0.02	0.02
11	OFF	0.05	0.02	OFF	0.02	0.02	0.05
12	OFF	0.02	OFF	OFF	0.02	0.03	0.03
13	OFF	OFF	OFF	OFF	OFF	OFF	0.00
14	OFF	OFF	OFF	OFF	OFF	OFF	0.00
15	OFF	OFF	OFF	OFF	OFF	OFF	0.00
16	OFF	OFF	OFF	OFF	OFF	OFF	0.00
17	0.13	0.09	OFF	0.10	0.04	0.06	0.13
18	0.02	OFF	OFF	0.11	0.02	OFF	0.11
19	OFF	OFF	0.02	OFF	0.05	0.02	0.05
20	0.07	0.02	0.04	OFF	0.02	OFF	0.07
21	0.04	0.02	0.02	OFF	0.03	OFF	0.04
22	OFF	0.02	0.02	0.03	0.02	OFF	0.03
23	0.03	0.03	0.04	0.03	0.05	0.02	0.05
24	0.03	OFF	0.05	OFF	0.04	OFF	0.05
25	OFF	0.05	0.03	0.02	0.03	0.04	0.05
26	OFF	OFF	0.02	0.02	0.02	0.02	0.02
27	0.05	0.02	0.02	0.10	0.03	0.03	0.10
28	0.04	0.03	0.02	0.09	0.03	0.02	0.09
29	0.02	0.04	0.03	0.02	0.02	OFF	0.04
30	OFF	0.04	0.02	0.03	0.03	OFF	0.04
31	OFF	0.02	OFF	OFF	OFF	0.06	0.06

  

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>
All 4-hour turbidity readings $\leq$ 1 NTU? <b>YES</b>	All Cl2 residual at entry point $\geq$ 0.2 mg/l? <b>YES</b>
All turbidity readings < IFE <sup>2</sup> triggers <b>YES</b>	

Notes: May 13 - May 16 system down for maintenance

Printed Name: DARREL LOCKARD

SIGNATURE: Darrel Lockard

Phone# (503) 505-9768

CERT# 2853

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		May-25		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.35	110	148.5	14.5	7.53	42.0	yes	107					
2	1.57	110	172.7	14.0	7.57	40.0	yes	104					
3	1.61	110	177.1	13.3	7.65	42.0	yes	106					
4	1.40	110	154.0	13.4	7.66	42.0	yes	105					
5	1.45	110	159.5	13.6	7.66	41.0	yes	109					
6	1.53	110	168.3	13.8	7.67	41.0	yes	107					
7	1.46	110	160.6	14.3	7.63	39.0	YES	101					
8	1.50	110	165.0	14.0	7.65	40.0	yes	93					
9	1.56	110	171.6	13.9	7.63	40.0	yes	94					
10	1.51	110	166.1	14.1	7.63	39.0	yes	89					
11	1.52	110	167.2	14.2	7.67	40.0	yes	93					
12	1.46	110	160.6	14.3	7.65	40.0	yes	97					
13	OFF												
14	OFF												
15	OFF												
16	OFF												
17	1.02	110	112.2	14.3	7.60	40.0	yes	81					
18	1.33	110	146.3	14.3	7.61	41.0	yes	81					
19	1.28	110	140.8	14.2	7.61	38.0	yes	101					
20	1.31	110	144.1	14.0	7.67	39.0	yes	85					
21	1.29	110	141.9	14.4	7.67	39.0	yes	89					
22	1.26	110	138.6	13.0	7.63	42.0	yes	91					
23	1.39	110	152.9	15.0	7.65	37.0	yes	87					
24	1.41	110	155.1	14.9	7.75	30.0	yes	87					
25	1.25	110	137.5	15.0	7.61	37.0	yes	85					
26	1.35	110	148.5	16.4	7.52	36.0	yes	95					
27	1.38	110	151.8	15.8	7.60	36.0	yes	95					
28	1.55	110	170.5	16.5	7.52	33.0	yes	105					
29	1.44	110	158.4	17.0	7.59	34.0	yes	105					
30	1.47	110	161.7	15.5	7.80	34.0	yes	105					
31	1.25	110	137.5	16.0	7.80	38.0	yes	99					

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX