

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Aug-25

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	OFF	OFF	0.06	0.02	0.03	0.06	
2	OFF	0.06	0.03	0.87	0.03	0.03	0.87	
3	OFF	0.03	0.03	0.03	0.03	0.03	0.03	
4	0.03	0.04	OFF	OFF	0.04	0.04	0.04	
5	0.04	0.04	0.05	0.05	0.02	0.02	0.05	
6	0.02	0.03	0.02	0.02	0.02	0.02	0.03	
7	0.02	0.02	0.05	0.02	0.02	0.02	0.05	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.03	0.02	0.02	0.02	0.06	0.06	
10	0.02	0.02	0.02	0.02	0.05	0.02	0.05	
11	0.04	0.02	0.02	0.02	0.02	0.02	0.04	
12	0.08	0.02	0.03	0.02	0.02	OFF	0.08	
13	0.02	0.02	0.03	0.03	0.02	OFF	0.03	
14	0.02	0.03	OFF	0.02	0.04	OFF	0.04	
15	OFF	OFF	OFF	OFF	OFF	0.06	0.06	
16	OFF	OFF	OFF	0.02	0.02	0.02	0.02	
17	0.02	0.02	0.02	0.02	0.02	OFF	0.02	
18	0.03	0.02	0.06	0.02	0.02	0.02	0.06	
19	0.04	OFF	0.02	OFF	0.02	0.02	0.04	
20	0.05	0.02	0.02	0.02	0.02	0.02	0.05	
21	0.03	0.03	0.03	0.02	0.02	0.02	0.03	
22	0.03	0.04	0.02	0.02	0.03	0.02	0.04	
23	0.03	0.03	0.02	0.03	0.03	0.03	0.03	
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
25	0.02	0.02	OFF	OFF	0.02	0.03	0.03	
26	0.03	OFF	OFF	0.05	0.03	0.08	0.08	
27	0.02	0.03	0.03	OFF	OFF	0.04	0.04	
28	OFF	0.05	0.02	0.02	0.02	0.02	0.05	
29	0.02	0.07	0.03	0.02	OFF	0.02	0.07	
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
31	OFF	0.02	0.02	0.02	0.02	0.02	0.02	

Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes	CT's met everyday? (see back) Yes
All 4-hour turbidity readings ≤ 1 NTU? Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All turbidity readings < IFE ² triggers Yes	

Notes: On August 15 the mill had an unplanned power outage resulting in loss of distribution system pressure from approximately 08:15 - 14:30. The mill issued a boil water notice that was in effect until coliform absent results were received on August 19. The boil water notice was lifted following confirmation of coliforms absent.	Printed Name: Darrel Lockard <i>9/8/25</i>
	SIGNATURE: <i>Darrel Lockard</i>
	Phone# 541-505-9968 CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Aug-25		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.43	110	157.3	22.4	7.60	23.0	yes	131					
2	1.45	110	159.5	22.3	7.59	22.0	yes	133					
3	1.36	110	149.6	21.3	7.62	24.0	yes	126					
4	1.43	110	157.6	21.4	7.62	24.0	yes	125					
5	1.31	110	144.1	21.3	7.59	23.0	yes	131					
6	1.31	110	144.1	20.9	7.59	24.0	yes	126					
7	1.43	110	157.3	21.3	7.60	24.0	yes	130					
8	1.38	110	151.8	20.4	7.59	25.0	yes	134					
9	1.34	110	147.4	22.3	7.55	24.0	yes	146					
10	1.37	110	150.7	22.9	7.60	23.0	yes	153					
11	1.37	110	150.7	21.7	7.61	23.0	yes	146					
12	1.30	110	143.0	22.5	7.59	22.0	yes	143					
13	1.37	110	150.7	22.1	7.59	23.0	yes	145					
14	1.32	110	145.2	22.0	7.66	23.0	yes	129					
15	1.41	110	155.1	22.2	7.61	22.0	yes	122					
16	0.37	110	40.7	22.2	7.60	22.0	yes	110					
17	1.33	110	146.3	22.7	7.43	22.0	yes	114					
18	1.33	110	146.3	22.8	7.63	22.0	yes	131					
19	1.40	110	154.0	21.9	7.61	23.0	yes	120					
20	1.56	110	154.0	21.7	7.59	23.0	yes	125					
21	1.23	110	135.3	22.2	7.85	25.0	yes	151					
22	1.44	110	158.4	22.1	7.85	25.0	yes	134					
23	1.49	110	163.9	22.3	7.55	22.0	yes	140					
24	1.36	110	149.6	22.3	7.52	22.0	yes	139					
25	1.29	110	141.9	23.3	7.48	21.0	yes	137					
26	1.39	110	152.9	22.8	7.52	21.0	yes	144					
27	1.30	110	143.0	21.9	7.53	22.0	yes	137					
28	1.40	110	154.0	21.9	7.53	22.0	yes	130					
29	1.36	110	149.6	22.2	7.52	22.0	yes	131					
30	1.33	110	146.3	21.9	7.54	22.0	yes	119					
31	1.32	110	145.2	22.1	7.53	22.0	yes	127					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX