

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Sep-25

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.02	OFF	0.02	0.02	0.02	0.03
2	0.02	0.02	0.03	0.02	0.02	0.02	0.03
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	OFF	0.02	0.02
5	0.03	0.02	0.02	0.02	0.03	0.02	0.03
6	0.02	0.02	0.02	0.02	0.02	OFF	0.02
7	OFF	0.02	0.02	OFF	0.02	0.02	0.02
8	OFF	0.02	0.02	0.02	OFF	0.02	0.02
9	0.02	0.02	0.02	0.02	OFF	0.02	0.02
10	0.02	0.02	OFF	0.02	0.02	0.01	0.02
11	0.02	OFF	0.02	OFF	0.03	0.02	0.03
12	0.02	OFF	OFF	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	OFF	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	OFF	OFF	0.02	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	OFF	OFF	0.02	0.02	0.02	0.02
18	OFF	0.02	0.03	0.02	0.02	0.02	0.03
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.01	0.02	0.02	OFF	OFF	0.02	0.02
21	0.02	0.02	OFF	0.01	0.02	OFF	0.02
22	0.03	0.02	0.02	OFF	0.02	0.02	0.03
23	0.02	0.02	0.02	0.03	0.02	OFF	0.03
24	OFF	0.02	OFF	OFF	0.02	0.02	0.02
25	0.02	0.02	OFF	0.02	0.02	0.02	0.02
26	OFF	OFF	OFF	0.02	OFF	0.03	0.03
27	0.02	0.03	0.02	0.02	OFF	OFF	0.03
28	0.02	OFF	0.02	OFF	OFF	0.03	0.03
29	0.03	0.03	0.03	0.03	OFF	OFF	0.03
30	0.03	0.03	0.03	OFF	OFF	0.03	0.03

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back) ☐ Yes
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	
All turbidity readings < IFE ² triggers	Yes	
		All Cl2 residual at entry point $\geq$ 0.2 mg/l? ☐ Yes

Notes:	Printed Name: Darrel Lockard	10/6/2025
	SIGNATURE: Darrel Lockard	
	Phone# 541-505-9968	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Sep-25	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow		
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]		
1	1.31	110	144.1	22.2	7.56	22.0	yes	126		
2	1.36	110	149.6	23.4	7.59	22.0	yes	148		
3	1.36	110	149.6	22.5	7.55	22.0	yes	148		
4	1.42	110	156.2	21.8	7.55	23.0	yes	137		
5	1.45	110	159.5	21.7	7.59	23.0	yes	140		
6	1.38	110	151.8	21.0	7.59	24.0	yes	130		
7	1.40	110	154.0	21.3	7.54	23.0	yes	127		
8	1.51	110	166.1	21.8	7.59	24.0	yes	138		
9	1.41	110	155.1	21.5	7.59	24.0	yes	125		
10	1.51	110	166.1	21.5	7.55	23.0	yes	127		
11	1.47	110	161.7	21.4	7.49	23.0	yes	125		
12	1.43	110	157.3	21.1	7.52	23.0	yes	118		
13	1.43	110	157.3	21.0	7.48	23.0	yes	130		
14	1.41	110	155.1	21.3	7.48	23.0	yes	133		
15	1.43	110	157.3	21.0	7.50	23.0	yes	114		
16	1.44	110	158.4	21.0	7.52	24.0	yes	129		
17	1.48	110	162.8	21.0	7.52	24.0	yes	129		
18	1.48	110	162.8	21.3	7.49	23.0	yes	132		
19	1.34	110	147.4	20.7	7.53	24.0	yes	130		
20	1.36	110	149.6	20.5	7.53	24.0	yes	122		
21	1.39	110	152.9	20.5	7.51	24.0	yes	111		
22	1.36	110	149.6	21.0	7.51	26.0	yes	119		
23	1.37	110	149.4	21.4	7.52	26.0	yes	121		
24	1.27	110	139.7	20.5	7.56	24.0	yes	120		
25	1.28	110	140.8	20.2	7.52	24.0	yes	113		
26	1.21	110	144.1	20.6	7.51	25.0	yes	112		
27	1.36	110	149.6	20.7	7.56	25.0	yes	109		
28	1.37	110	150.7	19.7	7.53	26.0	yes	110		
29	1.40	110	154.0	19.7	7.50	25.0	yes	107		
30	1.38	110	151.8	19.3	7.51	26.0	yes	100		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX