

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Oct-25

System Name:		Georgia Pacific CPLP Wauna					ID #: OR4190416	WTP : TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	0.03	0.03	0.01	0.02	OFF	0.03	
2	OFF	0.02	0.01	0.02	OFF	OFF	0.02	
3	OFF	0.01	0.03	OFF	0.02	0.02	0.03	
4	0.01	0.01	OFF	0.01	0.02	0.02	0.02	
5	OFF	OFF	0.01	0.02	0.02	0.01	0.02	
6	OFF	0.06	0.01	0.02	OFF	OFF	0.06	
7	0.02	0.01	OFF	0.02	0.01	0.01	0.02	
8	0.02	0.02	0.02	OFF	0.01	0.02	0.02	
9	OFF	0.03	0.01	OFF	OFF	OFF	0.03	
10	0.02	0.02	OFF	0.04	0.02	0.02	0.04	
11	0.03	0.02	0.01	0.02	OFF	OFF	0.03	
12	0.01	0.02	OFF	0.03	OFF	0.02	0.03	
13	OFF	OFF	0.02	0.02	OFF	0.01	0.02	
14	OFF	0.01	0.01	0.01	OFF	OFF	0.01	
15	0.02	OFF	0.03	0.01	0.02	OFF	0.03	
16	0.03	0.01	OFF	OFF	0.02	0.01	0.03	
17	0.02	OFF	OFF	0.02	0.01	0.02	0.02	
18	OFF	0.02	0.02	0.01	OFF	0.01	0.02	
19	OFF	0.02	0.02	0.02	OFF	0.02	0.02	
20	0.02	OFF	OFF	0.02	0.02	OFF	0.02	
21	0.02	0.02	0.02	OFF	OFF	0.02	0.02	
22	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
23	0.02	0.02	0.02	OFF	0.02	OFF	0.02	
24	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
25	OFF	0.02	OFF	0.02	OFF	OFF	0.02	
26	0.01	OFF	0.02	OFF	OFF	0.02	0.02	
27	0.02	0.02	0.02	0.02	0.01	OFF	0.02	
28	0.02	0.02	0.01	0.01	0.01	0.02	0.02	
29	0.02	0.01	0.02	0.02	0.02	0.03	0.03	
30	0.02	0.01	0.02	OFF	0.02	0.02	0.02	
31	OFF	0.02	0.01	0.02	0.02	OFF	0.02	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings ≤ 0.3 NTU?	yes	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
All turbidity readings < IFE ² triggers	yes	yes

Notes:

Printed Name: Darrel Lockard

SIGNATURE: Darrel Lockard

Phone# 541-505-9968

CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: A

System Name:		Georgia Pacific CPLP Wauna					ID #: OR4190416	Month/Year:	Oct-25	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow			
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]			
1	1.45	110	159.5	19.0	7.55	27.0	yes	108			
2	1.38	110	151.8	19.0	7.55	27.0	yes	104			
3	1.36	110	149.6	18.9	7.54	27.0	yes	97			
4	1.32	110	145.2	19.2	7.54	27.0	yes	98			
5	1.35	110	148.5	19.2	7.53	27.0	yes	103			
6	1.42	110	156.2	18.2	7.57	29.0	yes	100			
7	1.44	110	158.4	17.5	7.57	30.0	yes	104			
8	1.38	110	151.8	18.3	7.51	28.0	yes	110			
9	1.38	110	151.8	17.9	7.49	29.0	yes	96			
10	1.38	110	151.8	17.5	7.48	29.0	yes	126			
11	1.33	110	146.3	17.7	7.50	29.0	yes	110			
12	1.36	110	149.6	17.2	7.53	31.0	yes	93			
13	1.36	110	149.6	16.7	7.47	31.0	yes	97			
14	1.34	110	147.4	16.5	7.60	33.0	yes	96			
15	1.41	110	155.1	16.4	7.55	33.0	yes	100			
16	1.39	110	152.9	16.2	7.59	33.0	yes	96			
17	1.39	110	152.9	16.2	7.53	32.0	yes	101			
18	1.50	110	165.0	15.8	7.59	34.0	yes	86			
19	1.49	110	163.9	15.6	7.59	35.0	yes	93			
20	1.45	110	159.5	15.5	7.56	34.0	yes	88			
21	1.50	110	165.0	15.6	7.55	34.0	yes	97			
22	1.51	110	166.1	15.7	7.58	35.0	yes	92			
23	1.46	110	160.6	15.7	7.55	35.0	yes	83			
24	1.36	110	149.6	15.4	7.59	35.0	yes	82			
25	1.37	110	150.7	15.0	7.59	36.0	yes	83			
26	1.54	110	169.4	14.7	7.56	37.0	yes	108			
27	1.47	110	161.7	14.4	7.64	38.0	yes	96			
28	1.34	110	147.4	14.5	7.51	35.0	yes	99			
29	1.37	110	150.7	14.2	7.53	36.0	yes	100			
30	1.42	110	156.2	13.8	7.51	38.0	yes	102			
31	1.43	110	157.3	13.6	7.49	38.0	yes	90			

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Revised October 2016-6 PAX