

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Nov-25

System Name:		Georgia Pacific CPLP Wauna			ID #: OR4190416		WTP : TP - A	
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	0.02	0.02	OFF	0.02	0.02	0.02	
2	0.02	OFF	0.01	0.02	0.02	OFF	0.02	
3	0.01	0.02	0.01	0.02	0.01	0.02	0.02	
4	0.01	0.02	0.02	0.01	OFF	0.02	0.02	
5	OFF	OFF	0.02	0.02	OFF	OFF	0.02	
6	0.02	0.02	0.02	OFF	0.02	0.01	0.02	
7	0.03	0.01	0.01	0.02	0.01	0.01	0.03	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.03	0.02	0.02	0.03	OFF	0.03	
10	0.04	0.01	0.02	OFF	0.02	0.02	0.04	
11	0.02	0.02	0.02	0.03	0.02	0.02	0.03	
12	0.02	0.02	0.02	OFF	0.02	0.02	0.02	
13	0.01	0.02	OFF	0.02	OFF	0.03	0.03	
14	OFF	OFF	0.02	0.02	0.02	0.02	0.02	
15	0.02	0.02	0.03	OFF	0.02	OFF	0.03	
16	OFF	OFF	0.02	0.02	0.02	0.02	0.02	
17	0.02	0.02	0.02	OFF	0.02	OFF	0.02	
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
19	0.02	0.02	OFF	0.05	0.02	OFF	0.05	
20	0.02	OFF	0.02	0.03	0.02	OFF	0.03	
21	0.02	OFF	0.02	0.02	OFF	0.02	0.02	
22	0.02	0.02	0.02	OFF	OFF	OFF	0.02	
23	OFF	OFF	OFF	OFF	0.02	OFF	0.02	
24	0.03	0.02	0.02	OFF	0.02	0.02	0.03	
25	OFF	OFF	0.03	0.02	0.02	OFF	0.03	
26	0.02	0.02	0.02	0.02	OFF	0.02	0.02	
27	0.02	OFF	OFF	OFF	OFF	0.02	0.02	
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
29	OFF	0.02	OFF	0.02	0.02	0.03	0.03	
30	0.02	OFF	0.01	OFF	OFF	OFF	0.02	
31							0.00	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back) Yes
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	
All turbidity readings < IFE ² triggers	Yes	
All Cl ₂ residual at entry point $\geq$ 0.2 mg/l? Yes		

Notes:	Printed Name: Darrel Lockard	
	SIGNATURE: Darrel Lockard	
	Phone# 541-505-9968	CERT#2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Georgia Pacific CPLP Wauna		ID #: OR4190416		Month/ Year:		Nov-25		Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow					
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]					
1	1.46	110	160.6	13.6	7.43	39.0	yes	85					
2	1.47	110	161.7	13.5	7.56	39.0	yes	91					
3	1.54	110	169.4	13.3	7.51	40.0	yes	91					
4	1.42	110	156.2	13.1	7.51	40.0	yes	93					
5	1.46	110	160.6	13.0	7.51	41.0	yes	101					
6	1.52	110	167.2	13.0	7.51	41.0	yes	105					
7	1.42	110	156.2	12.9	7.51	41.0	yes	100					
8	1.50	110	165.0	12.6	7.49	41.0	yes	94					
9	1.46	110	160.6	12.7	7.48	41.0	yes	94					
10	1.16	110	127.6	12.8	7.48	40.0	yes	100					
11	0.96	110	105.6	12.7	7.55	49.0	yes	94					
12	1.08	110	118.8	12.7	7.48	41.0	yes	91					
13	1.33	110	146.3	12.6	7.51	41.0	yes	88					
14	1.25	110	137.5	12.6	7.44	40.0	yes	90					
15	1.33	110	146.3	12.7	7.49	41.0	yes	92					
16	1.41	110	155.1	12.7	7.44	40.0	yes	91					
17	1.31	110	144.1	12.7	7.49	41.0	yes	92					
18	1.43	110	157.3	12.5	7.49	41.0	yes	89					
19	1.39	110	152.9	12.2	7.56	43.0	yes	110					
20	1.47	110	161.7	12.1	7.56	44.0	yes	95					
21	1.44	110	158.4	12.0	7.55	44.0	yes	92					
22	1.36	110	149.6	12.0	7.51	43.0	yes	90					
23	1.44	110	158.4	11.5	7.58	46.0	yes	84					
24	1.43	110	157.3	11.2	7.58	47.0	yes	85					
25	1.48	110	162.8	10.9	7.57	47.0	yes	90					
26	1.44	110	158.4	10.9	7.61	49.0	yes	89					
27	1.44	110	158.4	11.7	7.53	44.0	yes	82					
28	1.26	110	138.6	11.8	7.54	45.0	yes	86					
29	1.27	110	78.0	11.8	7.54	41.0	yes	78					
30	1.52	110	167.2	11.8	7.48	43.0	yes	79					
31													

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX