

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Dec-25

System Name:	Georgia Pacific CPLP Wauna						ID #: OR4190416	WTP: TP - A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.04	0.02	OFF	OFF	0.04	
2	0.03	0.02	0.02	0.02	OFF	OFF	0.03	
3	OFF	0.02	OFF	0.02	0.02	OFF	0.02	
4	0.02	0.04	OFF	0.02	0.03	0.02	0.04	
5	0.02	OFF	OFF	0.02	OFF	OFF	0.02	
6	OFF	OFF	OFF	0.02	0.02	OFF	0.02	
7	0.02	0.03	0.02	0.02	OFF	OFF	0.03	
8	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
9	OFF	OFF	OFF	OFF	0.01	0.06	0.06	
10	0.02	0.06	OFF	0.02	0.05	0.02	0.06	
11	0.03	0.02	OFF	0.02	OFF	0.02	0.03	
12	0.02	0.02	OFF	OFF	0.02	0.02	0.02	
13	0.03	0.02	OFF	OFF	OFF	0.02	0.03	
14	0.02	0.02	OFF	OFF	OFF	0.02	0.02	
15	OFF	0.02	OFF	OFF	OFF	OFF	0.02	
16	OFF	OFF	OFF	OFF	OFF	OFF	0.00	
17	0.04	OFF	OFF	OFF	OFF	OFF	0.04	
18	0.01	0.02	0.02	OFF	OFF	OFF	0.02	
19	0.02	0.02	0.02	0.02	OFF	OFF	0.02	
20	OFF	OFF	0.02	OFF	OFF	0.02	0.02	
21	0.03	OFF	OFF	0.14	0.07	OFF	0.14	
22	0.10	0.17	OFF	OFF	OFF	OFF	0.17	
23	OFF	OFF	0.30	OFF	0.06	0.09	0.30	
24	0.11	0.17	0.13	0.03	0.04	0.21	0.21	
25	0.06	OFF	OFF	OFF	0.06	0.02	0.06	
26	0.08	OFF	0.06	0.04	0.04	OFF	0.08	
27	OFF	OFF	OFF	OFF	0.06	OFF	0.06	
28	OFF	OFF	0.03	0.02	0.02	0.02	0.03	
29	0.02	0.02	0.02	0.06	0.02	0.03	0.06	
30	0.03	0.02	OFF	OFF	OFF	0.12	0.12	
31	0.02	OFF	OFF	0.19	0.04	OFF	0.19	

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings \leq 0.3 NTU? *yes*
 All 4-hour turbidity readings \leq 1 NTU? *yes*
 All turbidity readings < IFE² triggers? *yes*

CT's met everyday? (see back) *yes*

All Cl₂ residual at entry point \geq 0.2 mg/l? *yes*

Notes:

Printed Name: *Daniel Lockard*
 SIGNATURE: *Daniel Lockard*
 Phone: *503.505.9969* CERT#

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(c)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: A

System Name:	Georgia Pacific CPLP Wauna		ID #: OR4190416	Month/Year:	Dec-25	Disinfection Giardia Log Inactiv:	1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.47	110	161.7	11.8	7.48	44.0	yes	106
2	1.50	110	165.0	11.0	7.49	47.0	yes	85
3	1.53	110	168.3	10.8	7.63	49.0	yes	67
4	1.26	110	138.6	10.4	7.48	50.0	yes	63
5	1.47	110	161.7	10.4	7.67	51.0	yes	84
6	1.32	110	145.2	10.6	7.67	50.0	yes	75
7	1.25	110	137.5	10.9	7.66	49.0	yes	78
8	1.64	110	180.4	11.0	7.56	49.0	yes	82
9	1.41	110	155.1	11.0	7.55	48.0	yes	72
10	1.40	110	154.0	11.2	7.55	49.0	yes	78
11	1.41	110	155.3	11.0	7.40	47.0	yes	69
12	1.39	110	152.9	11.6	7.51	46.0	yes	86
13	1.55	110	170.5	11.4	7.57	46.0	yes	63
14	1.40	110	154.0	11.4	7.56	46.0	yes	62
15	1.43	110	157.3	11.4	7.53	45.0	Yes	73
16	1.53	110	168.3	11.4	7.53	46.0	yes	73
17	1.61	110	177.1	11.0	7.53	47.0	yes	81
18	1.63	110	179.3	10.5	7.55	49.0	yes	101
19	1.31	110	144.1	10.6	7.55	48.0	yes	81
20	1.37	110	155.1	10.5	7.43	49.0	yes	69
21	1.27	110	155.1	10.3	7.41	48.0	yes	74
22	1.21	110	133.1	9.8	7.43	49.0	yes	76
23	1.44	110	158.4	10.1	7.51	49.0	yes	80
24	1.48	110	162.8	10.1	7.52	50.0	yes	78
25	1.35	110	148.5	10.1	7.52	49.0	yes	77
26	1.24	110	136.4	10.1	7.52	48.0	yes	78
27	1.30	110	143.0	9.4	7.54	55.0	yes	65
28	1.39	110	152.9	9.4	7.47	57.0	yes	69
29	1.32	110	145.2	8.4	7.51	55.0	yes	78
30	1.35	110	148.5	8.3	7.58	56.0	yes	82
31	1.40	110	154.0	8.4	7.69	60.0	yes	74

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.