

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Feb-26

System Name:	Georgia Pacific CPLP Wauna						ID #: OR4190416	WTP: TP - A
Day	24:00 (NTU)	04:00 (NTU)	08:00 (NTU)	12:00 (NTU)	16:00 (NTU)	20:00 (NTU)	Highest Reading of the Day (NTU)	
1	0.01	0.02	OFF	OFF	OFF	0.02	0.02	
2	0.02	0.02	0.04	OFF	OFF	0.01	0.04	
3	0.02	OFF	0.05	0.02	0.03	OFF	0.05	
4	OFF	OFF	OFF	0.02	0.02	0.02	0.02	
5	0.02	0.05	0.02	0.02	0.03	0.02	0.05	
6	0.02	0.02	0.02	0.02	OFF	0.02	0.02	
7	OFF	0.02	0.02	0.02	OFF	0.03	0.03	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	OFF	0.02	0.02	0.02	0.02	
10	OFF	0.02	0.02	0.07	0.03	OFF	0.07	
11	0.02	0.02	0.02	OFF	0.02	OFF	0.02	
12	OFF	OFF	0.02	0.02	0.11	OFF	0.11	
13	0.03	0.02	OFF	0.02	0.02	0.02	0.03	
14	0.02	0.02	OFF	0.02	0.02	OFF	0.02	
15	0.03	0.02	0.04	OFF	OFF	0.03	0.04	
16	0.03	0.02	OFF	0.02	0.03	0.02	0.03	
17	0.02	0.03	0.04	OFF	OFF	0.03	0.04	
18	0.03	0.02	OFF	0.02	OFF	0.02	0.03	
19	0.04	OFF	0.02	OFF	0.02	0.04	0.04	
20	0.02	OFF	OFF	OFF	0.04	0.02	0.04	
21	0.03	0.02	OFF	OFF	0.04	0.02	0.04	
22	0.04	OFF	0.02	0.02	0.03	0.03	0.04	
23	0.02	0.04	0.03	OFF	OFF	0.02	0.04	
24	OFF	0.02	OFF	0.02	0.02	0.02	0.02	
25	0.02	0.02	0.02	0.15	0.02	0.04	0.15	
26	OFF	OFF	OFF	0.03	0.05	OFF	0.05	
27	0.02	0.03	0.03	0.03	0.03	0.03	0.03	
28	0.03	0.04	0.02	0.06	OFF	OFF	0.06	
29							0.00	
30							0.00	
31							0.00	

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings < 0.3 NTU? <b>yes</b>	CT's met everyday? (see book) <b>yes</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>yes</b>
All 4-hour turbidity readings ≤ 1 NTU? <b>yes</b>		
All turbidity readings < IFE <sup>2</sup> triggers <b>yes</b>		

Notes: Printed Name: David Goodrich  
 SIGNATURE: [Signature]  
 Phone: 503-966-8533 CERT# 853

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name:	Georgia Pacific CPLP Wauna						ID #: OR4190416	Month/Year:	Feb-26	Disinfection Glards Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow			
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]			
1	1.52	110	167.2	7.2	7.67	63.0	yes	75			
2	1.51	110	166.1	6.7	7.67	66.0	yes	83			
3	1.41	110	154.0	7.0	7.62	63.0	yes	78			
4	1.40	110	154.0	7.2	7.61	62.0	yes	76			
5	1.27	110	139.7	7.3	7.68	63.0	yes	79			
6	1.36	110	151.8	7.2	7.68	63.0	yes	76			
7	1.33	110	146.3	7.2	7.66	62.0	yes	72			
8	1.34	110	147.4	7.0	7.64	63.0	yes	82			
9	1.45	110	159.5	6.9	7.66	64.0	yes	78			
10	1.60	110	176.0	6.9	7.62	64.0	yes	79			
11	1.44	110	158.4	7.1	7.54	61.0	yes	78			
12	1.48	110	162.8	7.2	7.70	64.0	yes	76			
13	1.44	110	158.4	7.5	7.68	62.0	yes	74			
14	1.46	110	160.6	7.4	7.63	61.0	yes	74			
15	1.48	110	162.8	7.4	7.53	59.0	yes	73			
16	1.50	110	165.0	7.0	7.64	64.0	yes	82			
17	1.39	110	152.9	6.9	7.66	64.0	yes	78			
18	1.19	110	130.9	6.8	7.66	65.0	yes	60			
19	1.38	110	151.8	6.8	7.63	64.0	yes	89			
20	1.29	110	141.9	6.9	7.60	62.0	yes	79			
21	1.22	110	134.2	7.2	7.45	61.0	yes	80			
22	1.27	110	139.7	6.9	7.72	64.0	yes	82			
23	1.26	110	137.5	7.4	7.77	64.0	yes	94			
24	1.42	110	156.2	7.2	7.77	66.0	yes	81			
25	1.56	110	171.6	6.8	7.78	68.0	yes	80			
26	1.50	110	165.0	7.0	7.75	66.0	yes	86			
27	1.41	110	155.1	7.5	7.60	60.0	yes	85			
28	1.43	110	157.3	7.8	7.68	60.0	yes	78			
29											
30											
31											

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2016-8 PAX