

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Clatsop

Conventional or Direct Filtration

Month/Year: Mar-26

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 WTP : TP - A							
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.04	0.03	OFF	OFF	0.04
2	0.02	0.02	0.02	0.03	0.02	OFF	0.03
3	0.02	0.03	0.02	0.02	OFF	OFF	0.03
4	0.03	0.02	0.02	0.02	0.02	0.02	0.03
5	0.02	OFF	OFF	0.02	0.02	0.02	0.02
6	OFF	0.02	0.02	0.03	0.11	0.02	0.11
7	OFF	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.02	0.02	0.02	0.02	OFF	0.02
9	0.02	OFF	0.02	0.02	0.02	0.03	0.03
10	0.02	0.02	0.02	0.02	0.02	OFF	0.02
11	0.02	OFF	0.02	0.02	OFF	0.02	0.02
12	0.02	0.02	0.02	0.03	OFF	OFF	0.03
13	0.02	0.03	OFF	0.02	0.02	OFF	0.03
14	0.02	0.02	0.02	0.02	OFF	OFF	0.02
15	OFF	0.02	0.02	OFF	0.02	OFF	0.02
16	0.02	0.03	0.02	0.05	0.02	0.02	0.05
17	0.01	OFF	0.03	0.02	0.02	0.02	0.03
18	0.02	OFF	OFF	0.02	0.02	0.02	0.02
19	0.02	OFF	0.02	OFF	OFF	OFF	0.02
20	OFF	0.02	0.02	0.02	0.02	0.04	0.04
21	0.02	0.02	OFF	0.04	OFF	OFF	0.04
22	0.02	0.02	0.02	OFF	0.03	0.02	0.03
23	OFF	OFF	OFF	OFF	0.02	0.02	0.02
24	OFF	0.02	0.04	OFF	OFF	OFF	0.04
25	OFF	0.02	0.02	0.02	0.02	OFF	0.02
26	OFF	0.02	0.02	Off	0.04	0.02	0.04
27	OFF	OFF	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.03	OFF	0.02	0.04	OFF	0.04	0.04
30	0.02	0.02	0.07	0.02	0.05	OFF	0.07
31	0.02	0.03	0.02	0.05	OFF	OFF	0.05

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	No	CT's met everyday? (see back) <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
All 4-hour turbidity readings ≤ 1 NTU?	Yes	No	
All turbidity readings < IFE ² triggers	Yes	No	
Notes:		All Cl2 residual at entry point ≥ 0.2 mg/l? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Printed Name: Darrel Lockard
 SIGNATURE: Darrel Lockard
 Phone# 541-505-9968 CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Georgia Pacific CPLP Wauna ID #: OR4190416 Month/Year: Mar-26							Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.37	110	151.8	7.8	7.63	59.0	yes	73
2	1.41	110	155.1	7.9	7.67	60.0	yes	82
3	1.52	110	167.2	8.1	7.69	58.0	yes	79
4	1.46	110	160.6	8.2	7.69	60.0	yes	86
5	1.64	110	180.4	7.8	7.77	64.0	yes	80
6	1.55	110	170.5	8.0	7.77	63.0	yes	85
7	1.62	110	178.2	8.2	7.77	62.0	yes	85
8	1.52	110	167.2	8.2	7.77	63.0	yes	77
9	1.60	110	176.0	8.0	7.74	62.0	yes	82
10	1.50	110	165.0	8.4	7.68	60.0	yes	85
11	1.40	110	154.0	8.5	7.74	64.0	yes	88
12	1.43	110	157.3	8.4	7.70	60.0	yes	82
13	1.41	110	155.1	8.1	7.79	63.0	yes	82
14	1.44	110	158.1	8.1	7.79	61.0	yes	79
15	1.37	110	150.7	8.4	7.73	60.0	yes	81
16	1.44	110	158.4	8.5	7.69	58.0	yes	83
17	1.46	110	160.6	9.1	7.83	59.0	yes	101
18	1.35	110	148.5	9.3	7.65	54.0	yes	100
19	1.36	110	149.6	9.6	7.65	54.0	yes	82
20	1.40	110	154.0	10.0	7.59	51.0	yes	79
21	1.41	110	166.1	9.8	7.69	53.0	yes	78
22	1.42	110	157.3	9.7	7.71	54.0	yes	79
23	1.37	110	150.7	9.8	7.72	53.0	yes	87
24	1.33	110	146.3	9.9	7.74	55.0	yes	77
25	1.37	110	150.7	9.7	7.78	55.0	yes	81
26	1.42	110	156.2	9.7	7.79	55.0	yes	82
27	1.37	110	150.7	9.7	7.69	53.0	yes	79
28	1.32	110	145.2	10.1	7.68	51.0	yes	81
29	1.38	110	151.8	10.0	7.72	54.0	yes	82
30	1.41	110	155.1	9.5	7.68	54.0	yes	86
31	1.32	110	145.2	10.0	7.66	51.0	yes	81

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.