


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Douglas
 Month/Year: June 2023

System Name: <u>Little River Christian Camp</u>		ID#: <u>419047</u>		WTP: <u>TP - A</u>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12				0.28			0.28
13				0.26			0.26
14				0.29			0.29
15							
16							
17							
18							
19							
20							
21							
22			0.30				0.30
23			0.29				0.29
24			0.28				0.28
25			0.27				0.27
26			0.31				0.31
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? 2	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: <u>Nolan Grant</u>	
	SIGNATURE: 	7-5-2023
	PHONE #: <u>(971) 282 7666</u>	CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP:

A

Disinfection Giardia Log
Inactiv:

1.0

System Name: Little River Christian Ca ID# 41 4190476 Month/Year: June 2023

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1		110						
2		110						
3		110						
4		110						
5		110						
6		110						
7		110						
8		110						
9		110						
10		110						
11		110						
12	0.3	110	33.0	20.2	7.01	17.8	yes	
13	0.3	110	33.0	19.7	6.78	16.8	yes	
14	0.4	110	44.0	19.9	7.00	18.3	yes	
15		110						
16		110						
17		110						
18		110						
19		110						
20		110						
21		110						
22	0.3	110	33.0	19.8	6.86	17.2	yes	
23	0.4	110	44.0	19.9	6.83	17.1	yes	
24	0.3	110	33.0	20.0	6.90	17.3	yes	
25	0.3	110	33.0	19.7	7.02	18.4	yes	
26	0.4	110	44.0	19.7	6.84	17.4	yes	
27		110						
28		110						
29		110						
30		110						
31		110						

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013