


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Douglas
 Month/Year: August-2013
 WTP: TP - A

| System Name: | Little River Christian Camp | | ID#: | 41 4190476 | | | |
|--------------|-----------------------------|------------|------------|------------|------------|------------|------------------------------------|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day 1 [NTU] |
| 1 | | | | | | 0.24 | |
| 2 | | | | | | 0.32 | |
| 3 | | | | | | 0.26 | |
| 4 | | | | | | 0.25 | |
| 5 | | | | | | 0.29 | |
| 6 | | | | | | 0.32 | |
| 7 | | | | | | 0.32 | |
| 8 | | | | | | 0.34 | |
| 9 | | | | | | 0.31 | |
| 10 | | | | | | 0.31 | |
| 11 | | | | | | 0.30 | |
| 12 | | | | | | | |
| 13 | | | | | | | |
| 14 | | | | | | 0.25 | |
| 15 | | | | | | 0.25 | |
| 16 | | | | | | 0.27 | |
| 17 | | | | | | | |
| 18 | | | | | | | |
| 19 | | | | | | | |
| 20 | | | | | | | |
| 21 | | | | | | 0.32 | |
| 22 | | | | | | 0.30 | |
| 23 | | | | | | 0.28 | |
| 24 | | | | | | 0.31 | |
| 25 | | | | | | 0.29 | |
| 26 | | | | | | 0.31 | |
| 27 | | | | | | 0.30 | |
| 28 | | | | | | 0.32 | |
| 29 | | | | | | 0.32 | |
| 30 | | | | | | 0.28 | |
| 31 | | | | | | 0.30 | |

| | | | |
|----------------------------------------------------|--------------------------------------|------------------------------------------------------------------------------------------------|---------------------------------------------|
| Slow Sand/Membrane/DE Filtration/Unfiltered | | Monthly Summary (Answer Yes or No) | |
| 95% of daily turbidity readings ≤ 1 NTU? 2 | <input checked="" type="radio"/> Yes | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU? | <input checked="" type="radio"/> Yes | <input checked="" type="radio"/> Yes | <input checked="" type="radio"/> Yes |
| Notes: | | PRINTED NAME: Nolan Grant | |
| | | SIGNATURE:  | |
| | | PHONE #: (541)946-1662 | CERT #: |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Little River Christian Ca ID#: 41 4190476 Month/Year: 2021/Jun

Disinfection *Giardia* Log Inactiv: 1.0

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) 3 | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? 3 | Peak Hourly Demand Flow |
|-------------|----------------------------------------------------|------------------|-----------|-------|------|-------------|-----------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 0.4 | 110 | 44.0 | 19.3 | 5.41 | 10.4 | Yes | |
| 2 | 0.4 | 110 | 44.0 | 20.1 | 6.87 | 17.2 | yes | |
| 3 | 0.4 | 110 | 44.0 | 21.2 | 6.93 | 16.3 | yes | |
| 4 | 0.4 | 110 | 44.0 | 24.9 | 7.06 | 13.3 | yes | |
| 5 | 0.4 | 110 | 44.0 | 24.5 | 7.21 | 14.5 | yes | |
| 6 | 0.4 | 110 | 44.0 | 24.9 | 7.09 | 13.4 | yes | |
| 7 | 0.4 | 110 | 44.0 | 24.6 | 6.93 | 12.9 | yes | |
| 8 | 0.4 | 110 | 44.0 | 24.2 | 6.85 | 12.9 | yes | |
| 9 | 0.2 | 110 | 22.0 | 24.4 | 7.02 | 13.2 | yes | |
| 10 | 0.2 | 110 | 22.0 | 24.7 | 7.11 | 13.4 | yes | |
| 11 | 0.2 | 110 | 22.0 | 24.1 | 6.98 | 13.3 | yes | |
| 12 | | 110 | | | | | | |
| 13 | | 110 | | | | | | |
| 14 | 0.2 | 110 | 22.0 | 23.9 | 7.24 | 14.9 | yes | |
| 15 | 0.2 | 110 | 22.0 | 23.7 | 7.18 | 14.7 | yes | |
| 16 | 0.2 | 110 | 22.0 | 23.3 | 7.33 | 16.0 | yes | |
| 17 | | 110 | | | | | | |
| 18 | | 110 | | | | | | |
| 19 | | 110 | | | | | | |
| 20 | | 110 | | | | | | |
| 21 | 0.6 | 110 | 66.0 | 23.4 | 7.04 | 15.0 | yes | |
| 22 | 0.6 | 110 | 66.0 | 23.3 | 7.16 | 15.8 | yes | |
| 23 | 0.4 | 110 | 44.0 | 23.5 | 7.09 | 14.8 | yes | |
| 24 | 0.4 | 110 | 44.0 | 23.9 | 7.06 | 14.2 | yes | |
| 25 | 0.2 | 110 | 22.0 | 23.6 | 7.02 | 14.0 | yes | |
| 26 | 0.13 | 110 | 14.3 | 23.7 | 6.99 | 13.6 | yes | |
| 27 | 0.2 | 110 | 22.0 | 22.4 | 7.02 | 15.2 | yes | |
| 28 | 0.2 | 110 | 22.0 | 19.9 | 7.13 | 18.7 | yes | |
| 29 | 0.4 | 110 | 44.0 | 20.2 | 7.24 | 19.6 | yes | |
| 30 | 0.4 | 110 | 44.0 | 20.4 | 7.18 | 18.9 | yes | |
| 31 | 0.4 | 110 | 44.0 | 20.1 | 7.04 | 18.3 | yes | |

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013