

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Douglas
 Month/Year: September 2022
 WTP: TP - A

System Name:	Little River Christian Camp		ID#:	41 4190476		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1						0.22	
2						0.21	
3							
4							
5							
6							
7							
8						0.23	
9						0.22	
10						0.24	
11						0.25	
12						0.23	
13							
14							
15							
16							
17							
18							
19							
20						0.20	
21						0.18	
22						0.20	
23						0.20	
24							
25							
26							
27							
28						0.30	
29						0.32	
30				0.34			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? 2	<input checked="" type="radio"/> Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes	<input checked="" type="radio"/> Yes	<input checked="" type="radio"/> Yes
Notes:		PRINTED NAME: Nolan Grant	
		SIGNATURE: <i>Nolan Grant</i>	
		PHONE #: (541)946-1662	
		CERT #:	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Little River Christian Ca ID#: 41 4190476 Month/Year: September 2023 Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.43	110	47.3	19.9	6.98	18.2	Yes	
2	0.49	110	53.9	19.6	7.14	19.9	Yes	
3		110						
4		110						
5		110						
6		110						
7		110						
8	0.49	110	53.9	20.2	7.12	18.9	Yes	
9	0.47	110	51.7	20.5	7.15	18.7	Yes	
10	0.43	110	47.3	20.3	6.97	17.6	Yes	
11	0.42	110	46.2	20.6	7.02	17.6	Yes	
12	0.48	110	52.8	23.4	7.14	15.3	Yes	
13	0.76	110	83.6	23.0	6.96	15.2	Yes	
14		110						
15		110						
16		110						
17		110						
18		110						
19		110						
20	0.44	110	48.4	19.9	7.22	19.9	Yes	
21	0.31	110	34.1	19.4	7.10	19.4	Yes	
22	0.41	110	45.1	19.6	7.02	18.8	Yes	
23	0.36	110	39.6	20.9	7.06	17.4	Yes	
24		110						
25		110						
26		110						
27		110						
28	0.46	110	50.6	18.2	6.97	20.4	Yes	
29	0.39	110	42.9	18.7	7.00	19.8	Yes	
30	0.41	110	45.1	18.4	7.07	20.8	Yes	
31		110						

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013