

OHA - Drinking Water Services - Surface Water Quality Data Form



County: Josephine

Cartridge or Bag Filtration

Month/Year: Aug-22

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	27.00	21.00	6.00	15.00	0.06	0.06
2	25.00	19.00	6.00	15.00	0.06	0.06
3	25.00	18.00	7.00	15.00	0.07	0.07
4	25.00	18.00	7.00	15.00	0.09	0.09
5	26.00	18.00	8.00	15.00	0.31	0.31
6	23.00	14.00	9.00	15.00	0.10	0.10
7	23.00	13.00	10.00	15.00	0.08	0.08
8	23.00	12.00	11.00	15.00	0.06	0.06
9	25.00	14.00	11.00	15.00	0.07	0.07
10	25.00	13.00	12.00	15.00	0.09	0.09
11	29.00	16.00	13.00	15.00	0.06	0.06
12	25.00	12.00	13.00	15.00	0.06	0.06
13	25.00	11.00	14.00	15.00	0.06	0.06
14	21.00	20.00	1.00	15.00	0.07	0.07
15	10.00	9.00	1.00	15.00	0.08	0.08
16	10.00	9.00	1.00	15.00	0.09	0.09
17	8.00	7.00	1.00	15.00	0.09	0.09
18	9.00	8.00	1.00	15.00	0.12	0.12
19	9.00	7.00	2.00	15.00	0.13	0.13
20	9.00	7.00	2.00	15.00	0.09	0.09
21	9.00	7.00	2.00	15.00	0.08	0.08
22	9.00	8.00	1.00	15.00	0.04	0.04
23	9.00	8.00	1.00	15.00	0.05	0.05
24	37.00	36.00	1.00	15.00	0.10	0.10
25	23.00	21.00	2.00	15.00	0.09	0.09
26	24.00	21.00	3.00	15.00	0.10	0.10
27				15.00		level 3 fire evacuation
28				15.00		level 3 fire evacuation
29				15.00		level 3 fire evacuation
30				15.00		level 3 fire evacuation
31				15.00		level 3 fire evacuation

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	yes	Yes

<b>Notes: PSI = pounds per square inch</b> <b>PSID = pounds per square inch difference (before filter - after filter)</b> <b>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.</b>	<b>printed name: Alisha Combs</b>	
	<b>SIGNATURE: Alisha Combs</b>	<b>DATE:9/5/2022</b>
	<b>PHONE #: ( 541 ) 476-3818</b>	<b>CERT #:</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	Aug-22	Disinfection Giardia Log Inactiv:	1
--------------	---------------	---------	-------	-------------	--------	---	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	1.2	62	74.4	20.3	8.10	29.4	YES	25
2	1.2	62	74.4	20.6	8.20	29.9	YES	25
3	1.2	62	74.4	20.5	8.10	29.0	YES	25
4	1.2	62	74.4	20.3	8.10	29.4	YES	25
5	1.2	62	74.4	20.3	7.80	26.3	YES	25
6	1.2	62	74.4	20.5	7.90	26.9	YES	25
7	1.2	62	74.4	20.5	7.80	26.0	YES	25
8	1.2	62	74.4	20.7	7.90	26.6	YES	25
9	1.2	62	74.4	19.3	8.20	32.6	YES	25
10	1.2	62	74.4	18.6	8.20	34.2	YES	25
11	1.2	62	74.4	18.5	8.10	33.2	YES	25
12	1.2	62	74.4	18.4	7.90	31.0	YES	25
13	1.2	62	74.4	18.3	7.90	31.2	YES	25
14	1.2	62	74.4	18.5	7.80	29.7	YES	25
15	1.2	62	74.4	19.4	7.80	27.9	YES	25
16	1.2	62	74.4	18.8	8.20	33.7	YES	25
17	1.2	62	74.4	19.0	8.10	32.1	YES	25
18	1.2	62	74.4	19.6	8.00	29.7	YES	25
19	1.2	62	74.4	19.6	8.20	32.0	YES	25
20	1.2	62	74.4	19.5	7.90	28.8	YES	25
21	1.2	62	74.4	19.6	7.80	27.6	YES	25
22	1.2	62	74.4	19.0	8.30	34.5	YES	25
23	1.2	62	74.4	19.1	8.20	33.1	YES	25
24	1.2	62	74.4	19.2	8.10	31.7	YES	25
25	1.2	62	74.4	20.1	8.00	28.7	YES	25
26	1.2	62	74.4	20.3	8.10	29.4	YES	25
27		62						25
28		62						25
29		62						25
30		62						25
31		62						25

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

[dwp\\_dmce@state.or.us](mailto:dwp_dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350