

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: July / 2023

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	35.00	21.00	14.00	15.00	0.09	0.09
2	44.00	44.00	0.00	15.00	0.09	0.09
3	26.00	25.00	1.00	15.00	0.09	0.09
4	32.00	31.00	1.00	15.00	0.08	0.08
5	26.00	25.00	1.00	15.00	0.08	0.08
6	30.00	28.00	2.00	15.00	0.12	0.12
7	38.00	35.00	3.00	15.00	0.14	0.14
8	57.00	55.00	2.00	15.00	0.12	0.12
9	43.00	40.00	3.00	15.00	0.08	0.08
10	43.00	40.00	3.00	15.00	0.10	0.10
11	38.00	35.00	3.00	15.00	0.08	0.08
12	40.00	36.00	4.00	15.00	0.08	0.08
13	37.00	33.00	4.00	15.00	0.08	0.08
14	34.00	27.00	7.00	15.00	0.07	0.07
15	25.00	15.00	10.00	15.00	0.07	0.07
16	35.00	24.00	11.00	15.00	0.07	0.07
17	36.00	25.00	11.00	15.00	0.10	0.10
18	45.00	33.00	12.00	15.00	0.08	0.08
19	47.00	35.00	12.00	15.00	0.14	0.14
20	32.00	19.00	13.00	15.00	0.09	0.09
21	45.00	31.00	14.00	15.00	0.12	0.12
22	48.00	34.00	14.00	15.00	0.15	0.15
23	31.00	31.00	0.00	15.00	0.06	0.06
24	25.00	24.00	1.00	15.00	0.05	0.05
25	44.00	42.00	2.00	15.00	0.08	0.08
26	38.00	37.00	1.00	15.00	0.08	0.08
27	28.00	26.00	2.00	15.00	0.08	0.08
28	59.00	57.00	2.00	15.00	0.23	0.23
29	42.00	40.00	2.00	15.00	0.09	0.09
30	10.00	8.00	2.00	15.00	0.07	0.07
31	40.00	37.00	3.00	15.00	0.07	0.07

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs
 SIGNATURE: Alisha Combs DATE: 8/2/23
 PHONE #: (541) 476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	July 2023	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	------------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	18.8	8.20	33.0	YES	25
2	1.2	62	74.4	18.8	8.30	35.0	YES	25
3	1.2	62	74.4	18.2	8.20	35.1	YES	25
4	1	62	62.0	18.1	8.20	34.6	YES	25
5	1	62	62.0	18.5	8.20	33.6	YES	25
6	1	62	62.0	18.2	8.20	34.3	YES	25
7	1	62	62.0	18.5	8.20	33.6	YES	25
8	1	62	62.0	17.9	8.30	36.3	YES	25
9	1.2	62	74.4	17.9	8.30	37.2	YES	25
10	1	62	62.0	18.1	8.40	37.2	YES	25
11	1	62	62.0	18.6	8.20	33.4	YES	25
12	1.2	62	74.4	18.3	8.10	33.6	YES	25
13	1.2	62	74.4	18.3	8.20	34.9	YES	25
14	1	62	62.0	18.2	8.10	33.1	YES	25
15	1	62	62.0	18.6	8.10	32.2	YES	25
16	1	62	62.0	19.1	8.40	34.8	YES	25
17	1.2	62	74.4	18.3	8.00	32.4	YES	25
18	1	62	62.0	18.3	8.00	31.7	YES	25
19	1.2	62	74.4	18.9	8.20	33.5	YES	25
20	1	62	62.0	18.9	8.10	31.6	YES	25
21	1	62	62.0	19.1	8.20	32.3	YES	25
22	1	62	62.0	18.5	8.10	32.4	YES	25
23	1	62	62.0	20.6	8.00	27.2	YES	25
24	1	62	62.0	19.3	8.00	29.6	YES	25
25	1.2	62	74.4	18.7	8.10	32.7	YES	25
26	1.2	62	74.4	18.6	8.00	31.8	YES	25
27	1	62	62.0	19.0	8.10	31.4	YES	25
28	1.2	62	74.4	19.2	8.10	31.7	YES	25
29	1.2	62	74.4	18.0	8.10	34.3	YES	25
30	1.2	62	74.4	18.5	8.20	34.4	YES	25
31	1	62	62.0	18.3	8.10	32.9	YES	25

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dup.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350