

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: 8/2023

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	40.00	36.00	4.00	15.00	0.17	0.17
2	46.00	42.00	4.00	15.00	0.09	0.09
3	37.00	34.00	3.00	15.00	0.07	0.07
4	44.00	40.00	4.00	15.00	0.08	0.08
5	44.00	40.00	4.00	15.00	0.08	0.08
6	31.00	27.00	4.00	15.00	0.10	0.10
7	47.00	39.00	8.00	15.00	0.09	0.09
8	40.00	30.00	10.00	15.00	0.08	0.08
9	57.00	47.00	10.00	15.00	0.10	0.10
10	40.00	30.00	10.00	15.00	0.10	0.10
11	32.00	19.00	13.00	15.00	0.10	0.10
12	42.00	29.00	13.00	15.00	0.10	0.10
13	41.00	27.00	14.00	15.00	0.15	0.15
14	42.00	28.00	14.00	15.00	0.10	0.10
15	34.00	19.00	15.00	15.00	0.10	0.10
16	59.00	58.00	1.00	15.00	0.09	0.09
17	59.00	58.00	1.00	15.00	0.09	0.09
18	59.00	58.00	1.00	15.00	0.13	0.13
19	40.00	38.00	2.00	15.00	0.18	0.18
20	18.00	16.00	2.00	15.00	0.23	0.23
21	27.00	25.00	2.00	15.00	0.08	0.08
22	35.00	33.00	2.00	15.00	0.09	0.09
23	22.00	20.00	2.00	15.00	0.08	0.08
24	35.00	32.00	3.00	15.00	0.08	0.08
25	57.00	54.00	3.00	15.00	0.20	0.20
26	40.00	36.00	4.00	15.00	0.09	0.09
27	34.00	30.00	4.00	15.00	0.09	0.09
28	41.00	37.00	4.00	15.00	0.10	0.10
29	39.00	35.00	4.00	15.00	0.09	0.09
30	34.00	30.00	4.00	15.00	0.09	0.09
31	35.00	31.00	4.00	15.00	0.13	0.13

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 5 NTU? Yes / No		

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME:	
SIGNATURE:	DATE:
PHONE #: ()	CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	8/2023	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	---------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	18.7	8.30	34.4	YES	25
2	1	62	62.0	18.8	8.20	33.0	YES	25
3	1.2	62	74.4	18.8	8.30	35.0	YES	25
4	1	62	62.0	18.7	8.20	33.2	YES	25
5	1.2	62	74.4	18.9	8.10	32.3	YES	25
6	1	62	62.0	19.3	8.20	31.9	YES	25
7	1	62	62.0	19.2	8.30	33.3	YES	25
8	1.2	62	74.4	19.1	8.00	30.7	YES	25
9	1.2	62	74.4	19.2	8.20	32.9	YES	25
10	0.8	62	49.6	19.3	8.30	32.4	YES	25
11	1	62	62.0	19.6	8.30	32.4	YES	25
12	1	62	62.0	19.8	8.30	32.0	YES	25
13	1.2	62	74.4	19.7	8.40	34.2	YES	25
14	1.2	62	74.4	20.8	7.90	26.4	YES	25
15	1	62	62.0	21.2	8.20	28.1	YES	25
16	1.2	62	74.4	22.0	8.30	28.3	YES	25
17	1.2	62	74.4	22.8	8.20	25.8	YES	25
18	1	62	62.0	23.3	8.30	25.3	YES	25
19	1.2	62	74.4	24.0	8.10	23.0	YES	25
20	1.2	62	74.4	19.8	8.20	31.6	YES	25
21	1.2	62	74.4	19.7	8.20	31.8	YES	25
22	1	62	62.0	18.3	8.30	35.4	YES	25
23	1	62	62.0	17.8	8.30	36.6	YES	25
24	1.2	62	74.4	18.5	8.40	37.1	YES	25
25	1.2	62	74.4	18.6	8.30	35.5	YES	25
26	1.2	62	74.4	19.0	8.30	34.5	YES	25
27	1	62	62.0	18.5	8.30	34.9	YES	25
28	1.2	62	74.4	19.0	8.40	35.8	YES	25
29	1	62	62.0	18.9	8.20	32.8	YES	25
30	1	62	62.0	18.3	8.30	35.4	YES	25
31	1	62	62.0	18.7	8.20	33.2	YES	25

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dup.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350