

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Sept/2023

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	43.00	38.00	5.00	15.00	0.09	0.09
2	40.00	34.00	6.00	15.00	0.08	0.08
3	39.00	33.00	6.00	15.00	0.09	0.09
4	38.00	31.00	7.00	15.00	0.08	0.08
5	39.00	31.00	8.00	15.00	0.09	0.09
6	33.00	25.00	8.00	15.00	0.08	0.08
7	45.00	36.00	9.00	15.00	0.11	0.11
8	40.00	31.00	9.00	15.00	0.08	0.08
9	35.00	25.00	10.00	15.00	0.08	0.08
10	37.00	27.00	10.00	15.00	0.08	0.08
11	26.00	15.00	11.00	15.00	0.10	0.10
12	38.00	26.00	12.00	15.00	0.08	0.08
13	30.00	17.00	13.00	15.00	0.08	0.08
14	35.00	21.00	14.00	15.00	0.09	0.09
15	50.00	49.00	1.00	15.00	0.09	0.09
16	42.00	41.00	1.00	15.00	0.10	0.10
17	59.00	58.00	1.00	15.00	0.10	0.10
18	48.00	47.00	1.00	15.00	0.10	0.10
19	44.00	42.00	2.00	15.00	0.11	0.11
20	44.00	42.00	2.00	15.00	0.11	0.11
21	47.00	45.00	2.00	15.00	0.19	0.19
22	36.00	34.00	2.00	15.00	0.10	0.10
23	28.00	26.00	2.00	15.00	0.06	0.06
24	40.00	38.00	2.00	15.00	0.08	0.08
25	40.00	38.00	2.00	15.00	0.16	0.16
26	36.00	34.00	2.00	15.00	0.04	0.04
27	35.00	33.00	2.00	15.00	0.04	0.04
28	45.00	43.00	2.00	15.00	0.08	0.08
29	40.00	37.00	3.00	15.00	0.08	0.08
30	40.00	37.00	3.00	15.00	0.07	0.07
31				15.00		

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs  
 SIGNATURE: Alisha Combs DATE: 10/2/2023  
 PHONE #: ( 541 ) 476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

<b>System Name:</b>	<b>Galice Resort</b>	<b>ID#: 41</b>	<b>90808</b>	<b>Month/Year:</b>	<b>Sept/2023</b>	<b>Disinfection <i>Giardia</i> Log Inactiv:</b>	<b>1</b>
---------------------	----------------------	----------------	--------------	--------------------	------------------	---	----------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	18.2	8.30	35.6	YES	25
2	1.2	62	74.4	18.0	8.40	38.3	YES	25
3	1	62	62.0	17.2	8.30	38.1	YES	25
4	1	62	62.0	17.4	8.30	37.6	YES	25
5	1	62	62.0	16.6	8.30	39.6	YES	25
6	1	62	62.0	17.9	8.40	37.7	YES	25
7	1	62	62.0	17.1	8.30	38.3	YES	25
8	1.2	62	74.4	16.8	8.40	41.5	YES	25
9	1	62	62.0	16.7	8.30	39.3	YES	25
10	1	62	62.0	17.5	8.30	37.3	YES	25
11	1	62	62.0	17.7	8.40	38.2	YES	25
12	1	62	62.0	17.7	8.00	33.0	YES	25
13	1.2	62	74.4	17.0	8.30	39.5	YES	25
14	1	62	62.0	17.2	8.40	39.5	YES	25
15	1	62	62.0	18.7	8.40	35.7	YES	25
16	1	62	62.0	19.4	8.40	34.1	YES	25
17	1.2	62	74.4	17.9	8.30	37.2	YES	25
18	1	62	62.0	18.4	8.40	36.5	YES	25
19	1	62	62.0	17.0	8.20	37.2	YES	25
20	1	62	62.0	16.4	8.20	38.7	YES	25
21	1.2	62	74.4	16.8	8.30	40.0	YES	25
22	1	62	62.0	14.5	8.50	49.0	YES	25
23	1	62	62.0	14.7	8.40	46.6	YES	25
24	1.2	62	74.4	15.1	8.40	46.4	YES	25
25	1	62	62.0	15.1	8.30	43.7	YES	25
26	1.2	62	74.4	15.6	8.30	43.3	YES	25
27	1	62	62.0	14.8	8.40	46.3	YES	25
28	1	62	62.0	14.0	8.30	47.1	YES	25
29	1.2	62	74.4	14.7	8.40	47.7	YES	25
30	1	62	62.0	14.6	8.40	46.9	YES	25
31		62						25

2 If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

[dup.dmce@oha.oregon.gov](mailto:dup.dmce@oha.oregon.gov); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350