

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: 11/23

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	47.00	42.00	5.00	15.00	0.09	0.09
2	43.00	38.00	5.00	15.00	0.09	0.09
3	45.00	40.00	5.00	15.00	0.09	0.09
4	30.00	25.00	5.00	15.00	0.10	0.10
5	48.00	43.00	5.00	15.00	0.09	0.09
6	45.00	40.00	5.00	15.00	0.10	0.10
7	44.00	39.00	5.00	15.00	0.10	0.10
8	51.00	46.00	5.00	15.00	0.09	0.09
9	48.00	43.00	5.00	15.00	0.09	0.09
10	42.00	37.00	5.00	15.00	0.09	0.09
11	55.00	50.00	5.00	15.00	0.09	0.09
12	45.00	40.00	5.00	15.00	0.10	0.10
13	54.00	49.00	5.00	15.00	0.09	0.09
14	41.00	36.00	5.00	15.00	0.08	0.08
15	55.00	50.00	5.00	15.00	0.08	0.08
16	41.00	36.00	5.00	15.00	0.08	0.08
17	41.00	36.00	5.00	15.00	0.09	0.09
18	47.00	42.00	5.00	15.00	0.08	0.08
19	48.00	43.00	5.00	15.00	0.08	0.08
20	50.00	45.00	5.00	15.00	0.09	0.09
21	49.00	43.00	6.00	15.00	0.09	0.09
22	50.00	45.00	5.00	15.00	0.09	0.09
23	50.00	45.00	5.00	15.00	0.09	0.09
24	50.00	45.00	5.00	15.00	0.09	0.09
25	30.00	25.00	5.00	15.00	0.08	0.08
26	39.00	33.00	6.00	15.00	0.09	0.09
27	50.00	44.00	6.00	15.00	0.09	0.09
28	47.00	41.00	6.00	15.00	0.09	0.09
29	46.00	40.00	6.00	15.00	0.09	0.09
30	55.00	49.00	6.00	15.00	0.09	0.09
31				15.00		

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) Yes
All daily turbidity readings ≤ 5 NTU? Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs
 SIGNATURE: Alisha Combs DATE: 12/01/23
 PHONE #: (541)476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	11/23	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	--------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	11.5	8.10	51.5	YES	25
2	1.2	62	74.4	12.3	8.10	49.9	YES	25
3	1	62	62.0	12.8	8.00	45.6	YES	25
4	1	62	62.0	13.5	8.10	45.2	YES	25
5	1	62	62.0	13.6	8.00	43.3	YES	25
6	1	62	62.0	13.1	8.10	46.4	YES	25
7	1.2	62	74.4	12.4	8.20	51.4	YES	25
8	1.2	62	74.4	11.8	8.20	53.5	YES	25
9	1	62	62.0	10.7	8.20	56.3	YES	25
10	1	62	62.0	10.6	8.10	54.7	YES	25
11	1	62	62.0	11.1	8.10	52.9	YES	25
12	1.2	62	74.4	11.1	8.10	54.1	YES	25
13	1.2	62	74.4	11.4	8.10	53.0	YES	25
14	1	62	62.0	11.8	8.10	50.4	YES	25
15	1	62	62.0	11.9	8.10	50.1	YES	25
16	1.2	62	74.4	11.9	8.00	49.5	YES	25
17	1	62	62.0	11.7	8.00	49.0	YES	25
18	1	62	62.0	11.4	8.00	50.0	YES	25
19	1	62	62.0	10.8	8.00	52.1	YES	25
20	1	62	62.0	10.0	8.00	54.9	YES	25
21	1	62	62.0	9.6	7.90	54.4	YES	25
22	1.2	62	74.4	9.7	7.90	55.3	YES	25
23	1.2	62	74.4	10.4	7.90	52.8	YES	25
24	1.2	62	74.4	9.2	7.90	57.2	YES	25
25	1	62	62.0	8.0	7.90	60.7	YES	25
26	1.2	62	74.4	7.5	7.90	64.2	YES	25
27	1.2	62	74.4	7.3	7.90	65.1	YES	25
28	1	62	62.0	7.7	7.90	61.9	YES	25
29	1.2	62	74.4	7.6	8.00	66.2	YES	25
30	1.2	62	74.4	7.8	8.00	65.3	YES	25
31		62						25

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dpw.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350