

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: 12/2023

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	42.00	36.00	6.00	15.00	0.09	0.09
2	40.00	34.00	6.00	15.00	0.09	0.09
3	41.00	35.00	6.00	15.00	0.09	0.09
4	41.00	35.00	6.00	15.00	0.10	0.10
5	44.00	38.00	6.00	15.00	0.09	0.09
6	44.00	37.00	7.00	15.00	0.09	0.09
7	34.00	27.00	7.00	15.00	0.10	0.10
8	44.00	37.00	7.00	15.00	0.09	0.09
9	41.00	34.00	7.00	15.00	0.09	0.09
10	41.00	34.00	7.00	15.00	0.10	0.10
11	45.00	37.00	8.00	15.00	0.11	0.11
12	49.00	41.00	8.00	15.00	0.12	0.12
13	42.00	34.00	8.00	15.00	0.13	0.13
14	34.00	26.00	8.00	15.00	0.12	0.12
15	34.00	26.00	8.00	15.00	0.13	0.13
16	40.00	32.00	8.00	15.00	0.12	0.12
17	42.00	33.00	9.00	15.00	0.12	0.12
18	45.00	36.00	9.00	15.00	0.13	0.13
19	42.00	33.00	9.00	15.00	0.13	0.13
20	41.00	32.00	9.00	15.00	0.10	0.10
21	45.00	36.00	9.00	15.00	0.10	0.10
22	42.00	32.00	10.00	15.00	0.10	0.10
23	34.00	23.00	11.00	15.00	0.10	0.10
24	33.00	20.00	13.00	15.00	0.12	0.12
25	34.00	19.00	15.00	15.00	0.12	0.12
26	44.00	43.00	1.00	15.00	0.12	0.12
27	62.00	61.00	1.00	15.00	0.12	0.12
28	62.00	61.00	1.00	15.00	0.13	0.13
29	46.00	45.00	1.00	15.00	0.22	0.22
30	46.00	45.00	1.00	15.00	0.30	0.30
31	47.00	45.00	2.00	15.00	0.22	0.22

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) Yes
All daily turbidity readings ≤ 5 NTU? Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs
 SIGNATURE: Alisha Combs DATE: 1/3/24
 PHONE #: (541)476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	12/2023	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	----------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	8.3	7.90	59.4	YES	25
2	1	62	62.0	9.1	8.00	58.4	YES	25
3	1	62	62.0	9.5	8.10	58.9	YES	25
4	1.2	62	74.4	10.1	8.00	55.8	YES	25
5	1	62	62.0	12.9	8.10	47.0	YES	25
6	1	62	62.0	11.3	8.00	50.3	YES	25
7	1	62	62.0	10.0	7.90	53.0	YES	25
8	1	62	62.0	10.1	7.90	52.6	YES	25
9	1	62	62.0	8.7	7.90	57.8	YES	25
10	1.2	62	74.4	8.3	7.80	58.7	YES	25
11	1	62	62.0	9.3	7.80	53.6	YES	25
12	1	62	62.0	9.9	7.70	49.7	YES	25
13	1.2	62	74.4	9.0	7.80	56.0	YES	25
14	1.2	62	74.4	9.2	7.80	55.2	YES	25
15	1	62	62.0	8.6	7.80	56.2	YES	25
16	1	62	62.0	7.8	7.80	59.3	YES	25
17	1	62	62.0	7.6	7.70	58.0	YES	25
18	1	62	62.0	8.2	7.80	57.7	YES	25
19	1.2	62	74.4	9.3	7.70	52.9	YES	25
20	1	62	62.0	9.6	7.70	50.7	YES	25
21	1	62	62.0	9.4	7.70	51.4	YES	25
22	1.2	62	74.4	9.3	7.70	52.9	YES	25
23	1.2	62	74.4	8.1	7.70	57.4	YES	25
24	1	62	62.0	8.2	7.70	55.7	YES	25
25	1	62	62.0	8.4	7.70	54.9	YES	25
26	1.2	62	74.4	9.0	7.70	54.0	YES	25
27	1.2	62	74.4	8.9	7.70	54.4	YES	25
28	1	62	62.0	9.3	7.70	51.7	YES	25
29	1	62	62.0	9.5	7.70	51.0	YES	25
30	1	62	62.0	9.9	7.60	47.9	YES	25
31	1.2	62	74.4	9.1	7.70	53.6	YES	25

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350