

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Jan/2024

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	43.00	41.00	2.00	15.00	0.22	0.22
2	62.00	60.00	2.00	15.00	0.29	0.29
3	45.00	43.00	2.00	15.00	0.29	0.29
4	45.00	43.00	2.00	15.00	0.22	0.22
5	47.00	45.00	2.00	15.00	0.22	0.22
6	63.00	61.00	2.00	15.00	0.22	0.22
7	45.00	43.00	2.00	15.00	0.23	0.23
8	48.00	46.00	2.00	15.00	0.22	0.22
9	47.00	45.00	2.00	15.00	0.20	0.20
10	47.00	42.00	5.00	15.00	0.19	0.19
11	47.00	41.00	6.00	15.00	0.24	0.24
12	47.00	40.00	7.00	15.00	0.23	0.23
13	48.00	41.00	7.00	15.00	0.22	0.22
14	48.00	40.00	8.00	15.00	0.22	0.22
15	50.00	41.00	9.00	15.00	0.22	0.22
16	50.00	40.00	10.00	15.00	0.26	0.26
17	45.00	33.00	12.00	15.00	0.22	0.22
18	43.00	29.00	14.00	15.00	0.22	0.22
19	45.00	44.00	1.00	15.00	0.20	0.20
20	44.00	43.00	1.00	15.00	0.19	0.19
21	44.00	43.00	1.00	15.00	0.20	0.20
22	43.00	42.00	1.00	15.00	0.20	0.20
23	51.00	50.00	1.00	15.00	0.20	0.20
24	51.00	49.00	2.00	15.00	0.29	0.29
25	44.00	42.00	2.00	15.00	0.29	0.29
26	46.00	44.00	2.00	15.00	0.26	0.26
27	46.00	43.00	3.00	15.00	0.25	0.25
28	54.00	51.00	3.00	15.00	0.25	0.25
29	54.00	51.00	3.00	15.00	0.25	0.25
30	51.00	48.00	3.00	15.00	0.26	0.26
31	51.00	48.00	3.00	15.00	0.25	0.25

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs
 SIGNATURE: Alisha Combs DATE: 02/01/24
 PHONE #: (541) 476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	Jan/2024	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	-----------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	9.5	7.70	51.0	YES	25
2	1.2	62	74.4	9.2	7.70	53.3	YES	25
3	1	62	62.0	9.1	7.60	50.6	YES	25
4	1.2	62	74.4	9.0	7.60	52.1	YES	25
5	1.2	62	74.4	8.8	7.60	52.8	YES	25
6	1	62	62.0	8.2	7.60	53.7	YES	25
7	1.2	62	74.4	7.3	7.60	58.4	YES	25
8	1	62	62.0	7.7	7.50	53.6	YES	25
9	1	62	62.0	8.0	7.60	54.4	YES	25
10	1	62	62.0	7.6	7.50	54.0	YES	25
11	1.2	62	74.4	7.0	7.50	57.5	YES	25
12	1.2	62	74.4	7.7	7.50	54.8	YES	25
13	1	62	62.0	7.6	7.60	55.9	YES	25
14	1	62	62.0	8.5	7.60	52.6	YES	25
15	1.2	62	74.4	8.4	7.50	52.3	YES	25
16	1	62	62.0	7.9	7.50	52.9	YES	25
17	1	62	62.0	8.5	7.50	50.8	YES	25
18	1	62	62.0	9.1	7.40	47.1	YES	25
19	1.2	62	74.4	9.2	7.40	47.9	YES	25
20	1	62	62.0	9.3	7.50	48.2	YES	25
21	1	62	62.0	9.5	7.50	47.5	YES	25
22	1.2	62	74.4	9.8	7.50	47.7	YES	25
23	1.2	62	74.4	10.1	7.50	46.7	YES	25
24	1	62	62.0	10.3	7.50	45.1	YES	25
25	1.2	62	74.4	9.8	7.50	47.7	YES	25
26	1.2	62	74.4	9.9	7.50	47.3	YES	25
27	1	62	62.0	10.4	7.50	44.8	YES	25
28	1.2	62	74.4	11.3	7.40	41.7	YES	25
29	1.2	62	74.4	11.3	7.40	41.7	YES	25
30	1	62	62.0	11.2	7.40	41.0	YES	25
31	1	62	62.0	11.5	7.50	41.6	YES	25

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dlw.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350