

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Feb 2024

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	49.00	45.00	4.00	15.00	0.30	0.30
2	46.00	41.00	5.00	15.00	0.21	0.21
3	49.00	44.00	5.00	15.00	0.18	0.18
4	51.00	44.00	7.00	15.00	0.14	0.14
5	49.00	41.00	8.00	15.00	0.19	0.19
6	60.00	51.00	9.00	15.00	0.17	0.17
7	51.00	42.00	9.00	15.00	0.17	0.17
8	52.00	42.00	10.00	15.00	0.17	0.17
9	52.00	42.00	10.00	15.00	0.18	0.18
10	51.00	41.00	10.00	15.00	0.16	0.16
11	52.00	41.00	11.00	15.00	0.15	0.15
12	51.00	40.00	11.00	15.00	0.15	0.15
13	52.00	41.00	11.00	15.00	0.14	0.14
14	47.00	35.00	12.00	15.00	0.18	0.18
15	48.00	36.00	12.00	15.00	0.19	0.19
16	49.00	37.00	12.00	15.00	0.18	0.18
17	49.00	37.00	12.00	15.00	0.18	0.18
18	50.00	37.00	13.00	15.00	0.14	0.14
19	51.00	38.00	13.00	15.00	0.14	0.14
20	49.00	36.00	13.00	15.00	0.14	0.14
21	50.00	37.00	13.00	15.00	0.16	0.16
22	51.00	37.00	14.00	15.00	0.16	0.16
23	52.00	38.00	14.00	15.00	0.17	0.17
24	51.00	37.00	14.00	15.00	0.17	0.17
25	51.00	37.00	14.00	15.00	0.17	0.17
26	52.00	37.00	15.00	15.00	0.19	0.19
27	62.00	62.00	0.00	15.00	0.18	0.18
28	59.00	58.00	1.00	15.00	0.15	0.15
29	59.00	58.00	1.00	15.00	0.13	0.13
30				15.00		
31				15.00		

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs
 SIGNATURE: Alisha Combs DATE: 03/01/24
 PHONE #: (541) 476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	Feb/2024	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	-----------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	62	74.4	10.7	7.40	43.3	YES	25
2	1	62	62.0	10.5	7.40	42.9	YES	25
3	1	62	62.0	9.4	7.40	46.2	YES	25
4	1	62	62.0	8.7	7.50	50.1	YES	25
5	1.2	62	74.4	8.5	7.40	50.2	YES	25
6	1.2	62	74.4	9.3	7.40	47.5	YES	25
7	1	62	62.0	8.8	7.40	48.1	YES	25
8	1.2	62	74.4	8.8	7.40	49.2	YES	25
9	1.2	62	74.4	8.2	7.30	49.4	YES	25
10	1	62	62.0	8.9	7.30	46.1	YES	25
11	1	62	62.0	8.9	7.40	47.7	YES	25
12	1	62	62.0	9.2	7.30	45.2	YES	25
13	1	62	62.0	9.1	7.30	45.5	YES	25
14	1.2	62	74.4	9.0	7.30	46.8	YES	25
15	1	62	62.0	9.1	7.40	47.1	YES	25
16	1	62	62.0	9.3	7.30	44.9	YES	25
17	1	62	62.0	9.5	7.30	44.3	YES	25
18	1	62	62.0	9.6	7.40	45.6	YES	25
19	1	62	62.0	9.8	7.40	45.0	YES	25
20	1.2	62	74.4	9.6	7.30	45.0	YES	25
21	1	62	62.0	9.7	7.20	42.2	YES	25
22	1.2	62	74.4	9.5	7.20	43.7	YES	25
23	1.2	62	74.4	9.6	7.10	41.9	YES	25
24	1	62	62.0	9.8	7.20	41.9	YES	25
25	1.2	62	74.4	9.4	7.20	44.0	YES	25
26	1	62	62.0	9.2	7.20	43.6	YES	25
27	1.2	62	74.4	8.6	7.10	44.8	YES	25
28	1	62	62.0	8.5	7.20	45.7	YES	25
29	1	62	62.0	9.0	7.20	44.2	YES	25
30		62						25
31		62						25

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dpw.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350