

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: 3/2024

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	62.00	61.00	1.00	15.00	0.14	0.14
2	52.00	51.00	1.00	15.00	0.14	0.14
3	50.00	49.00	1.00	15.00	0.14	0.14
4	50.00	49.00	1.00	15.00	0.12	0.12
5	49.00	48.00	1.00	15.00	0.12	0.12
6	51.00	50.00	1.00	15.00	0.14	0.14
7	51.00	50.00	1.00	15.00	0.12	0.12
8	62.00	61.00	1.00	15.00	0.13	0.13
9	62.00	61.00	1.00	15.00	0.12	0.12
10	50.00	49.00	1.00	15.00	0.16	0.16
11	61.00	60.00	1.00	15.00	0.15	0.15
12	50.00	48.00	2.00	15.00	0.19	0.19
13	50.00	48.00	2.00	15.00	0.17	0.17
14	50.00	48.00	2.00	15.00	0.11	0.11
15	54.00	52.00	2.00	15.00	0.24	0.24
16	51.00	49.00	2.00	15.00	0.29	0.29
17	52.00	50.00	2.00	15.00	0.25	0.25
18	51.00	49.00	2.00	15.00	0.21	0.21
19	51.00	49.00	2.00	15.00	0.30	0.30
20	61.00	60.00	1.00	15.00	0.34	0.34
21	59.00	57.00	2.00	15.00	0.34	0.34
22	50.00	48.00	2.00	15.00	0.34	0.34
23	50.00	48.00	2.00	15.00	0.18	0.18
24	48.00	46.00	2.00	15.00	0.34	0.34
25	59.00	57.00	2.00	15.00	0.29	0.29
26	60.00	58.00	2.00	15.00	0.23	0.23
27	60.00	58.00	2.00	15.00	0.22	0.22
28	58.00	56.00	2.00	15.00	0.30	0.30
29	58.00	56.00	2.00	15.00	0.31	0.31
30	46.00	44.00	2.00	15.00	0.29	0.29
31	45.00	43.00	2.00	15.00	0.21	0.21

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Alisha Combs  
 SIGNATURE: Alisha Combs DATE: 4/1/2024  
 PHONE #: ( 541 )476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

<b>System Name:</b>	<b>Galice Resort</b>	<b>ID#: 41</b>	<b>90808</b>	<b>Month/Year:</b>	<b>3/2024</b>	<b>Disinfection <i>Giardia</i> Log Inactiv:</b>	<b>1</b>
---------------------	----------------------	----------------	--------------	--------------------	---------------	-------------------------------------------------	----------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	62	62.0	7.9	7.20	47.5	YES	25
2	1	62	62.0	7.6	7.10	46.8	YES	25
3	1	62	62.0	7.3	7.10	47.7	YES	25
4	1.2	62	74.4	7.1	7.20	51.3	YES	25
5	1.2	62	74.4	6.6	7.20	53.0	YES	25
6	1.2	62	74.4	6.8	7.10	50.5	YES	25
7	1	62	62.0	6.5	7.20	52.2	YES	25
8	1.2	62	74.4	6.8	7.20	52.3	YES	25
9	1	62	62.0	7.0	7.20	50.5	YES	25
10	1	62	62.0	7.1	7.10	48.4	YES	25
11	1	62	62.0	7.5	7.10	47.1	YES	25
12	1.2	62	74.4	7.4	7.10	48.5	YES	25
13	1	62	62.0	7.5	7.10	47.1	YES	25
14	1	62	62.0	7.7	7.10	46.5	YES	25
15	1	62	62.0	7.5	7.10	47.1	YES	25
16	1	62	62.0	8.2	7.20	46.6	YES	25
17	1	62	62.0	8.4	7.20	46.0	YES	25
18	1	62	62.0	8.8	7.10	43.2	YES	25
19	1	62	62.0	9.3	7.10	41.8	YES	25
20	1	62	62.0	9.3	7.10	41.8	YES	25
21	1	62	62.0	8.9	7.30	46.1	YES	25
22	1	62	62.0	10.0	7.30	42.8	YES	25
23	1	62	62.0	10.2	7.20	40.8	YES	25
24	1	62	62.0	9.2	7.30	45.2	YES	25
25	1	62	62.0	9.5	7.30	44.3	YES	25
26	1.2	62	74.4	9.4	7.30	45.6	YES	25
27	1.2	62	74.4	8.8	7.20	45.8	YES	25
28	1	62	62.0	8.7	7.30	46.7	YES	25
29	1	62	62.0	8.8	7.20	44.8	YES	25
30	1	62	62.0	8.2	7.30	48.3	YES	25
31	1	62	62.0	9.7	7.20	42.2	YES	25

2 If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

[dpw.dmce@oha.oregon.gov](mailto:dpw.dmce@oha.oregon.gov); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350