

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: November/2024

System Name:		Galice Resort		ID#:	41	90808	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]		
1	60.00	60.00	0.00	25.00	0.13	0.13		
2	16.00	15.00	1.00	25.00	0.15	0.15		
3	62.00	62.00	0.00	25.00	0.15	0.15		
4	46.00	44.00	2.00	25.00	0.11	0.11		
5	62.00	62.00	0.00	25.00	0.12	0.12		
6	60.00	61.00	-1.00	25.00	0.10	0.10		
7	61.00	61.00	0.00	25.00	0.10	0.10		
8	61.00	61.00	0.00	25.00	0.11	0.11		
9	45.00	45.00	0.00	25.00	0.10	0.10		
10	45.00	45.00	0.00	25.00	0.11	0.11		
11	48.00	45.00	3.00	25.00	0.12	0.12		
12	45.00	45.00	0.00	25.00	0.10	0.10		
13	63.00	63.00	0.00	25.00	0.12	0.12		
14	59.00	59.00	0.00	25.00	0.13	0.13		
15	61.00	61.00	0.00	25.00	0.12	0.12		
16	61.00	61.00	0.00	25.00	0.11	0.11		
17	59.00	59.00	0.00	25.00	0.13	0.13		
18	61.00	61.00	0.00	25.00	0.13	0.13		
19	61.00	61.00	0.00	25.00	0.13	0.13		
20	61.00	61.00	0.00	25.00	0.14	0.14		
21	61.00	61.00	0.00	25.00	0.15	0.15		
22	61.00	61.00	0.00	25.00	0.11	0.11		
23	61.00	61.00	0.00	25.00	0.11	0.11		
24	61.00	61.00	0.00	25.00	0.10	0.10		
25	60.00	61.00	-1.00	25.00	0.10	0.10		
26	59.00	59.00	0.00	25.00	0.13	0.13		
27	61.00	62.00	-1.00	25.00	0.13	0.13		
28	54.00	55.00	-1.00	25.00	0.14	0.14		
29	55.00	56.00	-1.00	25.00	0.14	0.14		
30	52.00	51.00	1.00	25.00	0.15	0.15		
31				25.00				
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU?					Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?					Yes	Yes		Yes
Notes: PSI = pounds per square inch					PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: Kurt Swanson			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					DATE: 12/1/2024			
					PHONE #: (541)476-3818			
					CERT #:			

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :

System Name:	Galice Resort	ID#: 41	90808	Month/Year:	12/2024	Disinfection <i>Giardia</i> Log Inactiv:	1
---------------------	----------------------	----------------	--------------	--------------------	----------------	---	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	115	115.0	13.0	8.20	48.5	YES	3
2	1.2	115	138.0	13.1	8.10	47.5	YES	3
3	1.2	115	138.0	13.2	8.20	48.9	YES	3
4	1	115	115.0	12.8	8.10	47.3	YES	3
5	1	115	115.0	12.7	8.10	47.6	YES	3
6	1.2	115	138.0	12.1	8.20	52.4	YES	3
7	1.2	115	138.0	11.2	8.30	57.7	YES	3
8	1.2	115	138.0	11.2	8.20	55.7	YES	3
9	1.2	115	138.0	11.5	8.10	52.7	YES	3
10	1.2	115	138.0	12.1	8.10	50.6	YES	3
11	1.2	115	138.0	12.4	8.20	51.4	YES	3
12	1.2	115	138.0	12.6	8.30	52.8	YES	3
13	0.8	115	92.0	11.9	8.20	50.8	YES	3
14	1	115	115.0	11.5	8.20	53.3	YES	3
15	1	115	115.0	10.9	8.10	53.6	YES	3
16	1	115	115.0	10.8	8.10	53.9	YES	3
17	1.2	115	138.0	10.7	8.20	57.6	YES	3
18	1.2	115	138.0	10.4	8.30	61.0	YES	3
19	1.2	115	138.0	10.3	8.20	59.2	YES	3
20	1.2	115	138.0	10.2	8.30	61.8	YES	3
21	1	115	115.0	9.6	8.20	60.7	YES	3
22	1.2	115	138.0	9.8	8.20	61.2	YES	3
23	1	115	115.0	10.1	8.30	60.8	YES	3
24	1	115	115.0	9.8	8.20	59.8	YES	3
25	1	115	115.0	9.6	8.10	58.5	YES	3
26	0.6	115	69.0	9.2	8.30	61.7	YES	3
27	1	115	115.0	9.8	8.10	57.7	YES	3
28	1	115	115.0	9.3	8.20	61.9	YES	3
29	0.6	115	69.0	9.1	8.10	57.8	YES	3
30	0.6	115	69.0	8.9	8.00	56.5	YES	3
31								

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350