

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: December/2024

System Name: Galice Resort ID#: 41 90808 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	64.00	65.00	-1.00	25.00	0.15	0.15
2	51.00	52.00	-1.00	25.00	0.16	0.16
3	64.00	65.00	-1.00	25.00	0.15	0.15
4	64.00	65.00	-1.00	25.00	0.15	0.15
5	63.00	63.00	0.00	25.00	0.16	0.16
6	62.00	63.00	-1.00	25.00	0.12	0.12
7	49.00	49.00	0.00	25.00	0.10	0.10
8	47.00	46.00	1.00	25.00	0.05	0.05
9	50.00	50.00	0.00	25.00	0.05	0.05
10	62.00	63.00	-1.00	25.00	0.08	0.08
11	63.00	64.00	-1.00	25.00	0.07	0.07
12	63.00	64.00	-1.00	25.00	0.07	0.07
13	62.00	63.00	-1.00	25.00	0.07	0.07
14	51.00	52.00	-1.00	25.00	0.08	0.08
15	52.00	53.00	-1.00	25.00	0.07	0.07
16	52.00	53.00	-1.00	25.00	0.07	0.07
17	59.00	60.00	-1.00	25.00	0.07	0.07
18	59.00	60.00	-1.00	25.00	0.07	0.07
19	59.00	60.00	-1.00	25.00	0.07	0.07
20	52.00	52.00	0.00	25.00	0.07	0.07
21	52.00	53.00	-1.00	25.00	0.08	0.08
22	63.00	64.00	-1.00	25.00	0.14	0.14
23	49.00	49.00	0.00	25.00	0.21	0.21
24	51.00	51.00	0.00	25.00	0.16	0.16
25	51.00	51.00	0.00	25.00	0.17	0.17
26	51.00	52.00	-1.00	25.00	0.14	0.14
27	63.00	64.00	-1.00	25.00	0.13	0.13
28	53.00	54.00	-1.00	25.00	0.12	0.12
29	51.00	52.00	-1.00	25.00	0.13	0.13
30	51.00	52.00	-1.00	25.00	0.14	0.14
31	62.00	63.00	-1.00	25.00	0.12	0.12

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes	Yes

Notes: PSI = pounds per square inch	PRINTED NAME: Kurt Swanson
PSID = pounds per square inch difference (before filter - after filter)	SIGNATURE: Kurt Swanson DATE: 12/1/2024
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PHONE #: (541)476-3818 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form						WTP- :	
System Name:	Galice Resort	ID#: 41	90808	Month/Year:	12/2024	Disinfection <i>Giardia</i> Log Inactiv:	1

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	115	138.0	8.3	8.10	65.4	YES	3
2	1	115	115.0	8.3	8.00	61.6	YES	3
3	1	115	115.0	7.5	8.10	67.5	YES	3
4	0.8	115	92.0	7.5	8.10	65.9	YES	3
5	0.8	115	92.0	7.7	8.10	65.0	YES	3
6	0.6	115	69.0	8.2	8.10	61.4	YES	3
7	0.6	115	69.0	8.8	8.00	56.9	YES	3
8	0.6	115	69.0	9.1	8.10	57.8	YES	3
9	0.6	115	69.0	9.0	8.10	58.2	YES	3
10	0.8	115	92.0	8.2	8.10	62.9	YES	3
11	0.8	115	92.0	7.7	8.00	62.7	YES	3
12	0.8	115	92.0	8.4	8.10	62.0	YES	3
13	0.8	115	92.0	8.4	8.10	62.0	YES	3
14	0.8	115	92.0	8.6	8.10	61.2	YES	3
15	0.8	115	92.0	8.8	8.10	60.3	YES	3
16	0.6	115	69.0	8.6	8.20	62.0	YES	3
17	0.8	115	92.0	9.2	8.10	58.7	YES	3
18	0.6	115	69.0	9.7	8.10	55.5	YES	3
19	0.8	115	92.0	9.8	8.20	58.5	YES	3
20	0.6	115	69.0	9.7	8.10	55.5	YES	3
21	0.6	115	69.0	10.1	8.00	52.1	YES	3
22	0.6	115	69.0	10.6	8.10	52.2	YES	3
23	0.6	115	69.0	10.9	8.10	51.2	YES	3
24	0.8	115	92.0	10.2	8.00	53.0	YES	3
25	0.8	115	92.0	10.7	8.00	51.2	YES	3
26	0.8	115	92.0	10.3	8.00	52.6	YES	3
27	0.8	115	92.0	10.7	8.10	53.1	YES	3
28	0.8	115	92.0	9.9	8.10	56.0	YES	3
29	0.8	115	92.0	9.8	8.00	54.4	YES	3
30	0.8	115	92.0	9.5	8.00	55.5	YES	3
31	0.8	115	92.0	9.5	8.00	55.5	YES	3