

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Jan-25
System Name:	Galice Resort			ID#: 41-90808		WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	61.00	61.00	0	25.00	0.06	0.06	
2	63.00	63.00	0	25.00	0.10	0.10	
3	63.00	63.00	0	25.00	0.08	0.08	
4	63.00	63.00	0	25.00	0.10	0.10	
5	63.00	63.00	0	25.00	0.09	0.09	
6	54.00	52.00	2	25.00	0.10	0.10	
7	54.00	52.00	2	25.00	0.13	0.13	
8	63.00	63.00	0	25.00	0.10	0.10	
9	62.00	62.00	0	25.00	0.10	0.10	
10	62.00	62.00	0	25.00	0.10	0.10	
11	62.00	62.00	0	25.00	0.04	0.04	
12	60.00	60.00	0	25.00	0.05	0.05	
13	61.00	61.00	0	25.00	0.05	0.05	
14	62.00	62.00	0	25.00	0.05	0.05	
15	63.00	63.00	0	25.00	0.05	0.05	
16	64.00	64.00	0	25.00	0.07	0.07	
17	64.00	63.00	1	25.00	0.06	0.06	
18	64.00	63.00	1	25.00	0.06	0.06	
19	64.00	64.00	0	25.00	0.07	0.07	
20	64.00	64.00	0	25.00	0.07	0.07	
21	64.00	64.00	0	25.00	0.07	0.07	
22	65.00	64.00	1	25.00	0.07	0.07	
23	65.00	64.00	1	25.00	0.07	0.07	
24	52.00	48.00	4	25.00	0.07	0.07	
25	52.00	48.00	4	25.00	0.05	0.05	
26	62.00	62.00	0	25.00	0.06	0.06	
27	63.00	62.00	1	25.00	0.07	0.07	
28	63.00	61.00	2	25.00	.,07	0.07	
29	63.00	62.00	1	25.00	0.07	0.07	
30	63.00	63.00	0	25.00	0.07	0.07	
31	50.00	48.00	2	25.00	0.07	0.07	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch					PRINTED NAME: Kurt Swanson		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE:Kurt Swanson		DATE:1/31/2025
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					541-476-3818		CERT #:
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP: :	
System Name:	GALICE RESORT	41-90808		January/2025		Disinfection Giardia Log Inactiv:	0.5	
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	114	68.4	9.7	8.00	26.8	YES	3
2	0.6	114	68.4	9.8	8.00	26.6	YES	3
3	0.6	114	68.4	10.1	8.00	26.1	YES	3
4	0.6	114	68.4	10.8	8.00	24.9	YES	3
5	0.6	114	68.4	11.0	8.00	24.5	YES	3
6	0.6	114	68.4	11.3	8.00	24.04	YES	3
7	0.6	114	68.4	11.2	8.00	24.2	YES	3
8	0.6	114	68.4	9.3	8.00	27.49	YES	3
9	0.6	114	68.4	9.1	8.00	27.86	YES	3
10	0.6	114	68.4	9.0	8.00	28.05	YES	3
11	0.6	114	68.4	9.8	8.00	26.58	YES	3
12	0.6	114	68.4	9.9	8.00	26.40	YES	3
13	0.6	114	68.4	9.8	8.00	26.58	YES	3
14	0.6	114	68.4	9.8	8.00	26.58	YES	3
15	0.6	114	68.4	7.4	8.00	31.27	YES	3
16	0.6	114	68.4	7.8	7.80	28.31	YES	3
17	0.6	114	68.4	7.9	7.90	29.15	YES	3
18	0.6	114	68.4	7.6	7.90	29.75	YES	3
19	0.6	114	68.4	7.5	7.80	28.89	YES	3
20	0.6	114	68.4	6.6	7.80	30.71	YES	3
21	0.6	114	68.4	6.4	7.90	32.28	YES	3
22	0.6	114	68.4	6.1	7.80	31.77	YES	3
23	0.6	114	68.4	6.8	7.90	31.41	YES	3
24	0.6	114	68.4	6.9	7.90	31.20	YES	3
25	0.6	114	68.4	6.8	7.80	30.29	YES	3
26	0.6	114	68.4	6.1	7.80	31.77	YES	3
27	0.6	114	68.4	5.9	7.80	32.21	YES	3
28	0.6	114	68.4	5.9	7.90	33.40	YES	3
29	0.6	114	68.4	6.0	7.90	33.17	YES	3
30	0.6	114	68.4	6.2	7.80	31.55	YES	3
31	0.6	114	68.4	6.2	7.70	30.43	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2