

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Feb-25
System Name:	Galice Resort			ID#: 41-90808		WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	62.00	62.00	0	25.00	0.10	0.10	
2	62.00	62.00	0	25.00	0.11	0.11	
3	49.00	41.00	8	25.00	0.11	0.11	
4	63.00	63.00	0	25.00	0.12	0.12	
5	62.00	62.00	0	25.00	0.12	0.12	
6	63.00	63.00	0	25.00	0.13	0.13	
7	63.00	63.00	0	25.00	0.12	0.12	
8	63.00	63.00	0	25.00	0.12	0.12	
9	62.00	62.00	0	25.00	0.10	0.10	
10	62.00	62.00	0	25.00	0.07	0.07	
11	62.00	62.00	0	25.00	0.07	0.07	
12	62.00	62.00	0	25.00	0.07	0.07	
13	62.00	62.00	0	25.00	0.07	0.07	
14	65.00	65.00	0	25.00	0.07	0.07	
15	65.00	64.00	1	25.00	0.08	0.08	
16	65.00	64.00	1	25.00	0.08	0.08	
17	63.00	62.00	1	25.00	0.09	0.09	
18	65.00	63.00	2	25.00	0.09	0.09	
19	65.00	62.00	3	25.00	0.08	0.08	
20	65.00	64.00	1	25.00	0.08	0.08	
21	65.00	64.00	1	25.00	0.08	0.08	
22	64.00	62.00	2	25.00	0.08	0.08	
23	65.00	64.00	1	25.00	0.09	0.09	
24	65.00	63.00	2	25.00	0.08	0.08	
25	64.00	63.00	1	25.00	0.10	0.10	
26	64.00	62.00	2	25.00	0.09	0.09	
27	65.00	65.00	0	25.00	0.09	0.09	
28	64.00	63.00	1	25.00	0.09	0.09	
29				25.00			
30				25.00			
31				25.00			
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE:Kurt Swanson		DATE:2/31/2025	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818		CERT #:	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP: :	
System Name:	GALICE RESORT	41-90808		Febuary/2025		Disinfection Giardia Log Inactiv:	0.5	
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	114	68.4	9.2	7.80	25.8	YES	3
2	0.6	114	68.4	9.4	7.80	25.4	YES	3
3	0.6	114	68.4	8.5	7.80	27.0	YES	3
4	0.6	114	68.4	8.2	7.80	27.6	YES	3
5	0.6	114	68.4	8.2	7.80	27.6	YES	3
6	0.6	114	68.4	8.3	7.70	26.41	YES	3
7	0.6	114	68.4	8.2	7.80	27.6	YES	3
8	0.6	114	68.4	8.0	7.90	28.95	YES	3
9	0.6	114	68.4	7.9	7.80	28.12	YES	3
10	0.6	114	68.4	7.6	7.80	28.69	YES	3
11	0.6	114	68.4	7.1	7.80	29.68	YES	3
12	0.6	114	68.4	6.4	7.90	32.28	YES	3
13	0.6	114	68.4	8.2	7.90	28.56	YES	3
14	0.6	114	68.4	8.6	7.80	26.82	YES	3
15	0.6	114	68.4	9.3	7.80	25.59	YES	3
16	0.6	114	68.4	10.4	7.80	23.78	YES	3
17	0.6	114	68.4	10.8	7.80	23.16	YES	3
18	0.6	114	68.4	11.5	7.90	22.90	YES	3
19	0.6	114	68.4	11.7	7.90	22.60	YES	3
20	0.6	114	68.4	11.8	7.80	21.68	YES	3
21	0.6	114	68.4	11.7	7.90	22.60	YES	3
22	0.6	114	68.4	12.4	7.80	20.84	YES	3
23	0.6	114	68.4	13.8	7.80	18.96	YES	3
24	0.6	114	68.4	14.4	7.80	18.21	YES	3
25	0.6	114	68.4	14.6	7.90	18.65	YES	3
26	0.6	114	68.4	12.8	7.90	21.02	YES	3
27	0.6	114	68.4	12.9	7.80	20.12	YES	3
28	0.6	114	68.4	13.2	7.90	20.47	YES	3
29		114						3
30		114						3
31		114						3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2