

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Mar-25
System Name:	Galice Resort			ID#: 41-90808		WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	63.00	62.00	1	25.00	0.09	0.09	
2	50.00	40.00	10	25.00	0.09	0.09	
3	49.00	40.00	9	25.00	0.09	0.09	
4	62.00	62.00	0	25.00	0.10	0.10	
5	62.00	62.00	0	25.00	0.10	0.10	
6	62.00	62.00	0	25.00	0.10	0.10	
7	62.00	62.00	0	25.00	0.10	0.10	
8	62.00	62.00	0	25.00	0.11	0.11	
9	63.00	63.00	0	25.00	0.10	0.10	
10	63.00	63.00	0	25.00	0.10	0.10	
11	63.00	63.00	0	25.00	0.10	0.10	
12	63.00	63.00	0	25.00	0.12	0.12	
13	47.00	39.00	8	25.00	0.13	0.13	
14	49.00	41.00	8	25.00	0.13	0.13	
15	48.00	39.00	9	25.00	0.13	0.13	
16	63.00	63.00	0	25.00	0.13	0.13	
17	63.00	63.00	0	25.00	0.13	0.13	
18	63.00	63.00	0	25.00	0.12	0.12	
19	64.00	63.00	1	25.00	0.11	0.11	
20	64.00	64.00	0	25.00	0.12	0.12	
21	63.00	63.00	0	25.00	0.13	0.13	
22	50.00	40.00	10	25.00	0.12	0.12	
23	64.00	63.00	1	25.00	0.12	0.12	
24	49.00	40.00	9	25.00	0.11	0.11	
25	48.00	40.00	8	25.00	0.10	0.10	
26	48.00	39.00	9	25.00	0.12	0.12	
27	63.00	63.00	0	25.00	0.12	0.12	
28	64.00	64.00	0	25.00	0.13	0.13	
29	63.00	63.00	0	25.00	0.13	0.13	
30	64.00	64.00	0	25.00	0.13	0.13	
31	63.00	63.00	0	25.00	0.13	0.13	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: Kurt Swanson			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818			CERT #:
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	
System Name:	GALICE RESORT	41-90808					Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	114	68.4	13.8	7.80	19.0	YES	3
2	0.6	114	68.4	13.9	7.80	18.8	YES	3
3	0.6	114	68.4	14.1	7.80	18.6	YES	3
4	0.8	114	91.2	14.9	7.80	18.0	YES	3
5	0.8	114	91.2	14.8	7.70	17.5	YES	3
6	0.8	114	91.2	14.7	7.70	17.60	YES	3
7	0.8	114	91.2	14.6	7.80	18.4	YES	3
8	0.8	114	91.2	14.1	7.70	18.32	YES	3
9	0.8	114	91.2	14.3	7.60	17.42	YES	3
10	0.8	114	91.2	14.6	7.50	16.46	YES	3
11	0.8	114	91.2	14.8	7.60	16.85	YES	3
12	1.2	114	136.8	15.0	7.50	16.77	YES	3
13	1.2	114	136.8	15.2	7.50	16.55	YES	3
14	1.1	114	125.4	14.7	7.50	16.92	YES	3
15	1.2	114	136.8	14.8	7.50	17.00	YES	3
16	1.2	114	136.8	15.1	7.40	16.05	YES	3
17	1.2	114	136.8	15.4	7.30	15.16	YES	3
18	1.2	114	136.8	15.5	7.40	15.63	YES	3
19	1.2	114	136.8	15.6	7.40	15.53	YES	3
20	1.2	114	136.8	15.9	7.50	15.79	YES	3
21	1	114	114	16.3	7.50	15.03	YES	3
22	1.2	114	136.8	16.7	7.30	13.90	YES	3
23	1.2	114	136.8	17.0	7.40	14.14	YES	3
24	1.2	114	136.8	17.6	7.40	13.59	YES	3
25	1.2	114	136.8	18.1	6.80	10.50	YES	3
26	1.2	114	136.8	17.2	7.50	14.48	YES	3
27	1.2	114	136.8	18.6	7.40	12.70	YES	3
28	1.2	114	136.8	18.9	7.40	12.45	YES	3
29	1.2	114	136.8	18.7	7.40	12.62	YES	3
30	1.2	114	136.8	19.1	7.40	12.29	YES	3
31	1	114	114	18.8	7.40	12.25	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dlwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2